



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Craig W. Butler, Director

February 2, 2015

Re: Brunersburg Water District PWSID: OH2001103
Brunersburg Evansport PWSID: 2001203
Compliance Review
Letter of Compliance
Drinking Water Program
Defiance County

Brunersburg Water District
22485 Mill Street
Defiance, Ohio 43512

Subject: Certified Operator Compliance

The Ohio Environmental Protection Agency's (Ohio EPA), Division of Drinking and Ground Waters (DDAGW) received your operator of record notification forms. You designated Rick L. Schantz (WS4-1010680-99) and James A. Pauley (WS1-1131965-14) as the operators of record for the above referenced public water systems in accordance with Ohio Administrative Code (OAC) Rule 3745-7-02 (A)(2).

In accordance with OAC Rule 3745-7-03(C), the operator of record for a Class 1 PWS is required to be physically present at each PWS for a minimum of three days per week for one and one-half hours per week.

Within three days of any future change in the operator of record please use the Operator of Record Notification Form found at:
http://www.epa.ohio.gov/portals/28/documents/opcert/Operator_of_Record_NotificationForm.pdf

If you have any questions, feel free to contact Susan Wyatt at (614) 644-2752.

Sincerely,

A handwritten signature in black ink that reads "Andrew Barienbrock". The signature is written in a cursive, flowing style.

Andrew Barienbrock
Environmental Supervisor
Division of Drinking and Ground Waters

cc: Rick L. Schantz, 300 South Defiance Street, Archbold, Ohio 43502
James A. Pauley, 22485 Mill Street, Defiance, Ohio 43512