



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Craig W. Butler, Director

NOTICE OF VIOLATION – ACTION REQUIRED

June 20, 2016

RE: Scio PWS
NOV
Drinking Water Program
Harrison County
PWS ID: OH3401312

MICHELLE CARPENTER
SCIO PWS
PO BOX 307
SCIO, OH 43988

Dear Ms. Carpenter:

Scio PWS is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for manganese which is 0.05 mg/L. There were 4 weekly samples during the month of May in which manganese exceeded the secondary standard.

Monitoring and compliance determinations for the secondary maximum contaminant level for manganese are as follows:

- (a) Public water systems shall use the monitoring required by OAC 3745-83-01 (F)(6) to determine compliance with the secondary maximum contaminant level for manganese.
- (b) A public water system shall be in violation of the secondary standard for manganese when more than 25% of the monthly samples collected at each entry point to the distribution system exceed the secondary maximum contaminant level.

Scio must take immediate action to resolve this violation. Ohio EPA may take action to enforce the requirements of its drinking water rules. A civil penalty could be assessed as part of this enforcement action. Your response to this letter is required by July 20, 2016.

Scio PWS
June 20, 2016
Page 2

If you have any questions, please call me at (740) 380-5421. E-mail is also available at debra.prim@epa.ohio.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "Debra Prim", written in a cursive style.

Debra Prim
Environmental Specialist
Ohio EPA, Division of Drinking Water

DP/cb

cc: Harrison County Health Department
cc: Jim Albright
One Service Garage Rd.
Cadiz, OH 43907