

RE: Hopewell Estates MHP
Report
Drinking Water Program
Seneca County
PWS ID: OH7401412

RECEIVED

FEB 21 2017

DDAGW - NWDO



- LEGEND**
- NON-LEAD SERVICE CONNECTIONS
 - LEAD AND COPPER SAMPLE SITES

NOTES

HOPEWELL ESTATES MHP WAS CONSTRUCTED AFTER 1970.

ALL WATER DISTRIBUTION MAINS ARE PVC PIPE.

ALL WATER SERVICE LINES ARE HOPE TUBING.

NOTE:

BUILDINGS IN OHIO BUILT PRIOR TO 1998 OR THAT USE PLUMBING MATERIAL OR SOLDER MANUFACTURED BEFORE 1998 MAY HAVE MATERIALS WITH GREATER THAN 8% LEAD AND ARE AT A HIGHER RISK OF CONTRIBUTING LEAD TO THE DRINKING WATER THAN MATERIALS MANUFACTURED AFTER 1998. IN ADDITION, BUILDINGS BUILT AND PLUMBING MATERIALS MANUFACTURED AFTER 2014 WERE REQUIRED TO HAVE LESS THAN 0.25% LEAD BY WEIGHT AND HAVE THE LOWEST RISK FOR CONTRIBUTING LEAD TO THE DRINKING WATER. IT SHOULD BE NOTED HOWEVER THAT, ALTHOUGH PROHIBITED, SOME USE OF LEADED SOLDER OR LEADED COMPONENTS MAY HAVE OCCURRED AFTER THE PROHIBITIONS BECAME EFFECTIVE.

CASEMENT REFERENCE		
City/Co. No.	County Recorder Volume Page	Exhibit

REVISIONS			
No.	Description	Approval	Date
AS BUILT			

Drawn/Prepared by

Makeever Associates, Inc.
 11000 W. STATE ROUTE 18, SUITE 100
 FOSTORIA, OHIO 44830
 Phone: 419.242.0101 Fax: 419.242.0102

LEAD MAPPING IN DISTRIBUTION SYSTEM

PWS ID: OH7401412

DATE FILED NO.	
MAP ACCT. NO.	
CONTRACT NO.	
COMPLETION DATE	
CONTRACTOR	

HOPEWELL ESTATES MHP

8702 WEST STATE ROUTE 18
FOSTORIA, OHIO 44830

Scale: Horizontal = AS NOTED Vertical = AS NOTED	Sheet No. 1 OF 1
Original Sheet Size = 24"x36"	S:\V001\162\015
Date: 1/7/2017	Drawn by: Hopewell Estates Water PWS