

RECEIVED  
 FEB 24 2017  
 Central District Office  
 Civil Eng

# VILLAGE OF MT. GILEAD, OHIO

## WATER DISTRIBUTION SYSTEM

### 1993

REVISED DECEMBER 2001  
 GRAPHIC SCALE IN FEET

**Description:**

- (PB) Lead water service lines have been found throughout our Water Distribution System whether on RMS side or on Private/Customer Side.
  - Public Water System (RMS) Side (PB) Lead water service lines when discovered they are immediately replaced with type K copper tubing and fittings labeled NG Lead.
  - Private/Customer Side (PB) Lead water service lines when discovered, Tenant/Property owner is contacted and made aware of.
- We are currently in the process of changing out water meters in our distribution System. When doing so a record is being made of the following:
- Type of Plumbing (Water Service Line) entering Bldg./House
  - Type of Plumbing (Water Service Line) on outlet side of meter for Interior Plumbing
- Records are being maintained when any excavation is done on water distribution mains. Service lines to identify our areas of (PB) Lead Service Lines.

**Tier 2 Sample Sites - Yellow Lead Parcels - Lead (PB) Service Lines**

- 20 W High St - Business - RMS
- 23 S Main St - Business - RMS

**Tier 1 Sample Sites - Yellow Lead Parcels - Lead (PB) Service Lines**

- 334 W High St - Residential Home - RMS
- 222 W High St - Residential Home - RMS
- 194 W Marion St - Residential Home - RMS
- 177 W Marion St - Residential Home - RMS
- 167 E Marion St - Residential Home - RMS
- 74 E High St - Residential Home - RMS
- 124 N Walnut St - Residential Home - RMS
- 118 E Union St - Residential Home - RMS
- 220 N Main St - Residential Home - RMS
- 201 N Main St - Residential Home - RMS



Service lines known to be (PB) Lead  
 Service lines known to be (CC) Copper  
 Service lines known to be something other than (PB) Lead or (CC) Copper  
 Tier 2 Sample Sites

BURGESS & NIPLER

Prepared By: D. St. Clair  
 List: 01/25/01  
 2-21-2017