

# St. Peter's/Panda Lead and Copper Map

PREPARED FOR: Patricia Vanah, NEDO-OEPA  
COPY TO: ODH – [BEH@odh.ohio.gov](mailto:BEH@odh.ohio.gov); ODJFS – Bureau of Child Care Licensing and Monitoring  
PREPARED BY: Jim Borton – WS3-1008381-09  
330-201-1945 or [jimborton87@gmail.com](mailto:jimborton87@gmail.com)  
DATE: March 2, 2017

This report summarizes the presence, to the best of our knowledge, of lead and copper within the St. Peter's Lutheran Church/Panda Preschool building located at 9451 Ashland Rd., Wooster, Ohio 44691. Phone number for church is 330-264-1986.

The original kitchen was installed in 1974 and remodeled in 1998. A new main line was extended to the kitchen in 1974, but no records exist on if it was upgraded in 1988. In any case, while the lines to the sinks may have been replaced then, the main line from the well to the kitchen area might not have been. Likewise, we do know the lines from the main line to the restrooms and drinking fountain were upgraded in 2008, but again these area are still is served by the main 1" copper with soldered joints line. As such we have chosen the tier 2 designation to be most representative of the main line. We do know everything is copper or plastic, just don't know the age to determine the status of lead free or not. Fixtures are all newer than 1988, so likely to be lower in lead or lead free.

The identified sites, excluding the communion room are the sites sampled for lead and copper in 2015, and were all in compliance with the applicable standards for lead and copper levels. The 2017 sampling plan does not indicate lead and copper monitoring. As such the next scheduled sampling event will be 2018.

The associated lead and copper locations are listed below and are also indicated on the map.

LC201	N. Kitchen Sink
LC202	S. Kitchen Sink
LC203	Drinking Fountain
LC204	Men's RR
LC205	Women's RR

System map is shown below:



