

RE: Landeck Elementary School
Report
Drinking Water Program
Allen County
PWS ID: OH0253512

February 117, 2017

Landeck School
14750 Landeck Rd.
Delphos, Ohio 45833

PWS# OHO253512
STU# 252710

RECEIVED

MAR 03 2017

OHIO E.P.A.
N.W.D.O.

Building built in 1916. Has mixture of copper, which feeds boys and girls restroom toilets & urinals and girls sinks. Plastic 1" line from well into building to FRP bladder tanks, treatment system is all 1" PVC 40 & or PVC 80. ¾" CPVC runs to boys bathroom sinks and to 2nd floor drinking fountains, that is the only water on the second or third floor.

Buildings in Ohio built prior to 1998 or that use plumbing material or solder manufactured before 1998 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1998. In addition, buildings built and plumbing materials manufactured after 2014 were required to have less than 0.25% lead by weight and have the lowest risk for contributing lead to the drinking water. It should be noted, however, that although prohibited, some use of lead solder or leaded components may have occurred after the prohibitions became effective.