

RE: Firelands Manor  
Report  
Drinking Water Program  
Huron County  
PWS ID: OH3946912

RECEIVED

MAR 03 2017

DDAGW - NWDO



U.S. ROUTE 20 (RW VARIES)

LEAD AND COPPER SAMPLE SITES:

- ① LC201 - LOT # 82 - ROBIN ADAMS-MCNEELY
- ② LC202 - LOT # 5 - TRISHA MAXWELL
- ③ LC203 - LOT # 33 - TIMOTHY GREGORY
- ④ LC204 - LOT # 97 - MARK MCCULLOUGH
- ⑤ LC205 - LOT # 147 - DEBREE IDEGIC

LEGEND

- NON-LEAD SERVICE CONNECTIONS
- LEAD AND COPPER SAMPLE SITES

NOTES:

FIRELANDS MANOR MHP WAS CONSTRUCTED AFTER 1972.  
ALL WATER DISTRIBUTION MAINS ARE PVC PIPE.  
ALL WATER SERVICE LINES ARE HDPE TUBING.

NOTE:

BUILDINGS IN OHIO BUILT PRIOR TO 1998 OR THAT USE PLUMBING MATERIAL OR SOLDER MANUFACTURED BEFORE 1998 MAY HAVE MATERIALS WITH GREATER THAN 8% LEAD AND ARE AT A HIGHER RISK OF CONTRIBUTING LEAD TO THE DRINKING WATER THAN MATERIALS MANUFACTURED AFTER 1998. IN ADDITION, BUILDINGS BUILT AND PLUMBING MATERIALS MANUFACTURED AFTER 2014 WERE REQUIRED TO HAVE LESS THAN 0.25% LEAD BY WEIGHT AND HAVE THE LOWEST RISK FOR CONTRIBUTING LEAD TO THE DRINKING WATER. IT SHOULD BE NOTED HOWEVER THAT, ALTHOUGH PROHIBITED, SOME USE OF LEADED SOLDER OR LEADED COMPONENTS MAY HAVE OCCURRED AFTER THE PROHIBITIONS BECAME EFFECTIVE.

LEAD MAPPING IN DISTRIBUTION SYSTEM

PWS ID: OH3946912

ENG. FILE NO. \_\_\_\_\_  
MHP ACCT. NO. \_\_\_\_\_  
CONTRACT NO. \_\_\_\_\_  
COMPLETION DATE: \_\_\_\_\_  
CONTRACTOR: \_\_\_\_\_

FIRELANDS MANOR

5810 US HWY 20 EAST  
WAKEMAN, OHIO 44889

Scale: Horiz. = AS NOTED  
Vert. = AS NOTED  
Printed Sheet Size = 24"x36"  
Original Date = 03/07/2017  
Sheet No. = 1 OF 1  
S:\2015\016\006  
Dep. No. = 2015-016-006

EASEMENT REFERENCE

City's No.	County	Recorder	Volume	Page	Order

REVISIONS

No.	Description	Approval	Date
	AS BUILT		

Prepared by



AS BUILT