

**LEAD AND COPPER SAMPLE SITES:**

- ① LC201 - LOT # 130 - LOUIS HEZEBICKS
- ② LC202 - LOT # 112 - BRANDI WARD
- ③ LC203 - LOT # 8 - MARY ANGULO
- ④ LC204 - LOT # 127 - DARREN BRUSH
- ⑤ LC205 - LOT # 16 - JOHN KRAUSE

**LEGEND**


- NON-LEAD SERVICE CONNECTIONS
- LEAD AND COPPER SAMPLE SITES

**NOTES:**

AUSTIN MANOR MHP WAS CONSTRUCTED AFTER 1972.  
 ALL WATER DISTRIBUTION MAINS ARE AC PIPE OR PVC PIPE.  
 ALL WATER SERVICE LINES ARE COPPER TUBING OR HDPE TUBING.

**NOTE:**

BUILDINGS IN OHIO BUILT PRIOR TO 1998 OR THAT USE PLUMBING MATERIAL OR SOLDER MANUFACTURED BEFORE 1998 MAY HAVE MATERIALS WITH GREATER THAN 8% LEAD AND ARE AT A HIGHER RISK OF CONTRIBUTING LEAD TO THE DRINKING WATER THAN MATERIALS MANUFACTURED AFTER 1998. IN ADDITION, BUILDINGS BUILT AND PLUMBING MATERIALS MANUFACTURED AFTER 2014 WERE REQUIRED TO HAVE LESS THAN 0.25% LEAD BY WEIGHT AND HAVE THE LOWEST RISK FOR CONTRIBUTING LEAD TO THE DRINKING WATER. IT SHOULD BE NOTED HOWEVER THAT, ALTHOUGH PROHIBITED, SOME USE OF LEADED SOLDER OR LEADED COMPONENTS MAY HAVE OCCURRED AFTER THE PROHIBITIONS BECAME EFFECTIVE.



EASEMENT REFERENCE		
City's No.	County Recorder Volume	Page

REVISIONS			
No.	Description	Approval	Date
AS BUILT			

Plans Prepared By :

**Aakever & Associates, Inc.**  
 P.O. BOX 325, 1810 E. MANSFIELD ST.  
 BUCYRUS, OHIO 44820  
 Phone: (419) 562-7757 Fax: (419) 562-4717

**LEAD MAPPING IN DISTRIBUTION SYSTEM**

PWS ID: OH0401512

ENG. FILE NO. \_\_\_\_\_  
 IMP. ACCT. NO. \_\_\_\_\_  
 CONTRACT NO. \_\_\_\_\_  
 COMPLETION DATE \_\_\_\_\_  
 CONTRACTOR \_\_\_\_\_

**AUSTIN MANOR MHP**

**3583 & 3651 AUSTIN ROAD**  
**GENEVA, OHIO 44041**

Scale : Horiz. = AS NOTED  
 Vert. = AS NOTED  
 Original Sheet Size = 24"x36"  
 Original Date : 03/02/2017

Sheet No. : 1 OF 1  
 S:\2013\014\007  
 Dwg. No. : 2013-014-007