RE:

Brunersburg WD - Evansport Report Drinking Water Program Defiance County PWS ID: OH2001203

BRUNERSBURG WATER DISTRICT 22485 MILL STREET DEFIANCE OH 43512 PHONE: 419-782-7888 March 3, 2017

MAR 0 6 2017
OHIO E.P.A.
N.W.D.O.

OHIO EPA 347 N Dunbridge Rd Bowling Green OH 43402

To whom it may concern,

The Brunersburg WD – Evansport Waterline was installed in 1998. The water main is a 10" plastic line. All service lines to the curb box are plastic.

Because it is practically impossible to determine the lead content of an installed fixture, fitting or pipe, it should be assumed that the manufacture or installation date is the primary indicator of the lead content. Therefore; the characteristics of buildings and piping solder or fixtures would be buildings in Ohio built prior to 1998 or that used plumbing material or solder manufactured before 1998 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1998. In addition, buildings built and plumbing materials manufactured after 2014 were required to have less than .25% lead by weight and have a lowest risk for contributing lead in the drinking water. It should be noted however that, although prohibited, some use of solder or lead components may have occurred after the prohibitions became effective.

Sincerely,

Jim Harris, President Brunersburg Water District BRUNERSBURG WD - EVANSPORT OH2001203 (1 OF 7)



NON-LEAD
LEAD
ROADS

500 250 0 500 Feet

BRUNERSBURG WD - EVANSPORT OH2001203 (2 OF 7)

2005

1974

2008



PARCELS

NON-LEAD

LEAD

ROADS

500 250 0 500 Feet

1

BRUNERSBURG WD - EVANSPORT OH2001203 (3 OF 7)



PARCELS
NON-LEAD
LEAD
ROADS



7

BRUNERSBURG WD - EVANSPORT OH2001203 (4 OF 7)



NON-LEAD
LEAD
ROADS



BRUNERSBURG WD - EVANSPORT OH2001203 (5 OF 7)



NON-LEAD
LEAD
ROADS



BRUNERSBURG WD - EVANSPORT OH2001203 (6 OF 7)



NON-LEAD
LEAD
ROADS

180 90 0 180 Feet

BRUNERSBURG WD - EVANSPORT OH2001203 (7 OF 7)







7