

RE: HENRY COUNTY  
REGIONAL WSD – Co Rd P  
Report  
Drinking Water Program  
Henry County  
PWS ID: OH3539212

**District Board of Trustees**

Brian Baker  
Dean Dawson  
Tim Phillip- Vice Chairman  
Marvin Arps- Chairman  
Amy Behrman- Treasurer

HCRW&S District  
1857 Oakwood Avenue  
Napoleon, Ohio 43545  
Ph: 419.599.7370  
Fax: 419.592.4016



**RECEIVED**

**MAR 07 2017**

**OHIO E.P.A.  
N.W.D.O.**

Lead and Copper Mapping Report- HB 512

Road P System

**PWS #OH3539212**

March 6, 2017

**District Board of Trustees**

Brian Baker  
Dean Dawson  
Tim Phillip- Vice Chairman  
Marvin Arps- Chairman  
Amy Behrman- Treasurer

HCRW&S District  
1857 Oakwood Avenue  
Napoleon, Ohio 43545  
Ph: 419.599.7370  
Fax: 419.592.4016



**Road P Water System- PWS OH3539212**

McClure OH 43534

**Narrative of Current Water System**

The Road P waterline was installed in 2002 to service an industrial area both with potable water and fire protection located Harrison Township. This project was a joint venture between the Henry County Commissioners, the City of Napoleon, and the Henry County CIC. At the same time the line was being constructed the formation of the District was being processed in the court system. Once this line was completed and put into service it was turned over to the District. The District contracted with the City of Napoleon to remain as the ORC from 2002-2011 since this line was already part of their system. After 2011 the District became the ORC.

The material used for this water system was a 12" C900 PVC pipe. All service lines were either plastic or copper with a curb stop located at the right of way. There are currently 13 service connections on this system.


The first lead and copper sampling period for the District on this system was in 2013. This system was combined with the SR 108 line and 5 samples were taken from the two lines combined according to the monitoring schedule from the OEPA. If more sampling is required additional sites may have to be added but will be limited due to the number of service connections on both lines.

Most of the homes connected to this system were built between 1880 to 2006 with the majority of them built in the late 1970's according the Henry County Auditor's website. Construction material of the interior plumbing in most cases has not been verifiable by the District.

Included in this packet is a waterline map of the distribution system of Road P, a map indicating lead and copper sampling points (blue dots), and names and addresses of the sampling location.

HENRY COUNTY REGIONAL WATER AND SEWER DISTRICT

# Road P- Pb & Cu Sampling Points (PWS OH3539212)




March 6, 2017

- Parcels
- SectionLines
- RightOfWayNPL
- Incorporation Lines
- Street\_Centerlines
- COUNTY ROAD
- TOWNSHIP ROAD
- STREET

**RECEIVED**

**MAR 07 2017**

**OHIO E.P.A.  
N.W.D.O.**



Dan Jenkins  
Esri, HERE, DeLorme, MapmyIndia, © OpenStreetMap contributors

Henry County GIS  
Henry County Engineer



Environmental  
Protection Agency  
Division of Drinking and Ground Waters

RECEIVED

MAR 07 2017

OHIO E.P.A.  
N.W.D.O.



EPA 5105 Appendix

# DRINKING WATER LEAD AND COPPER MONITORING REPORT

Submit with Form EPA 5105

Page \_\_\_\_ of \_\_\_\_ pages

PWS Name: HCRW&SD	PWSID: 3539212 OH	Analytical Laboratory Name: Masi	Laboratory Certification No.: 4039
-------------------	-------------------------	-------------------------------------	---------------------------------------

List samples sequentially by Laboratory Sample Number

Date of Sample	Time Sample Taken	Laboratory Sample Number	Address of Sample Site  Example: 234 S Main St Town OH 40000	Tap Type* and Location  Example: B 2 <sup>nd</sup> floor	Structure Type SFR, MFR or BLDG	Interior Plumbing Material Pb, CuPb>82, CuPb<83, or other	Service Line Material Pb, Cu, or other	Tier 1, 2, 3, or other	Lead Conc (ug/L)	Copper Conc (ug/L)
09/27/13	1000	124236	N 527 ST RT 108	K 1 <sup>st</sup> floor	SFR	CuPb	Cu	1	<5.0	<50
09/20/13	0700	147835	11920 Co Rd P	K 1 <sup>st</sup> floor	SFR	CuPb	Cu	1	<5.0	<50
09/30/13	1600	140874	12416 Co Rd P	K 1 <sup>st</sup> floor	SFR	CuPb	Cu	1	<5.0	<50
09/24/13	0830	147836	N 160 ST RT 108	B 1 <sup>st</sup> floor	SFR	CuPb	Cu	1	<5.0	<50
09/24/13	0800	147837	P 314 Twp Rd 12	B 1 <sup>st</sup> floor	SFR	CuPb	Cu	1	<5.0	<50

\*Tap type codes: B – bathroom cold water tap; D – drinking fountain; K – kitchen sink cold water tap; R – restroom sink cold water tap; O – other (with prior Ohio EPA acceptance)

Note: 1 mg/L = 1000 ug/L

**District Board of Trustees**

Brian Baker  
Dean Dawson  
Tim Phillip- Vice Chairman  
Marvin Arps- Chairman  
Amy Behrman- Treasurer

HCRW&S District  
1857 Oakwood Avenue  
Napoleon, Ohio 43545  
Ph: 419.599.7370  
Fax: 419.592.4016



**Road P and SR 108 Water System- PWS OH3539212/ OH3539214**  
Napoleon OH 43545

Pb and Cu Sampling Sites: Address and current owner/ tenant

Phil Johnson	N 527 SR 108
Brent Bischoff	11 920 CR P
Tim Spring	12 416 CR P
Filling Home	N 160 SR 108
Keller Packaging	P 314 TR 12

**RECEIVED**

**MAR 07 2017**

**OHIO E.P.A.  
N.W.D.O.**

HENRY COUNTY REGIONAL WATER AND SEWER DISTRICT