



Legend

- Hydrant
- Valve
- Meter
- Tower

Building Plumbing Material

- Type A
- Type B

Water Main Material

- Type C
- Type D
- Type E
- Type F (Building Service Line)

Building and Plumbing Material		
Building	Building Plumbing Material	Plumbing Installation Date
Type A	Copper with lead solder, steel pipe	Installed before 1983
Type B	Copper with lead solder, galvanized steel pipe	Installed before 1983

Water Main Material	
Water Main	Water Main material
Type C	Ductile iron with lead connection joints
Type D	Ductile iron with gasket connection joints
Type E	PVC

Building Service Lines	
Service Line	Service Line Material
Type F	No Information

Buildings in Ohio built prior to 1988 or that use plumbing material or solder manufactured before 1988 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1988. Buildings built between 1988-2014 likely contain 0.25-0.5% lead. In addition, buildings built and plumbing materials manufactured after 2014 were required to have less than 0.25% lead by weight and have the lowest risk for contributing lead to the drinking water. It should be noted however that although prohibited, some use of leaded solder or leaded components may have occurred after the prohibitions became effective.

Note: All buildings built prior to 1988.