

VERIFICATION FORM FOR COMMUNITY PUBLIC WATER SYSTEMS CLAIMING NO LEAD SERVICE LINES

The owner or operator of all community public water systems must identify and map areas of their distribution system that are known or are likely to contain lead service lines. Systems must submit a copy of the applicable map to the Ohio Department of Health and the Ohio Department of Job and Family Services. Systems must also submit a report to the director containing at least both of the following: (1) The applicable map with narrative, and (2) A list of sampling locations used to collect samples as required by Ohio Revised Code (ORC) Section 6109.121 and any rules adopted thereunder, including contact information for the owner and occupant of each sampling site.

Should a water system determine no lead service lines exist in their distribution system, they must provide information stating they reviewed, at the minimum, historical permit records and local ordinances, distribution maintenance records and information pertaining to installation dates or materials for all services lines. This information must be verified below.

I HEREBY CERTIFY THAT THE FOLLOWING METHOD(S) WERE USED TO DETERMINE NO LEAD SERVICE LINES EXIST IN THIS WATER SYSTEM'S DISTRIBUTION SYSTEM, AS REQUIRED BY ORC 6109.121(F):

LEAD SERVICE LINE VERIFICATION	
<p>This PWS states they have no lead service lines and has reviewed the following information (select one or more of the following):</p> <ul style="list-style-type: none"> <input type="checkbox"/> Historical permit records and/or local ordinances <input checked="" type="checkbox"/> Distribution maintenance records (i.e. meter replacement, waterline break repairs) <input type="checkbox"/> Information pertaining to installation dates for all service lines (i.e. after 1986 when lead services lines were banned) <input type="checkbox"/> Service line material of all service lines is known (i.e. all service lines are known to be PVC) 	

Entity: Pleasant Park
 Doc Type: Report
 Doc Subtype: _____
 Program: OHACW
 County: Trumbull
 Secondary ID: OH7802512

Edward Mosko

Signature of Responsible Person _____ Date _____

Edward Mosko
 Printed Name and Title of Responsible Person _____

PWS NAME: Pleasant Park
PWS ID: OH 7802512
COUNTY: Trumbull

<p>For Ohio EPA use only:</p> <p>Date Verification Rec'd: _____</p>
--

RECEIVED

MAR 08 2017

OHIO EPA NEDO

Pleasant Park
PWS 7802512
community water system

5029 Parkman road northwest
Warren, Ohio 44481

LC 201-Pleasant Park's garage sink- tier 3 -Leo Chiarollo 5029 Parkman road Warren Ohio
LC 202-Pleasant Park's office sink (mobile home) - tier 3 -Leo Chiarollo 5029 Parkman road Warren
LC 203-lot # 45 - kitchen sink (mobile home) - tier 3 -Jim Daugherty 143 Pleasant Park, Warren
LC 204-lot # 54 - kitchen sink (mobile home) - tier 3 -Roger Wolf - 231 Pleasant Park, Warren
LC 205-lot # 95 - kitchen sink (mobile home) - tier 3 -Fraw Hawkins - 256 Pleasant Park, Warren

water room constructed 1970. plastic pipe (pvc) used in water room

well #1- located at end of drive for water building - service is line plastic.
about 100 feet from water room

water room is part of 30 x 45 garage (water room is 10 x 25 walled off area)

well water line enters a 10 x 25 water room where sodium hypochlorite is injected into the water. From there it goes to a bladder tank (40 gallons) followed by two chlorine contact tanks(80 gallons each) .

plumbing is plastic in the water room.

water line goes back into the ground and goes to each mobile home. the water lines in the mobile home park are combination of copper with flare fitting and plastic pipe. when repairing water lines, plastic is used replace where possible.

RECEIVED

MAR 08 2017

OHIO EPA NEDO

Garage That contains Water room



Pleasant Park Plw 57802512

3/5/2017

Imagery ©2017

(https://maps.google.com/maps?ll=41.263987,-80.884107&z=20&t=k&hl=en-US&gl=US&mapclient=api3) http://hd satelliteviewmap.com/Satellite-View/?gclid=COeh-r_hv9ICFYIXDQodG4EKRA