


ALL PORTIONS OF THE SCHOOL
CONSTRUCTED 2009 OR LATER
All internal plumbing in School and
Concession Stand is Copper
Underground Piping from Water Treatment
Plant to School & Concession Stand is a
combination of PVC and Ductile Iron.

Because it is practically impossible to determine the lead content of an installed fixture, fitting or pipe, it should be assumed that the manufacture or installation date is the primary indicator of the lead content. Therefore, the characteristics of buildings and piping solder or fixtures would be buildings built prior to 1998 or that use plumbing material or solder manufactured before 1998 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1998. In addition, buildings built and plumbing materials manufactured after 2014 were required to have less than 0.25% lead by weight and have the lowest risk for contributing lead to the drinking water. It should be noted however that, although prohibited, some use of leaded solder or leaded components may have occurred after the prohibitions became effective."



FAIRLAWN K-12 SCHOOL
Public Water Supply ID: OH7542512

Lead & Copper Fixture Inventory

Mar-17

* Denotes SMP Site

Location/Room #	Description	Type	Quantity
419	Mechanical Room	Water Heater	1
		Backflow Preventor	1
Utility Closet	Student Dining	Mop Sink	1
415	PE Office	Sink	1
		Stool	1
		Shower	1
413	PE Office	Sink	1
		Stool	1
		Shower	1
409	Trainer	Sink	1
		Ice Machine	1
405	Boys Locker Room	Sink	1
		Stool	1
		Urinal	1
		Shower Stall	5
403	Girls Locker Room	Sink	1
		Stool	2
		Shower Stall	5
401	PE Storage	Mop Sink	1
		Washer/Dryer	1
406	Kitchen*	Sink	8
		Dishwasher	1
		Ice Machine	1
		Mixer	1
Student Dining	Fountain 1*	Drinking Fountain	2
427	Boosters	Sink	1
404B	Fountain 2*	Drinking Fountain	2

Location/Room #	Description	Type	Quantity
D435	Boys Locker Room	Sink	1
		Toilet Stalls	1
		Urinal	1
		Shower Stall	5
D435	Girls Locker Room	Sink	1
		Toilet Stalls	2
		Shower Stall	5
310 E	Classroom	Sink	1
C320	Classroom*	Combination Sink/Fountain	1
Restroom	Staff Restroom	Sink	1
	Across from Room 202	Toilet Stalls	1
Restroom	Boys	Sink	3
	Across from Room 202	Toilet Stalls	2
		Urinals	3
Restroom	Girls	Sink	3
	Across from Room 202	Toilet Stalls	5
Hallway	Fountain 3*	Drinking Fountain	2
	Across from Room 202		
201	Classroom*	Combination Sink/Fountain	1
	Restroom	Toilet	1
		Sink	1
203	Teacher Workroom	Sink	1
205	Classroom*	Combination Sink/Fountain	1
	Restroom	Toilet	1
		Sink	1
209	Mechanical	Mop Sink	1
211	Classroom*	Combination Sink/Fountain	1

2009: Year of Contruction/Installation

FAIRLAWN K-12 SCHOOL

Public Water Supply ID: OH7542512

Lead & Copper Fixture Inventory

Mar-17

* Denotes SMP Site

Location/Room #	Description	Type	Quantity
213	Classroom*	Combination Sink/Fountain	1
215	Classroom*	Combination Sink/Fountain	1
217	Classroom*	Combination Sink/Fountain	1
218	Classroom*	Combination Sink/Fountain	1
216	Classroom*	Combination Sink/Fountain	1
214	Classroom*	Combination Sink/Fountain	1
212	Classroom*	Combination Sink/Fountain	1
210	Classroom*	Combination Sink/Fountain	1
208	Classroom*	Combination Sink/Fountain	1
206	Classroom*	Combination Sink/Fountain	1
204	Classroom*	Combination Sink/Fountain	1
202	Classroom	Combination Sink/Fountain	1
Mechanical Room		Mop Sink	1
314	Classroom*	Combination Sink/Fountain	1
302	Classroom	Sink	1
104	301 B Admin. Offices	Sink	1
		Restroom - Toilet	1
		Restroom - Sink	1
108	Classroom - Science	Sink - Cold Water	1
		Eyewash - Cold Water	1
		Lab Stations - Cold Water	6
		Sink	2
112	Classroom - Science	Sink - Cold Water	1
		Eyewash - Cold Water	1
		Lab Stations - Cold Water	6
		Sink	1
113	Mechanical	Mop Sink	1
Hallway	Fountain 7*	Drinking Fountain	2
	Across from Room 114		

Location/Room #	Description	Type	Quantity
125	Classroom - VoAg	Sink	1
		Sink - Cold Water	6
129A	VoAg Shop	Sink	1
Restroom	2 Staff Restrooms	Sink	2
	Across from Room 112	Toilet Stalls	2
Restroom	Boys Locker Room	Sink	3
	Across from Room 112	Toilet Stalls	2
		Urinals	3
Restroom	Girls	Sink	3
	Across from Room 112	Toilet Stalls	5
111	Classroom - Science	Sink - Cold Water	7
		Eyewash - Cold Water	1
		Sink	1
105	Teacher Workroom	Sink	1
103	Classroom - Life Skills	Sink	6
Restroom	Family Restroom	Sink	1
	Located by Room 305 & Door 7	Toilet	1
Restroom	Boys	Sink	3
	Located by Room 305 & Door 7	Toilet Stalls	3
		Urinals	5
Restroom	Girls	Sink	3
	Located by Room 305 & Door 7	Toilet Stalls	8
Hallway	Fountain 4*	Drinking Fountain	2
	Located by Room 305 & Door 7		
Playground	Fountain 5	Drinking Fountain	1
Ball Diamond	Boys Restroom	Sink	1
		Toilet Stall	1
		Urinal	2
Ball Diamond	Girls Restroom	Sink	1
		Toilet Stall	2
Ball Diamond	Concessions	Sink	1
Ball Diamond	Utility Room	Water Heater	1
		Mop Sink	1
Ball Diamond	Fountain 6	Drinking Fountain	2