

Village of Zaleski Water System Stantec PWS ID # OH8200512

Lead Line Mapping Narrative

The Village of Zaleski owns and maintains a public water system that serves approximately 152 customers. The system varies widely in age and condition with the oldest portions being in the central portion of the Village while the newer sections are on the outer areas. The system contains a variety of main line and service line materials as well. New or recent construction projects utilized pvc main line and pe service line and therefore can be classified as not containing lead.

The Village lacks sufficient records to accurately determine areas within the system containing lead service lines or main line joints but did feel that there is most likely no lead in the main lines. They do not have a building department or permit records. Their existing operation and maintenance records do not contain information about the material of existing lines that were repaired. The Village does not use tap cards for new installations nor do they have any historic tap card records. The Village has not implemented a customer self-reporting program to identify lead lines within the distribution system. Due to the lack of adequate record information, the only basis of determination for preparation of the lead line map is age of the building and interviews with staff who have worked on the system.

Because it is practically impossible to determine the lead content of an installed fixture, fitting or pipe, it is assumed that the manufacture or installation date is the primary indicator of the lead content. Therefore, the characteristics of buildings and piping solder or fixtures would be buildings in Ohio built prior to 1998 or that use plumbing material or solder manufactured before 1998 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1998. In addition, buildings built and plumbing materials manufactured after 2014 were required to have less than 0.25% lead by weight and have the lowest risk for contributing lead to the drinking water. It should be noted however that, although prohibited, some use of leaded solder or leaded components may have occurred after the prohibitions became effective.

For the mapping purposes, any buildings or areas constructed prior to 1998 were classified as "no information available", while buildings or areas constructed in 1998 or after were classified as "no lead". The age of the building and area was obtained from waterline construction plans and the knowledge of Village staff.



PROJECT NO. 173409268	
1 OF 1	
VILLAGE OF ZALESKI	PWS ID# OH8200512
UNDERGROUND UTILITIES Two Working Days EFFORE YOU DIS Call 811 (Toll free) OHIO UTILITIES PROTECTION SERVICE NON-MEMBERS MUST BE CALLED DIRECTLY OGGPUPS COCC	
Ohio Oil & Gas Producers Underground Protection Service Call (800) 925–0988	
REVISION:	5
DESCRIPTION	
DATE	
1311 W. HUNTER STREET LOGAN, OHIO43138(740)380-28281-866-558-2828FAX(740)380-3535	
DESIGN <u>GDS</u> DRAWN <u>EZS</u> SCALE: 1" = 300'	
SCALE: <u>1" = 300'</u> Copyright Reserved The Contractor shall verify and be responsible for all dimensions. DO NOT scale the drawing – any errors or omissions shall be reported to Stantec without delay. The Copyrights to all designs and drawings are the property of Stantec. Reproduction or use for any purpose other than that authorized by Stantec is forbidden.	