



## Legend

### LeadFreeWaterLines

#### Diameter

- 0
- 1
- 2
- 3
- 4
- 5
- 6
- 8
- 10
- 12

## PIKE WATER DISTRIBUTION SYSTEM Plant System



Buildings built prior to 1988 or that used plumbing material or solder manufactured before 1988 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1988. In addition, buildings built and plumbing materials manufactured after 2014 were required to have less than 0.2% lead by weight and have the lowest risk for contributing lead to the drinking water. It should be noted however that, although prohibited, some use of leaded solder or leaded components may have occurred after the prohibitions became effective.

1. Pike Water has never used leaded material since beginning operations.
2. Pike Water has always instructed all customers to use PVC piping.
3. This system is approximately 90% PVC and 10% ductile iron.