

RE: MILLIRON IRON AND METAL
Report
Drinking Water Program
Richland County
PWS ID: OH7038212

RECEIVED

MAR 09 2017

DDAGW - NWDO


Milliron Iron and Metal PWS
OH7039212
2391 Springmill Road (SR 39)
Mansfield, OH 44903



Shelby
6 miles

State Route 39

X LAT 40.821113,
LONG -82.596102



2004
Shredder

Lead Sample Locations:

- North Scale House Kitchen
- Maintenance Building Tap
- Shredder Kitchen
- Kitchen
- Media Building Kitchen

North Scale House
1999

CW Building
2014

Pump House
1999

PWS Well

Private Residence
with its own well

Nonferrous Metals
<1980

Old Maintenance Building
1987

Main Office
2002

New Maintenance Building
2016

- Lead =
- Non-Lead =
- No Information =

Buildings in Ohio built prior to 1998 or that use plumbing material or solder manufactured before 1998 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1998. In addition, buildings built and plumbing materials manufactured after 2014 were required to have less than 0.25% lead by weight and have the lowest risk for contributing lead to the drinking water. It should be noted however that, although prohibited, some use of leaded solder or leaded components may have occurred after the prohibitions became effective.

Waterline locations are approximate.

Mansfield
6 miles

