

 = Non-Lead pipes which may contain lead based solder or fittings

 = Verified Lead Containing Components

 = No Information

 = Water lines which may contain Lead



Green Meadows Mobile Home Park
PWS ID #: OH4901812

Green Meadows Mobile Home Park

1 Thornlocust Lane

London, Ohio 43140

PWS ID #: OH4901812

Green Meadows Mobile Home Park homes are fed from a central water building with polyethylene pipes that have both galvanized steel mechanical fixtures and polyethylene mechanical fixtures.

The well house and water building has only polyethylene and galvanized pipes and fixtures.

The clubhouse has only polyethylene fixtures.

Each home has either a polyethylene pipe with mechanical fixtures, or a water riser that contains copper with copper mechanical fixtures.

Buildings in Ohio built prior to 1998 or that use plumbing material or solder manufactured before 1998 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1998. In addition, buildings built and plumbing materials manufactured after 2014 were required to have less than 0.25% lead by weight and have the lowest risk for contributing lead to the drinking water. It should be noted however that, although prohibited, some use of leaded solder or leaded components may have occurred after the prohibitions became effective.

**VERIFICATION FORM FOR COMMUNITY PUBLIC WATER SYSTEMS
CLAIMING NO LEAD SERVICE LINES**

The owner or operator of all community public water systems must identify and map areas of their distribution system that are known or are likely to contain lead service lines. Systems must submit a copy of the applicable map to the Ohio Department of Health and the Ohio Department of Job and Family Services. Systems must also submit a report to the director containing at least both of the following: (1) The applicable map with narrative, and (2) A list of sampling locations used to collect samples as required by Ohio Revised Code (ORC) Section 6109.121 and any rules adopted thereunder, including contact information for the owner and occupant of each sampling site.

Should a water system determine no lead service lines exist in their distribution system, they must provide information stating they reviewed, at the minimum, historical permit records and local ordinances, distribution maintenance records and information pertaining to installation dates or materials for all service lines. This information must be verified below.

I HEREBY CERTIFY THAT THE FOLLOWING METHOD(S) WERE USED TO DETERMINE NO LEAD SERVICE LINES EXIST IN THIS WATER SYSTEM'S DISTRIBUTION SYSTEM, AS REQUIRED BY ORC 6109.121(F):

LEAD SERVICE LINE VERIFICATION	
This PWS states they have no lead service lines and has reviewed the following information (select one or more of the following):	
<input type="checkbox"/> Historical permit records and/or local ordinances <input checked="" type="checkbox"/> Distribution maintenance records (i.e. meter replacement, waterline break repairs) <input type="checkbox"/> Information pertaining to installation dates for all service lines (i.e. after 1986 when lead services lines were banned) <input type="checkbox"/> Service line material of all service lines is known (i.e. all service lines are known to be PVC)	

<i>Jessie Ward</i>	<u>3/8/17</u>
Signature of Responsible Person	Date
<u>Jessie Ward</u>	
Printed Name and Title of Responsible Person	

PWS NAME: GREEN MEADOWS
PWS ID: OH: 4901812
COUNTY: MADISON

<u>For Ohio EPA use only:</u>	
Date Verification Rec'd: <i>KAA</i>	3/9/17