


Document Path: H:\Jobs\2017\005\CADD\GIS\Map\Lead Mapping.mxd



Private Property Information
Buildings built prior to 1998 or that use plumbing material or solder manufactured before 1998 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1998. In addition, building built and plumbing materials manufactured after 2014 were required to have less than 0.25% lead by weight and have the lowest risk of contributing lead to the drinking water. It should be noted however that, although prohibited, some use of lead solder or leaded components may have occurred after the prohibitions became effective.



MATERIAL	Lead (City Owner)	Year Building Built
Ductile Iron	No	Unknown
Galvanized	Lead	1810-1998
Cast	Unknown	1999-Present
PVC	Unknown / Unknown	

1 inch = 200 feet	Job No. 17-005	Page 1 / 1
DWN: APM CKD: BPC Date: 3/7/2017		

Canal Point
PWS# OH2346603
2017 Lead Mapping