






JOHNSON TOWNSHIP - SECTIONS: 12, 18, & 24
JACKSON TOWNSHIP - SECTIONS: 11, 17, & 23
CHAMPAIGN COUNTY, OHIO



LEGEND

-  SERVICE AREA
 BUILDINGS CONSTRUCTED 2014-2017
 BUILDINGS CONSTRUCTED 1998-2013
 BUILDINGS CONSTRUCTED BEFORE 1998

-  HYDRANT
- WATER TOWER
- WELL

WATER MAINS TYPE

- 4" WATER MAIN
 6" WATER MAIN
 8" WATER MAIN

NOTE: ALL PIPE MATERIAL IS DUCTILE IRON
UNLESS OTHERWISE NOTED

[illegible]

PREPARED BY:

ChoiceOne
Engineering

SINCEY, OHIO 612.497.8200
LOVELAND, OHIO 513.229.8554
PORTLAND, INDIANA 219.766.2900

www.CHOICEONEENGINEERING.COM

**VERIFICATION FORM FOR COMMUNITY PUBLIC WATER SYSTEMS
CLAIMING NO LEAD SERVICE LINES**

The owner or operator of all community public water systems must identify and map areas of their distribution system that are known or are likely to contain lead service lines. Systems must submit a copy of the applicable map to the Ohio Department of Health and the Ohio Department of Job and Family Services. Systems must also submit a report to the director containing at least both of the following: (1) The applicable map with narrative, and (2) A list of sampling locations used to collect samples as required by Ohio Revised Code (ORC) Section 6109.121 and any rules adopted thereunder, including contact information for the owner and occupant of each sampling site.

Should a water system determine no lead service lines exist in their distribution system, they must provide information stating they reviewed, at the minimum, historical permit records and local ordinances, distribution maintenance records and information pertaining to installation dates or materials for all services lines. This information must be verified below.

I HEREBY CERTIFY THAT THE FOLLOWING METHOD(S) WERE USED TO DETERMINE NO LEAD SERVICE LINES EXIST IN THIS WATER SYSTEM'S DISTRIBUTION SYSTEM, AS REQUIRED BY
ORC 6109.121(F):

LEAD SERVICE LINE VERIFICATION

This PWS states they have no lead service lines and has reviewed the following information (select one or more of the following):

- ☐ Historical permit records and/or local ordinances
- ☒ Distribution maintenance records (i.e. meter replacement, waterline break repairs)
- ☐ Information pertaining to installation dates for all service lines (i.e. after 1986 when lead services lines were banned)
- ☒ Service line material of all service lines is known (i.e. all service lines are known to be PVC)

Signature of Responsible Person

Date

Printed Name and Title of Responsible Person

PWS NAME: Village of St. Paris
PWS ID: OH 1100912
COUNTY: Champaign

For Ohio EPA use only:

Date Verification Rec'd: _____

Village of St. Paris Public Water System Lead and Copper Map Legend Narrative

- Yellow areas on the map indicate buildings constructed prior to 1998. These buildings may or may not contain fixtures or piping containing lead or lead solder.
- Blue areas on the map indicate buildings constructed after 2014 with a low risk of having fixtures or piping that contains lead or lead solder.
- Orange areas on the map indicate buildings constructed between the years 1998 and 2013 with a low risk of having fixtures or piping that contains lead or lead solder.
- The Village of St. Paris has no information indicating that we have any lead service lines in our system.
- “Because it is practically impossible to determine the lead content of an installed fixture, fitting or pipe, it should be assumed that the manufacture or installation date is the primary indicator of the lead content. Therefore, the characteristics of buildings and piping solder or fixtures would be buildings in Ohio built prior to 1998 or that use plumbing material or solder manufactured before 1998 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1998. In addition, buildings built and plumbing materials manufactured after 2014 were required to have less than 0.25% lead by weight and have the lowest risk for contributing lead to the drinking water. It should be noted however that, although prohibited, some use of leaded solder or leaded components may have occurred after the prohibitions became effective.”