



**Hamersville**

**Hamersville Water - Pb/Cu**

- Pb-Cu SMP
- PARCELS
- Water Mains - Services - All Non Lead



# **Village of Hamersville, OH**

**Public Water Supply ID: OH0800603**

**Lead / Copper: Water Mains - Services - Customer Plumbing Lines & Fixtures**

**Narrative by John C. Van Harlingen: March 2, 2017**

The Village of Hamersville, Ohio installed its initial water distribution system in 1963. The water mains were constructed largely with asbestos cement (transite) pipe. Service lines to the customer's water meters were constructed with copper piping. In the years following, main water lines were constructed with PVC while the customer service lines to the water meters were installed using polyethylene (PEP) piping.

Through personal observation, discussions with past and present utility superintendents, and repair contractors, only copper and PEP service lines have been identified during repairs. It is believed that no lead service lines exist in the Village of Hamersville's water distribution system and with the distribution system not being installed until 1963, this premise is supported with the time frame of lead pipe regulations during that period.

Concerning customer owned water services (beyond the meters), lines and fixtures, the Village of Hamersville only has jurisdiction to and including the water customer's water meter. It is understood that buildings in Ohio built prior to 1998 or that use plumbing material or solder manufactured before 1998 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1998. In addition, buildings built and plumbing materials manufactured after 2014 were required to have less than 0.25% lead by weight and have the lowest risk for contributing lead to the drinking water. It should be noted however that, although prohibited, some use of leaded solder or leaded components may have occurred after the prohibitions became effective.

John C. Van Harlingen, Operator of Record



March 2, 2017

**VERIFICATION FORM FOR COMMUNITY PUBLIC WATER SYSTEMS  
CLAIMING NO LEAD SERVICE LINES**

The owner or operator of all community public water systems must identify and map areas of their distribution system that are known or are likely to contain lead service lines. Systems must submit a copy of the applicable map to the Ohio Department of Health and the Ohio Department of Job and Family Services. Systems must also submit a report to the director containing at least both of the following: (1) The applicable map with narrative, and (2) A list of sampling locations used to collect samples as required by Ohio Revised Code (ORC) Section 6109.121 and any rules adopted thereunder, including contact information for the owner and occupant of each sampling site.

Should a water system determine no lead service lines exist in their distribution system, they must provide information stating they reviewed, at the minimum, historical permit records and local ordinances, distribution maintenance records and information pertaining to installation dates or materials for all services lines. This information must be verified below.

I HEREBY CERTIFY THAT THE FOLLOWING METHOD(S) WERE USED TO DETERMINE NO LEAD SERVICE LINES EXIST IN THIS WATER SYSTEM'S DISTRIBUTION SYSTEM, AS REQUIRED BY ORC 6109.121(F):

<b>LEAD SERVICE LINE VERIFICATION</b>
<p><b>This PWS states they have no lead service lines and has reviewed the following information (select one or more of the following):</b></p> <ul style="list-style-type: none"><li><input type="checkbox"/> Historical permit records and/or local ordinances</li><li><input checked="" type="checkbox"/> Distribution maintenance records (i.e. meter replacement, waterline break repairs)</li><li><input checked="" type="checkbox"/> Information pertaining to installation dates for all service lines (i.e. after 1986 when lead services lines were banned)</li><li><input type="checkbox"/> Service line material of all service lines is known (i.e. all service lines are known to be PVC)</li></ul>

<u>John C. Van Harlingen</u>	<u>3-2-2017</u>
Signature of Responsible Person	Date
<u>John C. Van Harlingen, Operator of Record</u>	
Printed Name and Title of Responsible Person	

**PWS NAME:** Hamersville Water Supply  
**PWS ID:** OH0800603  
**COUNTY:** Brown

<p><b>For Ohio EPA use only:</b></p> <p>Date Verification Rec'd: _____</p>
--