Note: Building was constructed in approximately 1928. There are no records of plumbing updates over the course of time. The main and visible components of the water system appear to be galvanized and copper piping. The age of the fixtures and their material makeup are also unknown. Because it is practically impossible to determine the lead content of an installed fixture, fitting or pipe, it should be assumed that the manufacture or installation date is the primary indicator of the lead content. Therefore, the characteristics of buildings and piping solder or fixtures would be buildings built prior to 1998 or that use plumbing material or solder manufactured before 1998 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1998. In addition, buildings built and plumbing materials manufactured after 2014 were required to have less than 0.25% lead by weight and have the lowest risk for contributing lead to the drinking water. It should be noted however that, although prohibited, some use of leaded solder or leaded components may have occurred after the prohibitions became effective.



PWS: OH1134612 Location: 2468:ST RT 54 Urbana, OH 43078 Owner Contact: Bob Huelsman 937.631.4866 Operator of Record Contact: Aaron Sherman 937.215.5067

Water Service Entrance Point. No information on age. Appears to be galvanized.

Indicates the SMP ID Number for Lead and Copper Testing Site at this location. Also indicates no information on age or materials of fixture.

Note: Building was constructed in approximately 1928. There are no records of plumbing updates over the course of time. The main and visible components of the water system appear to be galvanized and copper piping. The age of the fixtures and their material makeup are also unknown. Because it is practically impossible to determine the lead content of an installed fixture, fitting or pipe, it should be assumed that the manufacture or installation date is the primary indicator of the lead content. Therefore, the characteristics of buildings and piping solder or fixtures would be buildings built prior to 1998 or that use plumbing material or solder manufactured before 1998 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1998. In addition, buildings built and plumbing materials manufactured after 2014 were required to have less than 0.25% lead by weight and have the lowest risk for contributing lead to the drinking water. It should be noted however that, although prohibited, some use of leaded solder or leaded components may have occurred after the prohibitions became effective.



PWS: OH1134612 Location: 2468 ST RT 54 Urbana, OH 43078 Owner Contact: Bob Huelsman 937.631.4866 Operator of Record Contact: Aaron Sherman 937.215.5067

LC##¥

Water Service Entrance Poirt. No information on age. Appears to be galvanized.

Indicates the SMP ID Number for Lead and Copper Testing Site at this location. Also indicates no information on age or materials of fixture.

Note: Building was constructed in approximately 1928. There are no records of plumbing updates over the course of time. The main and visible components of the water system appear to be galvanized and copper piping. The age of the fixtures and their material makeup are also unknown. Because it is practically impossible to determine the lead content of an installed fixture, fitting or pipe, it should be assumed that the manufacture or installation date is the primary indicator of the lead content. Therefore, the characteristics of buildings and piping solder or fixtures would be buildings built prior to 1998 or that use plumbing material or solder manufactured before 1998 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1998. In addition, buildings built and plumbing materials manufactured after 2014 were required to have less than 0.25% lead by weight and have the lowest risk for contributing lead to the drinking water. It should be noted however that, although prohibited, some use of leaded solder or leaded components may have occurred after the prohibitions became effective.



Water Distribution Information for:

PWS: OH1134612 Location: 2468 ST RT 54 Urbana, OH 43078 Owner Contact: Bob Huelsman 937.631.4866 Operator of Record Contact: Aaron Sherman 937.215.5067

Water Service Entrance Point. No information on age. Appears to be galvanized.

LC###