RECEIVED

MAR 0 8 2017

Southwest District

COTTONWOOD ENTERPRISES MOBILE HOME PARK 8312 ST. RT. 366 RUSSELLS POINT, OHIO 43348 419-236-2790

3-5-2017

PWS# OH4634612

LEAD SERVICE LINE; Mapping Statement

Cottonwood Enterprises mobile home park has NO LEAD SERVICE LINES!

This information is based on the following parameters:

- 1. It is known, that the entire water distribution system is galvanized piping including the water mains and service lines to the valve for the trailer shut-off.
- 2. All excavations that have been performed since the park was developed have un-covered only the above mentioned galvanized materials. There is absolutely no evidence that any lead service lines exist.

Contained within the shaded area of green and yellow striping are components that are likely to have lead content.

Buildings in Ohio built prior to 1998 or that use plumbing material or solder manufactured before 1998 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1998. In addition, buildings built and plumbing materials after 2014 were required to have less than 0.25% lead by weight and have the lowest risk for contributing lead to the drinking water. It should be noted however that, although prohibited, some use of leaded solder or leaded components may have occurred after the prohibitions became effective.

Dale Albert Cottonwood Enterprises Water Technical Representative

1/ ale Mar

MAR 0 8 2017

VERIFICATION FORM FOR COMMUNITY PUBLIC WATER SYSTEMS CLAIMING NO LEAD SERVICE LINES

The owner or operator of all community public water systems must identify and map areas of their distribution system that are known or are likely to contain lead service lines. Systems must submit a copy of the applicable map to the Ohio Department of Health and the Ohio Department of Job and Family Services. Systems must also submit a report to the director containing at least both of the following: (1) The applicable map with narrative, and (2) A list of sampling locations used to collect samples as required by Ohio Revised Code (ORC) Section 6109.121 and any rules adopted thereunder, including contact information for the owner and occupant of each sampling site.

Should a water system determine no lead service lines exist in their distribution system, they must provide information stating they reviewed, at the minimum, historical permit records and local ordinances, distribution maintenance records and information pertaining to installation dates or materials for all services lines. This information must be verified below.

I HEREBY CERTIFY THAT THE FOLLOWING METHOD(S) WERE USED TO DETERMINE NO LEAD SERVICE LINES EXIST IN THIS WATER SYSTEM'S DISTRIBUTION SYSTEM, AS REQUIRED BY ORC 6109.121(F):

This PWS states they have no lead servic reviewed the following information (selec following):	e lines and has t one or more of the
 Historical permit records and/or local A Distribution maintenance records (i.e. waterline break repairs) Information pertaining to installation d (i.e. after 1986 when lead services line Service line material of all service line service lines are known to be PVC) 	meter replacement, ates for all service lines es were banned)
Image: Second State 3-6-2017 re of Responsible Person Date Alberg - Maren Tech. Mep. Name and Title of Responsible Person	PWS NAME: <u>Enterph</u> PWS ID: OH 46342 COUNTY: <u>LogAn</u>

Date Verification Rec'd:

Lead Mapping Verification Form Revised 2/14/17

