

RE: JEROMESVILLE VILLAGE
Report
Drinking Water Program
Ashland County
PWS ID: OH0300912

RECEIVED

MAR 08 2017

DDAGW - NWDO

LEGEND
LEAD
NON-LEAD
UNKNOWN



0 250 500 1000
SCALE OF FEET

Hillsdale Middle School

JEROMESVILLE VILLAGE

SCALE : SEE BAR SCALE

NOTES:

1. ALL MAIN LINES ARE MADE OF PLASTIC, TRANSITE, CAST IRON, & DUCTILE IRON. ALL SERVICE LINES ARE MADE OF COPPER, PLASTIC, AND GALVANIZED.
2. DUE TO THE AGE OF THE HOMES, ALL OR MOST HOMES LIKELY CONTAIN LEAD SOLDER ON INTERNAL PLUMBING.
3. IF LEAD SERVICE LINES ARE PRESENT IN THIS SYSTEM, THEY ARE CONTAINED WITHIN THE "UNKNOWN" AREA OF THE MAP.
4. JEROMESVILLE ALSO SERVES HILLSDALE MIDDLE SCHOOL.
5. BUILDINGS IN OHIO BUILT PRIOR TO 1998 OR THAT USE PLUMBING MATERIAL OR SOLDER MANUFACTURED BEFORE 1998 MAY HAVE MATERIALS WITH GREATER THAN 8% LEAD AND ARE AT A HIGHER RISK OF CONTRIBUTING LEAD TO THE DRINKING WATER THAN MATERIALS MANUFACTURED AFTER 1998. IN ADDITION, BUILDINGS BUILT AND PLUMBING MATERIALS MANUFACTURED AFTER 2014 WERE REQUIRED TO HAVE LESS THAN 0.25% LEAD BY WEIGHT AND HAVE THE LOWEST RISK FOR CONTRIBUTING LEAD TO THE DRINKING WATER. IT SHOULD BE NOTED HOWEVER THAT, ALTHOUGH PROHIBITED, SOME USE OF LEADED SOLDER OR LEADED COMPONENTS MAY HAVE OCCURRED AFTER THE PROHIBITIONS BECAME EFFECTIVE.

VILLAGE OF JEROMESVILLE
PO BOX 83
JEROMESVILLE, OHIO 44840
PHONE # (419) 388-3644
PWS ID # OH0300912