

RECEIVED
OHIO EPA
MAR 06 2017
Southwest District

VERIFICATION FORM FOR COMMUNITY PUBLIC WATER SYSTEMS CLAIMING NO LEAD SERVICE LINES

The owner or operator of all community public water systems must identify and map areas of their distribution system that are known or are likely to contain lead service lines. Systems must submit a copy of the applicable map to the Ohio Department of Health and the Ohio Department of Job and Family Services. Systems must also submit a report to the director containing at least both of the following: (1) The applicable map with narrative, and (2) A list of sampling locations used to collect samples as required by Ohio Revised Code (ORC) Section 6109.121 and any rules adopted thereunder, including contact information for the owner and occupant of each sampling site.

Should a water system determine no lead service lines exist in their distribution system, they must provide information stating they reviewed, at the minimum, historical permit records and local ordinances, distribution maintenance records and information pertaining to installation dates or materials for all services lines. This information must be verified below.

I HEREBY CERTIFY THAT THE FOLLOWING METHOD(S) WERE USED TO DETERMINE NO LEAD SERVICE LINES EXIST IN THIS WATER SYSTEM'S DISTRIBUTION SYSTEM, AS REQUIRED BY ORC 6109.121(F):

LEAD SERVICE LINE VERIFICATION	
This PWS states they have no lead service lines and has reviewed the following information (select one or more of the following):	
<input type="checkbox"/>	Historical permit records and/or local ordinances
<input type="checkbox"/>	Distribution maintenance records (i.e. meter replacement, waterline break repairs)
<input type="checkbox"/>	Information pertaining to installation dates for all service lines (i.e. after 1986 when lead services lines were banned)
<input checked="" type="checkbox"/>	Service line material of all service lines is known (i.e. all service lines are known to be PVC)

Cindy McMahon 3-3-17
Signature of Responsible Person Date
Cindy McMahon
Printed Name and Title of Responsible Person

PWS NAME: Brookwood Mobile Home Park
PWS ID: OH 1200212
COUNTY: Clark

For Ohio EPA use only: Date Verification Rec'd: _____

Test Sites

RECEIVED
OHQ/EPK

FEB 21 2017

SOUTHWEST District

CAROLYN Drive

3400	CHRISTINA DRIVE	3399	3400	MICHELLE DRIVE	3399	3400	MICHAEL DRIVE	3399
3402		3401	3402		3401	3402		3401
3404		3403	3404		3403	3404		3403
3406		3405	3406		3405	3406		3405
3408		3407	3408		3407	3408		3407
3410		3409	3410		3409	3410		3409
3412		3411	3412		3411	3412		3411
3414		3413	3414		3413	3414		3413
3416		3415	3416		3415	3416		3415
3418		3417	3418		3417	3418		3417
3420		3419	3420		3419	3420		3419
3422		3421	3422		3421	3422		3421
3424		3423	3424		3423	3424		3423
3426		3425	3426		3425	3426		3425
3428		3427	3428		3427	3428		3427
3430		3429	3430		3429	3430		3429
3432			3432		3431	3432		3431
3434			3434		3433	3434		3433
3436			3436		OFFICE	3436		3435
3438			3438		3435	3438		3437

Leaded Base
+
Tennis Area

2" Plastic main lines

Brookwood
Mobile Home
Park

3435 Michelle Dr
New Carlisle Ohio
45344

WELL

2" Plastic Lines main

2" Plastic main Lines



McMahan's
BROOKWOOD MOBILE HOME PARK
3435 Michelle Drive • New Carlisle, OH 45344
(937) 845-1414

RECEIVED
OHIO EPA
FEB 21 2017
Southwest District

All our water lines are plastic. There are some brass components on some shut off valves that could have varying lead amounts. Office has a few copper lines. All Mobile Homes most always have plastic lines.

To my knowledge we have no lead pipes at Brookwood Mobile Home Park.

Because it is practically impossible to determine the lead content of an installed fixture, fitting or pipe, it should be assumed that the manufacture or installation date is the primary indicator of the lead content. Therefore, the characteristics of buildings and piping solder or fixtures would be buildings in Ohio built prior to 1998 or that use plumbing material or solder manufactured before 1998 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1998. In addition, buildings built and plumbing materials

(next page)



McMahan's
BROOKWOOD MOBILE HOME PARK
3435 Michelle Drive • New Carlisle, OH 45344
(937) 845-1414

Page 2

manufactured after 2014 were required to have less than 0.25% lead by weight and have the lowest risk for contributing lead to the drinking water. It should be noted however that, although prohibited, some use of leaded solder or leaded components may have occurred after the prohibitions.

Respectfully

Lindy McMahan

Park Manager