



Greenlawn Village Condominium

Jackson Heights

41

Miller Rd

3301 Miller Rd

David Aaron Dr

© 2016 Google

GOO

RECEIVED
CHICAGO
MAY 06 2017
District

THREE R ROLLING TERRACE MHP LLC.

(ROLLING TERRACE MHP)

3301 MILLER RD.

SPRINGFIELD, OHIO 45502

PWS 1253242

LEAD MAPPING PROJECT 2017

NARRATIVE

RECEIVED
OHIO EPA
MAR 06 2017
Southwest District

The Park was built in 1970.

The Park has a master meter, but individual homes are not metered.

All main line and service lines throughout the Park are galvanized pipes.

All service lines are galvanized lines-see below recent repairs.

3/2010 Lot 7—repaired leak in service line before shut off—galvanized

11/2014—Lot 22 repaired leak in service line before shut off—replaced with PEX

Lines in well house are galvanized and PVC have been repaired over the years with galvanized and PVC pipe.
(Building A on map)

Well # 1 line from pump was replaced with black plastic well pipe March 2010.

Well #2 line from pump is galvanized pipe.

Lines in the old laundry room are copper with solder (age unknown, but prior to 2006). This building is not open to the public and is only used as storage and workroom for staff. (Building B on map). Should be called Workshop/storage area.

All mobile homes are owner occupied.

A form was sent out to all residents asking them to check the type of lines in their homes and return. Of the 36 forms sent out 22 were returned.

Because it is practically impossible to determine the lead content of an installed fixture, fitting or pipe, it should be assumed that the manufacture or installation date is the primary indicator of the lead content. Therefore, the characteristics of buildings and piping solder or fixtures would be buildings in Ohio built prior to 1998 or that use plumbing material or solder manufactured before 1998 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1998. In addition, buildings built and plumbing materials manufactured after 2014 were required to have less than 0.25% lead by weight and have the lowest risk for contributing lead to the drinking water. It should be noted however that although prohibited, some use of leaded solder or leaded components may have occurred after the prohibitions became effective.

RECEIVED
OHIO EPA
MAR 06 2017
S. J. ... District

THREE R ROLLING TERRACE MOBILE HOME PARK

3301 MILLER ROAD

SPRINGFIELD, OHIO 45502

EPA LEAD MAPPING PROJECT JANUARY 2017

<u>LOT #</u>	<u>YEAR</u>	<u>TYPE OF LINE MATERIAL</u>
LOT 1	1972	COPPER WITH FLARED OR FITTED CONNECTIONS
LOT 2	1997	GALVANIZED, PVC
LOT 3	1976	NOT RETURNED
LOT 4	1980	NOT RETURNED
LOT 5	1993	NOT RETURNED
LOT 6	1990	UNKNOWN
LOT 7	2000	PVC
LOT 8	1967	NOT RETURNED
LOT 9	1972	GALVANIZED, PVC
LOT 10	2001	PVC
LOT 11	1991	GALVANIZED, PVC, PEX
LOT 12	1999	PVC
LOT 13	1996	PEX
LOT 14	1999	NOT RETURNED
LOT 15	1985	NOT RETURNED
LOT 16	1972	NOT RETURNED
LOT 17	1975	NOT RETURNED
LOT 18	1979	GALVANIZED, PVC, COPPER WITH FLARED OR FITTED CONNECTIONS
LOT 19	1975	GALVANIZED, PEX, COPPER WITH FLARED OR FITTED CONNECTIONS
LOT 20	1972	NOT RETURNED
LOT 21	1995	UNKNOWN
LOT 22	1974	GALVANIZED, COPPER WITH FLARED OR FITTED CONNECTIONS
LOT 28	1974	GALVANIZED, COPPER WITH FLARED OR FITTED CONNECTIONS
LOT 29	1975	NOT RETURNED
LOT 30	1994	NOT RETURNED

RECEIVED
OHIO EPA
MAR 06 2017
Southwest District

LOT 31	2001	PEX
LOT 32	1993	PEX
LOT 33	2000	PVC
LOT 34	1989	PEX
LOT 35	1995	GALVANIZED, PEX
LOT 36	1985	NOT RETURNED
LOT 37	1994	PEX, COPPER WITH FLARED OR FITTED CONNCTIONS
LOT 38	1996	PVC
LOT 39	1993	NOT RETURNED
LOT 40	1979	PEX, COPPER WITH FLARED OR FITTED CONNECTIONS
LOT 41	1973	NOT RETURNED
BUILDING A		GALVANIZED, PVC
BUILDING B		PVC, COPPER WITH LEAD SOLDERED CONNECTIONS

**VERIFICATION FORM FOR COMMUNITY PUBLIC WATER SYSTEMS
CLAIMING NO LEAD SERVICE LINES**

The owner or operator of all community public water systems must identify and map areas of their distribution system that are known or are likely to contain lead service lines. Systems must submit a copy of the applicable map to the Ohio Department of Health and the Ohio Department of Job and Family Services. Systems must also submit a report to the director containing at least both of the following: (1) The applicable map with narrative, and (2) A list of sampling locations used to collect samples as required by Ohio Revised Code (ORC) Section 6109.121 and any rules adopted thereunder, including contact information for the owner and occupant of each sampling site.

Should a water system determine no lead service lines exist in their distribution system, they must provide information stating they reviewed, at the minimum, historical permit records and local ordinances, distribution maintenance records and information pertaining to installation dates or materials for all services lines. This information must be verified below.

I HEREBY CERTIFY THAT THE FOLLOWING METHOD(S) WERE USED TO DETERMINE NO LEAD SERVICE LINES EXIST IN THIS WATER SYSTEM'S DISTRIBUTION SYSTEM, AS REQUIRED BY ORC 6109.121(F):

LEAD SERVICE LINE VERIFICATION
<p>This PWS states they have no lead service lines and has reviewed the following information (select one or more of the following):</p> <ul style="list-style-type: none"><input type="checkbox"/> Historical permit records and/or local ordinances<input type="checkbox"/> Distribution maintenance records (i.e. meter replacement, waterline break repairs)<input type="checkbox"/> Information pertaining to installation dates for all service lines (i.e. after 1986 when lead services lines were banned)<input checked="" type="checkbox"/> Service line material of all service lines is known (i.e. all service lines are known to be PVC)

<u><i>Robert A. Beck</i></u> Signature of Responsible Person	<u>3-2-17</u> Date
<u>Robert A Beck owner</u> Printed Name and Title of Responsible Person	

Three A
PWS NAME: Dollins Terrace MHP
PWS ID: OH 1253242
COUNTY: Clark

For Ohio EPA use only:

Date Verification Rec'd: _____

RECEIVED
OHIO EPA

MAR 06 2017

Southwest District