

Central state University was established in 1887. The Central State drinking water distribution mains consist of ductile iron and interior plumbing is copper. The copper setters that were made prior to June 1986 may contain lead solder, all copper setters made after June 1986 may not. No lead service lines have been encountered over numerous years of distribution maintenance. Because it is practically impossible to determine the lead content of an installed fixture, fittings or pipes, it should be assumed that the manufacturer or installation date is the primary indicator of the lead content. Therefore, the characteristics of the buildings and piping solder or fixtures would be in buildings built in Ohio prior to 1998 or that use plumbing material or solder manufactured before 1998 may have materials with greater than 8% lead and are at higher risk of contributing lead to the drinking water than materials manufactured after 1998. In addition, buildings built and plumbing materials manufactured after 2014 were required to have less than 0.25% lead by weight and have the lowest risk of contributing lead to the drinking water. It should be noted however that, although prohibited, some use of lead and solder or leaded components may have occurred after the prohibitions became effective.



1	Lionel H. Newsom Administration Building	13	Natatorium	25	Elizabeth M. Anderson Hall
Year	1978	Year	1975	Year	1970
Test	2015 PB 3.46 ug / L CU .883 MG / L			TEST	2015 PB BDL CU .381 mg / L
2	Louis Stokes Center on Aging	14	James J. Walker Gymnasium	26	Foundation Hall I
Year	2001	Year	1975	Year	2002
3	Harry M. Lackey/Benjamin F. Lee Health Center	15	Camille O. & William H. Cosby Mass Communications Center	27	Foundation Hall II
Year	1978	Year	1958	Year	2004
		TEST	2015 PB 4.46 ug / L CU 2.11 mg / L		
4	Charles H. Wesley Arts & Science Building	16	Field Storage	28	Paul Robeson Cultural & Performing Arts Center
YEAR	1967	YEAR	1980	YEAR	1978

Test	2015 PB BDL CU .882 mg / L			TEST	2015 PB 7.34 ug / L CU .361 mg / L
5	Walter G. Sellers Alumni Tower/William Galloway Hall	17	William Patrick McPherson Memorial Stadium	29	National Afro-American Museum and Cultural Center
Year	1906/1980	Year	1949	Year	1988
TEST	2015 PB 29.1 ug / L CU .714 mg / L				
6	Norman E. Ward Sr. University Center	18	Steam Plant	30	Administration Annex/Pre-Law
Year	1964	Year	1927	Year	2003
TEST	2015 PB BDL CU .461 mg / L				
7	Inez Edwards Mercer Cafeteria	19	Facilities/Maintenance	31	Harry G. Johns Living Learning Center
Year	1963	Year	1974	Year	2010
		TEST	2015 PB BDL CU 1.16 mg / L		
8	Anne O'Hare Williamson Hall	20	Charles S. Smith Hall College of Business	32	John R. Fox Hall
Year	1964	Year	1970	Year	2010
9	Jane Hunter Hall	21	CJ. Mclin International Center for Water Resource Management	33	E. J. Emery Hall

Year	1958	Year	1994	Year	1913
10	Clara Henderson Hall	22	Carl C. Jenkins Technology Education Hall	34	Wilberforce Carnegie Library
Year	1985	Year	1971	Year	1904
		TEST	2015 PB 11.9 ug / L CU 1.24 mg / L		
11	Hallie Q. Brown Memorial Library	23	Joseph D. Lewis/George T. Simpson/Grill 1S5	35	((ENS) Center for Education and Natural Sciences
Year	1985	Year	1974	Year	2006
		TEST	2015 PB 3.23 ug / L CU .786 mg / L		
12	Madison w. Beacom / Gaston F. Lewis Gymnasium	24	Susie S. Green Hall	36	Student Center
Year	1961/1975	Year	1970	Year	2015

**VERIFICATION FORM FOR COMMUNITY PUBLIC WATER SYSTEMS
CLAIMING NO LEAD SERVICE LINES**

The owner or operator of all community public water systems must identify and map areas of their distribution system that are known or are likely to contain lead service lines. Systems must submit a copy of the applicable map to the Ohio Department of Health and the Ohio Department of Job and Family Services. Systems must also submit a report to the director containing at least both of the following: (1) The applicable map with narrative, and (2) A list of sampling locations used to collect samples as required by Ohio Revised Code (ORC) Section 6109.121 and any rules adopted thereunder, including contact information for the owner and occupant of each sampling site.

Should a water system determine no lead service lines exist in their distribution system, they must provide information stating they reviewed, at the minimum, historical permit records and local ordinances, distribution maintenance records and information pertaining to installation dates or materials for all services lines. This information must be verified below.

I HEREBY CERTIFY THAT THE FOLLOWING METHOD(S) WERE USED TO DETERMINE NO LEAD SERVICE LINES EXIST IN THIS WATER SYSTEM'S DISTRIBUTION SYSTEM, AS REQUIRED BY ORC 6109.121(F):

LEAD SERVICE LINE VERIFICATION
<p>This PWS states they have no lead service lines and has reviewed the following information (select one or more of the following):</p> <ul style="list-style-type: none"> <input type="checkbox"/> Historical permit records and/or local ordinances <input checked="" type="checkbox"/> Distribution maintenance records (i.e. meter replacement, waterline break repairs) <input type="checkbox"/> Information pertaining to installation dates for all service lines (i.e. after 1986 when lead services lines were banned) <input type="checkbox"/> Service line material of all service lines is known (i.e. all service lines are known to be PVC)

<p><u> <i>MICT Thompson</i> </u> Signature of Responsible Person</p>	<p><u> 3/6/17 </u> Date</p>
<p><u> MICT Thompson </u> Printed Name and Title of Responsible Person</p>	

PWS NAME: Central state
PWS ID: OH 2901912
COUNTY: Greene

<p>For Ohio EPA use only:</p> <p>Date Verification Rec'd: _____</p>
--