

"There are no known lead service lines on Wright-Patterson AFB. However, buildings constructed prior to 1998 are likely to contain plumbing material or solder that may have materials with greater than 8% lead and thus are at a higher risk of contributing lead to the drinking water than materials manufactured after 1998. Conversely, buildings constructed after 2014 were required to have less than 0.25% lead by weight and thus have the lowest risk for contributing lead to the drinking water.
Where water lines are uncovered during maintenance operations, and leaking joints are discovered that contain lead soldering, the lead is removed during the course of the repair"

Wright-Patterson AFB Area A PWS
PWS ID: OH2903412

LEGEND

- Buildings Built Prior to 1998
- Buildings Built Between 1998-2014
- Buildings Built After 2014
- Installation Boundary

COORDINATOR			DESIGN CHIEF			ENGINEERING CHIEF		
DATE	NO.	REVISION	BY	DATE	NO.	REVISION	BY	

WPAFB

WRIGHT-PATTERSON AIR FORCE BASE

US AF 88TH ABW CIVIL ENGINEER

EPA Building Map
AREA A

1 OF 2

DESIGNED	JDC	DRAWN	JDC	CHECKED	MRL	DATE	30 JAN 2017