

VERIFICATION FORM FOR COMMUNITY PUBLIC WATER SYSTEMS CLAIMING NO LEAD SERVICE LINES

The owner or operator of all community public water systems must identify and map areas of their distribution system that are known or are likely to contain lead service lines. Systems must submit a copy of the applicable map to the Ohio Department of Health and the Ohio Department of Job and Family Services. Systems must also submit a report to the director containing at least both of the following: (1) The applicable map with narrative, and (2) A list of sampling locations used to collect samples as required by Ohio Revised Code (ORC) Section 6109.121 and any rules adopted thereunder, including contact information for the owner and occupant of each sampling site.

Should a water system determine no lead service lines exist in their distribution system, they must provide information stating they reviewed, at the minimum, historical permit records and local ordinances, distribution maintenance records and information pertaining to installation dates or materials for all services lines. This information must be verified below.

I HEREBY CERTIFY THAT THE FOLLOWING METHOD(S) WERE USED TO DETERMINE NO LEAD SERVICE LINES EXIST IN THIS WATER SYSTEM'S DISTRIBUTION SYSTEM, AS REQUIRED BY ORC 6109.121(F):

LEAD SERVICE LINE VERIFICATION
<p>This PWS states they have no lead service lines and has reviewed the following information (select one or more of the following):</p> <ul style="list-style-type: none"><input type="checkbox"/> Historical permit records and/or local ordinances<input checked="" type="checkbox"/> Distribution maintenance records (i.e. meter replacement, waterline break repairs)<input type="checkbox"/> Information pertaining to installation dates for all service lines (i.e. after 1986 when lead services lines were banned)<input type="checkbox"/> Service line material of all service lines is known (i.e. all service lines are known to be PVC)

Candice A. VanSkoyck 2/28/17
Signature of Responsible Person Date

Candice A. VanSkoyck, Refurbishment Mgr.
Printed Name and Title of Responsible Person

Otterbein Lebanon
PWS NAME: Distribution System
PWS ID: OH 8301112
COUNTY: Warren

For Ohio EPA use only:

Date Verification Rec'd: _____



ROADS & COURTS

- BROWN** = Ranch Homes
Morningside, Daybreak, Willow
- AQUA** = East Court Homes
Redbud, Maple, Dogwood, Cedar, Buckeye, Apple
- PLUM** = West Court Homes
Dove, Bluebird, Cardinal, Thrush, Wren, Swallow
- DARK GREEN** = Patio Homes
Hummingbird, Goldfinch, Killdeer, Meadowlark, Nightingale, Robin, Oriole

BUILDINGS

- DARK BLUE** = Independent Living Homes
- LIGHT BLUE** = Independent Living Apartments
- RED** = Nursing Areas
- ORANGE** = Assisted Living & Nursing
- PURPLE** = Community Activity Areas

GARDENS

In keeping with our United Methodist tradition, we seek to enhance the *quality of life* and holistic growth of older persons.



Lead Content Information and Map Development

Narrative: PWS OH8301112 Otterbein Lebanon Distribution System

The structures served by this PWS are grouped into three (3) distinct categories based on the date of construction listed in the history of Otterbein Lebanon Records.

Because it is practically impossible to determine the lead content of an installed fixture, fitting or pipe, it is assumed that the date of installation (first listed date of home construction) and age of water main servicing those buildings will be used as the two (2) primary indicators of potential lead content. Buildings constructed in OHIO prior to 1988 could contain lead pipe and/or lead based solder, buildings constructed prior to 1988, or utilized plumbing materials or solder manufactured before 1988 may contain materials with greater than 8% lead content and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1998. In addition, buildings constructed after 2014 which incorporated plumbing materials manufactured after 2014, which were required to contain less than 0.25% lead by weight, will have the lowest risk for contributing lead to the drinking water. It should be noted that, although prohibited by law, some use of leaded solder or lead bearing components may have occurred after the prohibition became effective.

Based on this criteria, we have identified (by map color code) the following divisions of potential for private side lead component content:

-  Single Family and Multi Family Homes Constructed Before 1983
-  Single Family and Multi Family Homes Constructed After 1983
-  Single Family and Multi Family Homes Constructed After 2014

The public side service lines in this PWS should all be K Type copper tubing with brass cor stops, angle valves, water meters and other appurtenances.

END