



Shelby County Sewer District

3475 Canal Road #1
Minster, Ohio 45865
(419) 628-3411

Shelby County Water and Sewer District
PWS ID# OH7500112
Lead and Copper Narrative
3/3/2017

To Whom It May Concern,

This narrative includes information pertaining to the Lead and Copper Mapping Requirements of 2017. After reviewing the water lines, it has been determined that the main lines are Plastic. Service Lines from the main to the residential valve box are Plastic. Service lines from the valve box in to the homes are an assortment of plastic and copper. The subdivision was developed prior to 1988 so there is a possibility of lead solder more than 0.2% in the homes. These homes may also contain materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water. Records and visual inspections verify that the mains and service lines owned by the Sewer District are in fact plastic. Please contact me should you have any questions regarding this matter.

Sincerely,

A handwritten signature in black ink, appearing to read 'Tyler Shuster'.

Tyler Shuster
Shelby County Sewer District, Director
3475 Canal Road No. 1
Minster, OH 45865
Cell: 937-538-0132
Office: 419-628-3411
Email: tshuster@shelbycountyengineer.com






1 inch = 200 feet

SHELBY COUNTY OHIO

Arrowhead Subdivision - Water Distribution System



-  Plastic/Non-Lead Main Lines
-  Area May Contain Lead Solder in Service Lines
-  Wastewater Facility
- * Public Service Lines are Plastic
- * Private Service Lines are Unknown

