

RE: Perrysburg Estates MHP  
Report  
Lead Mapping  
Drinking Water Program  
Wood County  
PWS ID: OH8701912



**LEGEND**

DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL
WELL	(W)	WATER MAIN	—
MAIN WATER SHUTOFF	(H)	5" P.V.C.	—
	(N)		

0' 31' 62' 124' NORTH

**NARRATIVE**

- 1) MOBILE HOME COMMUNITY WITH AN OFFICE AND POOL.
- 2) WATER DISTRIBUTION SYSTEM CONSISTS OF P.V.C. PIPING, AND GALVANIZED SERVICE CONNECTIONS.
- 3) MODIFICATIONS UNKNOWN.
- 4) C.M.S. ASSUMES NO RESPONSIBILITY TO DRAWING ACCURACY; INFO DERIVED FROM HISTORICAL DATA.

NOTE: Buildings in Ohio built prior to 1948 or that use plumbing material or solder manufactured before 1948 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1948. In addition, buildings built and plumbing materials manufactured after 2014 were required to have less than 0.25% lead by weight and have the lowest risk for contributing lead to the drinking water. It should be noted however that, although prohibited, some use of leaded solder or leaded components may have occurred after the prohibitions became effective.

hi  
EPA 5105  
DRINKING WATER LEAD AND COPPER MONITORING REPORT

Sample Date: April 03, 2017  
 System Name: Perrysburg Estates MHP  
 Location: Perrysburg, OH  
 Lead Action Level: 0.015 mg/L  
 Copper Action Level: 1.3 mg/L

Site ID	Site Name	Location	Address of Sample Point	Year That the Sample Point was Installed	Sample Date	Sample Time	Sample Type	Lead (mg/L)	Copper (mg/L)	Lead Action Level (mg/L)	Copper Action Level (mg/L)
001A	1101	110101	1101	2014	4/3/17	10:00	First Draw	0.015	0.8	0.015	1.3
001B	1101	110101	1101	2014	4/3/17	10:00	Flush	0.015	0.8	0.015	1.3
001C	1101	110101	1101	2014	4/3/17	10:00	Tap	0.015	0.8	0.015	1.3
001D	1101	110101	1101	2014	4/3/17	10:00	Tap	0.015	0.8	0.015	1.3

**Perrysburg Estates Mobile Home Park**  
 23720 Lime City Road, Perrysburg, OH 43551  
 Tel: (419) 308-6653

**RECEIVED**

E.P.A. Lead Pipe Infrastructure Mapping

APR 07 2017

DDAGW - NWDO

April 6, 2017

