

BEFORE THE
OHIO ENVIRONMENTAL PROTECTION AGENCY

OHIO E.P.A.

JAN 31 2013

ENTERED DIRECTOR'S JOURNAL

In the matter of:

Scott Hess : Director's Final Findings
3920 C.R. 11 : and Orders
Lawrence Township :
Wauseon, OH 43567 :
Respondent :

PREAMBLE

It is agreed by the parties hereto as follows:

I. JURISDICTION

These Director's Final Findings and Orders ("Orders") are issued to Scott Hess ("Respondent") pursuant to the authority vested in the Director of the Ohio Environmental Protection Agency ("Ohio EPA") under Ohio Revised Code ("ORC") §§ 6111.03, and 3745.01.

II. PARTIES BOUND

These Orders shall apply to and be binding upon Respondent and his successors in interest liable under Ohio law.

III. DEFINITIONS

Unless otherwise stated, all terms used in these Orders shall have the same meaning as defined in ORC Chapter 6111 and the rules promulgated there under.

IV. FINDINGS

The Director of Ohio EPA has determined the following findings:

1. Scott Hess (Respondent) owns Country Court Mobile Home Park (MHP) which is located at 7030 County Road 5-2, Delta, Ohio.
2. On April 1, 2010, Ohio EPA renewed the National Pollutant Discharge Elimination System (NPDES) permit, number 2PY00060*CD for the discharges

from Country Court MHP wastewater treatment plant (WWTP) to Swan Creek. Swan Creek constitutes "waters of the state" as defined by ORC Section 6111.01.

3. Pursuant to ORC Section 6111.04(C), no person to whom a permit has been issued shall place or discharge, or cause to be placed or discharged, in any waters of the state any sewage, sludge, sludge materials, industrial waste, or other wastes in excess of the permissive discharges specified under an existing permit.
4. Pursuant to ORC Section 6111.07(A), no person shall violate or fail to perform any duty imposed by ORC Sections 6111.01 to 6111.08 or violate any order, rule, or term or condition of a permit issued or adopted by the Director of Ohio EPA pursuant to those sections. Each day of violation is a separate offense.
5. Respondent violated effluent limitations of its NPDES permit on numerous occasions as cited in Attachment I. Each violation cited in Attachment I constitutes a separate violation of ORC Sections 6111.04(C) and 6111.07(A). Attachment I is hereby incorporated into these Findings & Orders as if fully stated herein.
6. Ohio EPA has sent Respondent Notices of Violations (NOVs) on 8/18/2010, 11/3/2010, 5/12/2011, and 11/15/2011 in an effort to address Respondent's significant non-compliance.
7. Respondent's sewer collection system is believed to have problems with excessive infiltration and inflow ("I/I") in the collection system which could contribute collection system surcharging and overflows, bypassing of the treatment plant units, and poor treatment plant performance.
8. This document does not modify NPDES Permit No. 2PY00060*CD. The purpose of this document is to correct a condition of noncompliance with NPDES Permit No. 2PY00060*CD and not to alter said permit.
9. Compliance with the ORC Chapter 6111 is not contingent upon the availability or receipt of financial assistance.
10. The Director has given consideration to, and based his determination on, evidence relating to the technical feasibility and economic reasonableness of complying with these Orders and to evidence relating to conditions calculated to result from compliance with these Orders, and its relation to the benefits to the people of the State to be derived from such compliance in accomplishing the purposes of ORC Chapter 6111.

V. ORDERS

The Director hereby issues the following Orders:

1. Respondent shall, upon the effective date of these Orders, meet the final effluent limitations in NPDES permit No 2PY00060*CD. If, for two years after the effective date of these Orders, Respondent has (1) effluent violations that are equal or are greater than a 40% exceedance for total suspended solids, nitrogen, ammonia (NH₃) (summer) or CBOD 5 day for any two or more months of two consecutive quarters; (2) a 20% exceedance of total residual chlorine for any two or more months of two consecutive quarters; or (3) a violation of any monthly effluent limit set forth in the permit by any amount for any four or more months in two consecutive quarters, Respondent shall, within 60 days of triggering these criteria, submit a compliance plan to Ohio EPA in accordance with Order 2 that includes a compliance schedule for returning the wastewater treatment plant to compliance. The current permitted effluent limits and the calculated exceedance thresholds are set for in Tables 1 and 2 below:

Table 1

Parameter	Monthly Av. (concentration)	Monthly Av. (load)	40% (max day)	40% (Monthly Average)	40% (Max Load)	40% (Average Load)
total suspended solids	12 mg/l	0.228 kg/d	25.2 mg/l	16.8 mg/l	0.477 kg/d	0.319 kg/d
nitrogen, ammonia (NH ₃) (summer)	5.0 mg/l	0.09 kg/d	10.5 mg/l	7.0 mg/l	0.20 kg/d	0.13 kg/d
CBOD 5 Day	10.0 mg/l	0.19 kg/d	21.0 mg/l	14.0 mg/l	0.39 kg/d	0.27 kg/d

Table 2

Parameter	Max Daily	20% (Max Daily)
total residual chlorine	0.019 mg/l	.027 mg/l

2. Upon Ohio EPA's approval of the compliance plan, Respondent shall implement the compliance plan in accordance with the approved schedule. The compliance plan shall include the following:

- a. Identify the reasons/sources for non-compliance; this should include an evaluation of Inflow & Infiltration in the system. Provide a detailed explanation of how these reasons/sources were identified;
 - b. Alternatives for returning the WWTP to compliance with the NPDES permit;
 - c. Cost estimates for the required improvements and cost effectiveness analysis of the alternatives based on total present worth. The cost effectiveness analysis must include the total construction costs of each alternative as well as operation, maintenance, and replacement costs;
 - d. The financial mechanisms to be used to fund the required improvements, as well as the operation, maintenance, and replacement costs; and
 - e. An implementation schedule for submitting a complete and approvable permit to install application and approvable detail plans, awarding construction bids, starting and completing construction, and attaining compliance with ORC Chapter 6111 and the administrative rules promulgated thereunder.
3. Respondent shall maintain in good working order and operate as efficiently as possible the WWTP to achieve compliance with the terms and conditions of the NPDES permit.
 4. Respondent shall comply with the effluent limitations and monitoring and reporting requirements of NPDES permit 2PY00060*CD, including the obligation to report any bypass that occurs.
 5. Respondent shall pay the amount of ten thousand, eight hundred and four (\$10,804.00) in settlement of Ohio EPA's claims for civil penalties, which may be assessed pursuant to ORC Chapter 6111. Respondent shall pay the civil penalty in accordance with the following schedule:
 - a. By April 1, 2013 make payment to Ohio EPA by an official check made payable to "Treasurer, State of Ohio" for \$1350.50;
 - b. By July 1, 2013 make payment to Ohio EPA by an official check made payable to "Treasurer, State of Ohio" for \$1350.50;
 - c. By October 1, 2013, make payment to Ohio EPA by an official check made payable to "Treasurer, State of Ohio" for \$1350.50;

- d. By January 1, 2014, make payment to Ohio EPA by an official check made payable to "Treasurer, State of Ohio" for \$1350.50;
- e. By April 1, 2014 make payment to Ohio EPA by an official check made payable to "Treasurer, State of Ohio" for \$1350.50;
- f. By July 1, 2014 make payment to Ohio EPA by an official check made payable to "Treasurer, State of Ohio" for \$1350.50;
- g. By October 1, 2014, make payment to Ohio EPA by an official check made payable to "Treasurer, State of Ohio" for \$1350.50;
- h. By January 1, 2015, make payment to Ohio EPA by an official check made payable to "Treasurer, State of Ohio" for \$1350.50;

The official checks shall be submitted to Carol Butler, or her successor, together with a letter identify the Respondent, to:

Office of Fiscal Administration
Ohio Environmental Protection Agency
P.O. Box 1049
Columbus, Ohio 43216-1049

A copy of the check shall be sent to Mark Mann, Environmental Manager, Storm Water and Enforcement Section, or his successor, at the following address:

Ohio EPA
Division of Surface Water
P.O. Box 1049
Columbus, Ohio 43216-1049

VI. TERMINATION

Respondent's obligations under these Orders shall terminate when Respondent certifies in writing and demonstrates to the satisfaction of Ohio EPA that Respondent has performed all obligations under these Orders and the Chief of Ohio EPA's Division of Surface Water acknowledges, in writing, the termination of these Orders. If Ohio EPA does not agree that all obligations have been performed, then Ohio EPA will notify Respondent of the obligations that have not been performed, in which case Respondent shall have an opportunity to address any such deficiencies and seek termination as described above.

The certification shall contain the following attestation: "I certify that the information contained in or accompanying this certification is true, accurate and complete."

This certification shall be submitted by Respondent to Ohio EPA and shall be signed by a responsible official of the Respondent. For purposes of these Orders, a responsible official is defined in OAC Rule 3745-33-03(F)(1) for a corporation, OAC Rule 3745-33-03(F)(2) for a partnership, OAC Rule 3745-33-03(F)(3) for a sole proprietorship, and OAC Rule 3745-33-03(F)(4) for a municipal, state, or other public facility.

VII. OTHER CLAIMS

Nothing in these Orders shall constitute or be construed as a release from any claim, cause of action or demand in law or equity against any person, firm, partnership or corporation, not a party to these Orders, for any liability arising from, or related to activities occurring on or at the site.

VIII. OTHER APPLICABLE LAWS

All actions required to be taken pursuant to these Orders shall be undertaken in accordance with the requirements of all applicable local, state and federal laws and regulations. These Orders do not waive or compromise the applicability and enforcement of any other statutes or regulations applicable to Respondent.

IX. MODIFICATIONS

These Orders may be modified by agreement of the parties hereto. Modifications shall be in writing and shall be effective on the date entered in the journal of the Director of Ohio EPA.

X. RESERVATION OF RIGHTS

Ohio EPA and Respondent each reserve all rights, privileges and causes of action, except as specifically waived in Section XI of these Orders.

XI. WAIVER

In order to resolve disputed claims, without admission of fact, violation or liability, and in lieu of further enforcement action by Ohio EPA for only the violations specifically cited in these Orders, Respondent consents to the issuance of these Orders and agrees to comply with these Orders. Compliance with these Orders shall be a full accord and satisfaction for Respondent's liability for the violations specifically cited herein.

Respondent hereby waives the right to appeal the issuance, terms and conditions, and service of these Orders, and Respondent hereby waives any and all rights Respondent may have to seek administrative or judicial review of these Orders either in law or equity.

Notwithstanding the preceding, Ohio EPA and Respondent agree that if these Orders are appealed by any other party to the Environmental Review Appeals Commission, or any court, Respondent retains the right to intervene and participate in such appeal. In such an event, Respondent shall continue to comply with these Orders notwithstanding such appeal and intervention unless these Orders are stayed, vacated or modified.

XII. EFFECTIVE DATE


The effective date of these Orders is the date these Orders are entered into the Ohio EPA Director's journal.

XIII. SIGNATORY AUTHORITY

Each undersigned representative of a party to these Orders certifies that he or she is fully authorized to enter into these Orders and to legally bind such party to these Orders.

IT IS SO ORDERED AND AGREED:

Ohio Environmental Protection Agency




Scott J. Nally
Director

1/28/13

Date

IT IS SO AGREED:

Scott Hess



Signature

1/21/13

Date

Scott Hess

Printed or Typed Name

Owner

Title

Attachment I

Sample ID	Month	Station	Parameter	Unit	Value	Unit	Value	Date
2PY00060*AD	March 2005	001	00530	Total Suspended Solids	30D Conc	12	16.	3/1/2005
2PY00060*AD	March 2005	001	00530	Total Suspended Solids	30D Qty	0.23	.2925	3/1/2005
2PY00060*AD	March 2005	001	80082	CBOD 6 day	30D Conc	10	26.	3/1/2005
2PY00060*AD	March 2005	001	80082	CBOD 5 day	30D Qty	0.19	.47532	3/1/2005
2PY00060*AD	March 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	4.7	3/3/2005
2PY00060*AD	March 2005	001	80082	CBOD 5 day	7D Conc	15	26.	3/8/2005
2PY00060*AD	March 2005	001	80082	CBOD 5 day	7D Qty	0.28	.47532	3/8/2005
2PY00060*AD	March 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	4.3	3/9/2005
2PY00060*AD	March 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	3.8	3/16/2005
2PY00060*AD	April 2005	001	00530	Total Suspended Solids	30D Conc	12	31.	4/1/2005
2PY00060*AD	April 2005	001	00530	Total Suspended Solids	30D Qty	0.23	.50161	4/1/2005
2PY00060*AD	April 2005	001	80082	CBOD 5 day	30D Conc	10	37.	4/1/2005
2PY00060*AD	April 2005	001	80082	CBOD 5 day	30D Qty	0.19	.59869	4/1/2005
2PY00060*AD	April 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	4.	4/6/2005
2PY00060*AD	April 2005	001	00530	Total Suspended Solids	7D Conc	18	31.	4/8/2005
2PY00060*AD	April 2005	001	00530	Total Suspended Solids	7D Qty	0.34	.50161	4/8/2005
2PY00060*AD	April 2005	001	80082	CBOD 5 day	7D Conc	15	37.	4/8/2005
2PY00060*AD	April 2005	001	80082	CBOD 5 day	7D Qty	0.28	.59869	4/8/2005
2PY00060*AD	April 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	4.5	4/13/2005
2PY00060*AD	April 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	3.6	4/20/2005
2PY00060*AD	April 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	3.8	4/27/2005
2PY00060*AD	May 2005	001	00530	Total Suspended Solids	30D Conc	12	56.	5/1/2005
2PY00060*AD	May 2005	001	00530	Total Suspended Solids	7D Conc	18	56.	5/1/2005
2PY00060*AD	May 2005	001	00530	Total Suspended Solids	30D Qty	0.23	1.11279	5/1/2005
2PY00060*AD	May 2005	001	00530	Total Suspended Solids	7D Qty	0.34	1.11279	5/1/2005
2PY00060*AD	May 2005	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	5.0	38.5	5/1/2005
2PY00060*AD	May 2005	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.09	.55739	5/1/2005
2PY00060*AD	May 2005	001	80082	CBOD 5 day	30D Conc	10	43.	5/1/2005
2PY00060*AD	May 2005	001	80082	CBOD 5 day	7D Conc	15	43.	5/1/2005
2PY00060*AD	May 2005	001	80082	CBOD 5 day	30D Qty	0.19	.85446	5/1/2005
2PY00060*AD	May 2005	001	80082	CBOD 5 day	7D Qty	0.28	.85446	5/1/2005
2PY00060*AD	May 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	3.5	5/4/2005
2PY00060*AD	May 2005	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	7.5	38.5	5/8/2005

2PY00060*AD	May 2005	001	00610	Nitrogen, Ammonia (NH3	7D Qty	0.14	.55739	5/8/2005
2PY00060*AD	May 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	.03	5/11/2005
2PY00060*AD	May 2005	001	31616	Fecal Coliform	7D Conc	2000	2515.	5/15/2005
2PY00060*AD	May 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	3.2	5/18/2005
2PY00060*AD	May 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	3.6	5/25/2005
2PY00060*AD	June 2005	001	00530	Total Suspended Solids	30D Conc	12	52.	6/1/2005
2PY00060*AD	June 2005	001	00530	Total Suspended Solids	7D Conc	18	52.	6/1/2005
2PY00060*AD	June 2005	001	00530	Total Suspended Solids	30D Qty	0.23	.85617	6/1/2005
2PY00060*AD	June 2005	001	00530	Total Suspended Solids	7D Qty	0.34	.85617	6/1/2005
2PY00060*AD	June 2005	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	32.1	6/1/2005
2PY00060*AD	June 2005	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.63787	6/1/2005
2PY00060*AD	June 2005	001	31616	Fecal Coliform	30D Conc	1000	1330.	6/1/2005
2PY00060*AD	June 2005	001	80082	CBOD 5 day	30D Conc	10	34.	6/1/2005
2PY00060*AD	June 2005	001	80082	CBOD 5 day	7D Conc	15	34.	6/1/2005
2PY00060*AD	June 2005	001	80082	CBOD 5 day	30D Qty	0.19	.5598	6/1/2005
2PY00060*AD	June 2005	001	80082	CBOD 5 day	7D Qty	0.28	.5598	6/1/2005
2PY00060*AD	June 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	2.5	6/1/2005
2PY00060*AD	June 2005	001	00610	Nitrogen, Ammonia (NH3	7D Conc	7.5	32.1	6/8/2005
2PY00060*AD	June 2005	001	00610	Nitrogen, Ammonia (NH3	7D Qty	0.14	.63787	6/8/2005
2PY00060*AD	June 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	.71	6/10/2005
2PY00060*AD	June 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	.3	6/15/2005
2PY00060*AD	June 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	2.9	6/22/2005
2PY00060*AD	July 2005	001	00530	Total Suspended Solids	30D Conc	12	17.	7/1/2005
2PY00060*AD	July 2005	001	00530	Total Suspended Solids	30D Qty	0.23	.34746	7/1/2005
2PY00060*AD	July 2005	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	22.1	7/1/2005
2PY00060*AD	July 2005	001	00610	Nitrogen, Ammonia (NH3	7D Conc	7.5	22.1	7/1/2005
2PY00060*AD	July 2005	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.45798	7/1/2005
2PY00060*AD	July 2005	001	00610	Nitrogen, Ammonia (NH3	7D Qty	0.14	.45798	7/1/2005
2PY00060*AD	July 2005	001	80082	CBOD 5 day	30D Conc	10	34.	7/1/2005
2PY00060*AD	July 2005	001	80082	CBOD 5 day	30D Qty	0.19	.69493	7/1/2005
2PY00060*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	3.7	7/6/2005
2PY00060*AD	July 2005	001	00530	Total Suspended Solids	7D Qty	0.34	.34746	7/8/2005
2PY00060*AD	July 2005	001	80082	CBOD 5 day	7D Conc	15	34.	7/8/2005
2PY00060*AD	July 2005	001	80082	CBOD 5 day	7D Qty	0.28	.69493	7/8/2005
2PY00060*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	1.4	7/13/2005
2PY00060*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	.2	7/19/2005
2PY00060*AD	July 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	3.2	7/27/2005

2PY00060*AD	August 2005	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	29.1	8/1/2005
2PY00060*AD	August 2005	001	00610	Nitrogen, Ammonia (NH3	7D Conc	7.5	29.1	8/1/2005
2PY00060*AD	August 2005	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.57825	8/1/2005
2PY00060*AD	August 2005	001	00610	Nitrogen, Ammonia (NH3	7D Qty	0.14	.57825	8/1/2005
2PY00060*AD	August 2005	001	80082	CBOD 5 day	30D Conc	10	39.	8/1/2005
2PY00060*AD	August 2005	001	80082	CBOD 5 day	7D Conc	15	39.	8/1/2005
2PY00060*AD	August 2005	001	80082	CBOD 5 day	30D Qty	0.19	.77498	8/1/2005
2PY00060*AD	August 2005	001	80082	CBOD 5 day	7D Qty	0.28	.77498	8/1/2005
2PY00060*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	3.2	8/4/2005
2PY00060*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	2.5	8/10/2005
2PY00060*AD	August 2005	001	50060	Chlorine, Total Residu	1D Conc	0.5	2.2	8/17/2005
2PY00060*AD	August 2005	001	00400	pH	1D Conc	6.5	6.4	8/17/2005
2PY00060*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	4.5	8/17/2005
2PY00060*AD	August 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	4.1	8/24/2005
2PY00060*AD	September 2005	001	00530	Total Suspended Solids	30D Conc	12	15.	9/1/2005
2PY00060*AD	September 2005	001	00530	Total Suspended Solids	30D Qty	0.23	.25549	9/1/2005
2PY00060*AD	September 2005	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	22.8	9/1/2005
2PY00060*AD	September 2005	001	00610	Nitrogen, Ammonia (NH3	7D Conc	7.5	22.8	9/1/2005
2PY00060*AD	September 2005	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.38834	9/1/2005
2PY00060*AD	September 2005	001	00610	Nitrogen, Ammonia (NH3	7D Qty	0.14	.38834	9/1/2005
2PY00060*AD	September 2005	001	80082	CBOD 5 day	30D Conc	10	12.	9/1/2005
2PY00060*AD	September 2005	001	80082	CBOD 5 day	30D Qty	0.19	.20439	9/1/2005
2PY00060*AD	September 2005	001	50060	Chlorine, Total Residu	1D Conc	0.5	2.2	9/7/2005
2PY00060*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	3.8	9/7/2005
2PY00060*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	3.7	9/12/2005
2PY00060*AD	September 2005	001	50060	Chlorine, Total Residu	1D Conc	0.5	1.34	9/21/2005
2PY00060*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	2.8	9/21/2005
2PY00060*AD	September 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	1.	9/28/2005
2PY00060*AD	October 2005	001	00530	Total Suspended Solids	30D Conc	12	20.	10/1/2005
2PY00060*AD	October 2005	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	34.2	10/1/2005
2PY00060*AD	October 2005	001	00610	Nitrogen, Ammonia (NH3	7D Conc	7.5	34.2	10/1/2005
2PY00060*AD	October 2005	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.95144	10/1/2005
2PY00060*AD	October 2005	001	00610	Nitrogen, Ammonia (NH3	7D Qty	0.14	.95144	10/1/2005
2PY00060*AD	October 2005	001	31616	Fecal Coliform	30D Conc	1000	54000.	10/1/2005
2PY00060*AD	October 2005	001	31616	Fecal Coliform	7D Conc	2000	54000.	10/1/2005
2PY00060*AD	October 2005	001	80082	CBOD 5 day	30D Conc	10	79.	10/1/2005
2PY00060*AD	October 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	.08	10/5/2005

2PY00060*AD	October 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	.07	10/10/2005
2PY00060*AD	October 2005	001	00530	Total Suspended Solids	7D Conc	18	20.	10/15/2005
2PY00060*AD	October 2005	001	80082	CBOD 5 day	7D Conc	15	79.	10/15/2005
2PY00060*AD	October 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	.13	10/18/2005
2PY00060*AD	October 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	4.3	10/26/2005
2PY00060*AD	November 2005	001	80082	CBOD 5 day	30D Conc	10	22.	11/1/2005
2PY00060*AD	November 2005	001	80082	CBOD 5 day	30D Qty	0.19	.59954	11/1/2005
2PY00060*AD	November 2005	001	00300	Dissolved Oxygen	1D Conc	6.0	3.3	11/3/2005
2PY00060*AD	November 2005	001	80082	CBOD 5 day	7D Conc	15	22.	11/8/2005
2PY00060*AD	November 2005	001	80082	CBOD 5 day	7D Qty	0.28	.59954	11/8/2005
2PY00060*AD	November 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	4.7	11/9/2005
2PY00060*AD	December 2005	001	00530	Total Suspended Solids	30D Conc	12	52.	12/1/2005
2PY00060*AD	December 2005	001	00530	Total Suspended Solids	30D Qty	0.23	.81188	12/1/2005
2PY00080*AD	December 2005	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	11.	12/1/2005
2PY00080*AD	December 2005	001	00610	Nitrogen, Ammonia (NH3	7D Conc	7.5	11.	12/1/2005
2PY00060*AD	December 2005	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.20818	12/1/2005
2PY00060*AD	December 2005	001	00610	Nitrogen, Ammonia (NH3	7D Qty	0.14	.20818	12/1/2005
2PY00060*AD	December 2005	001	80082	CBOD 5 day	30D Conc	10	66.	12/1/2005
2PY00060*AD	December 2005	001	80082	CBOD 5 day	30D Qty	0.19	1.03047	12/1/2005
2PY00060*AD	December 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	3.5	12/1/2005
2PY00060*AD	December 2005	001	00530	Total Suspended Solids	7D Conc	18	52.	12/8/2005
2PY00060*AD	December 2005	001	00530	Total Suspended Solids	7D Qty	0.34	.81188	12/8/2005
2PY00060*AD	December 2005	001	80082	CBOD 5 day	7D Conc	15	66.	12/8/2005
2PY00060*AD	December 2005	001	80082	CBOD 5 day	7D Qty	0.28	1.03047	12/8/2005
2PY00060*AD	December 2005	001	00300	Dissolved Oxygen	1D Conc	5.0	4.	12/8/2005
2PY00060*AD	January 2006	001	00530	Total Suspended Solids	30D Conc	12	26.	1/1/2006
2PY00060*AD	January 2006	001	00530	Total Suspended Solids	7D Conc	18	26.	1/1/2006
2PY00060*AD	January 2006	001	00530	Total Suspended Solids	30D Qty	0.23	.49205	1/1/2006
2PY00060*AD	January 2006	001	00530	Total Suspended Solids	7D Qty	0.34	.49205	1/1/2006
2PY00060*AD	January 2006	001	80082	CBOD 5 day	30D Conc	10	38.	1/1/2006
2PY00060*AD	January 2006	001	80082	CBOD 5 day	7D Conc	15	38.	1/1/2006
2PY00060*AD	January 2006	001	80082	CBOD 5 day	30D Qty	0.19	.71915	1/1/2006
2PY00060*AD	January 2006	001	80082	CBOD 5 day	7D Qty	0.28	.71915	1/1/2006
2PY00060*AD	January 2006	001	00300	Dissolved Oxygen	1D Conc	5.0	3.2	1/4/2006
2PY00060*AD	January 2006	001	00300	Dissolved Oxygen	1D Conc	5.0	2.1	1/11/2006
2PY00060*AD	January 2006	001	00300	Dissolved Oxygen	1D Conc	5.0	4.	1/19/2006
2PY00060*AD	January 2006	001	00300	Dissolved Oxygen	1D Conc	5.0	2.5	1/25/2006

2PY00060*AD	February 2006	001	00530	Total Suspended Solids	30D Conc	12	28.	2/1/2006
2PY00060*AD	February 2006	001	00530	Total Suspended Solids	7D Conc	18	28.	2/1/2006
2PY00060*AD	February 2006	001	00530	Total Suspended Solids	30D Qty	0.23	.87434	2/1/2006
2PY00060*AD	February 2006	001	00530	Total Suspended Solids	7D Qty	0.34	.87434	2/1/2006
2PY00060*AD	February 2006	001	80082	CBOD 5 day	30D Conc	10	14.	2/1/2006
2PY00060*AD	February 2006	001	80082	CBOD 5 day	30D Qty	0.19	.43717	2/1/2006
2PY00060*AD	February 2006	001	80082	CBOD 5 day	7D Qty	0.28	.43717	2/1/2006
2PY00060*AD	February 2006	001	00300	Dissolved Oxygen	1D Conc	5.0	4.3	2/1/2006
2PY00060*AD	February 2006	001	00300	Dissolved Oxygen	1D Conc	5.0	4.5	2/15/2006
2PY00060*AD	February 2006	001	00300	Dissolved Oxygen	1D Conc	5.0	4.2	2/22/2006
2PY00060*AD	March 2006	001	00530	Total Suspended Solids	30D Conc	12	44.	3/1/2006
2PY00060*AD	March 2006	001	00530	Total Suspended Solids	7D Conc	18	44.	3/1/2006
2PY00060*AD	March 2006	001	00530	Total Suspended Solids	30D Qty	0.23	1.06169	3/1/2006
2PY00060*AD	March 2006	001	00530	Total Suspended Solids	7D Qty	0.34	1.06169	3/1/2006
2PY00060*AD	March 2006	001	80082	CBOD 5 day	30D Conc	10	76.	3/1/2006
2PY00060*AD	March 2006	001	80082	CBOD 5 day	7D Conc	15	76.	3/1/2006
2PY00060*AD	March 2006	001	80082	CBOD 5 day	30D Qty	0.19	1.83383	3/1/2006
2PY00060*AD	March 2006	001	80082	CBOD 5 day	7D Qty	0.28	1.83383	3/1/2006
2PY00060*AD	March 2006	001	00300	Dissolved Oxygen	1D Conc	5.0	4.6	3/8/2006
2PY00060*AD	April 2006	001	80082	CBOD 5 day	30D Conc	10	17.	4/1/2006
2PY00060*AD	April 2006	001	80082	CBOD 5 day	7D Conc	15	17.	4/1/2006
2PY00060*AD	April 2006	001	80082	CBOD 5 day	30D Qty	0.19	.33781	4/1/2006
2PY00060*AD	April 2006	001	80082	CBOD 5 day	7D Qty	0.28	.33781	4/1/2006
2PY00060*AD	April 2006	001	00300	Dissolved Oxygen	1D Conc	5.0	3.4	4/11/2006
2PY00060*AD	April 2006	001	00300	Dissolved Oxygen	1D Conc	5.0	2.4	4/19/2006
2PY00060*AD	April 2006	001	00300	Dissolved Oxygen	1D Conc	5.0	2.6	4/26/2006
2PY00060*BD	February 2007	001	80082	CBOD 5 day	30D Qty	0.19	.24527	2/1/2007
2PY00060*BD	April 2007	001	00530	Total Suspended Solids	30D Conc	12	18.	4/1/2007
2PY00060*BD	April 2007	001	00530	Total Suspended Solids	30D Qty	0.23	.43433	4/1/2007
2PY00060*BD	April 2007	001	80082	CBOD 5 day	30D Conc	10	15.	4/1/2007
2PY00060*BD	April 2007	001	80082	CBOD 5 day	30D Qty	0.19	.36194	4/1/2007
2PY00060*BD	April 2007	001	00530	Total Suspended Solids	1D Qty	0.34	.43433	4/4/2007
2PY00060*BD	April 2007	001	80082	CBOD 5 day	1D Qty	0.28	.36194	4/4/2007
2PY00060*BD	May 2007	001	00530	Total Suspended Solids	30D Conc	12	14.	5/1/2007
2PY00060*BD	May 2007	001	00530	Total Suspended Solids	30D Qty	0.23	.35768	5/1/2007
2PY00060*BD	May 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	5.0	6.93	5/1/2007
2PY00060*BD	May 2007	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.09	.17705	5/1/2007

2PY00060*BD	May 2007	001	80082	CBOD 5 day	30D Conc	10	13.	5/1/2007
2PY00060*BD	May 2007	001	80082	CBOD 5 day	30D Qty	0.19	.33213	5/1/2007
2PY00060*BD	May 2007	001	00530	Total Suspended Solids	1D Qty	0.34	.35768	5/10/2007
2PY00060*BD	May 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.14409	5/10/2007
2PY00060*BD	May 2007	001	80082	CBOD 5 day	1D Qty	0.28	.33213	5/10/2007
2PY00060*BD	May 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	8.22	5/22/2007
2PY00060*BD	May 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.21001	5/22/2007
2PY00060*BD	May 2007	001	50060	Chlorine, Total Residu	1D Conc	0.019	.05	5/22/2007
2PY00060*BD	June 2007	001	00530	Total Suspended Solids	30D Conc	12	28.	6/1/2007
2PY00060*BD	June 2007	001	00530	Total Suspended Solids	30D Qty	0.23	.67562	6/1/2007
2PY00060*BD	June 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	14.3	6/1/2007
2PY00060*BD	June 2007	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.34505	6/1/2007
2PY00060*BD	June 2007	001	80082	CBOD 5 day	30D Conc	10	23.	6/1/2007
2PY00060*BD	June 2007	001	80082	CBOD 5 day	30D Qty	0.19	.55498	6/1/2007
2PY00060*BD	June 2007	001	00400	pH	1D Conc	6.5	6.2	6/1/2007
2PY00060*BD	June 2007	001	00300	Dissolved Oxygen	1D Conc	5.0	1.6	6/1/2007
2PY00060*BD	June 2007	001	00530	Total Suspended Solids	1D Conc	18	28.	6/7/2007
2PY00060*BD	June 2007	001	00530	Total Suspended Solids	1D Qty	0.34	.67562	6/7/2007
2PY00060*BD	June 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	14.3	6/7/2007
2PY00060*BD	June 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.34505	6/7/2007
2PY00060*BD	June 2007	001	80082	CBOD 5 day	1D Conc	15	23.	6/7/2007
2PY00060*BD	June 2007	001	80082	CBOD 5 day	1D Qty	0.28	.55498	6/7/2007
2PY00060*BD	June 2007	001	00300	Dissolved Oxygen	1D Conc	5.0	.6	6/13/2007
2PY00060*BD	June 2007	001	50060	Chlorine, Total Residu	1D Conc	0.019	.1	6/20/2007
2PY00060*BD	June 2007	001	00300	Dissolved Oxygen	1D Conc	5.0	4.6	6/20/2007
2PY00060*BD	June 2007	001	00300	Dissolved Oxygen	1D Conc	5.0	3.	6/22/2007
2PY00060*BD	July 2007	001	00530	Total Suspended Solids	30D Conc	12	17.	7/1/2007
2PY00060*BD	July 2007	001	00530	Total Suspended Solids	30D Qty	0.23	.42468	7/1/2007
2PY00060*BD	July 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	15.25	7/1/2007
2PY00060*BD	July 2007	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.38096	7/1/2007
2PY00060*BD	July 2007	001	80082	CBOD 5 day	30D Conc	10	13.	7/1/2007
2PY00060*BD	July 2007	001	80082	CBOD 5 day	30D Qty	0.19	.32475	7/1/2007
2PY00060*BD	July 2007	001	00530	Total Suspended Solids	1D Qty	0.34	.42468	7/5/2007
2PY00060*BD	July 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	18.8	7/5/2007
2PY00060*BD	July 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.46964	7/5/2007
2PY00060*BD	July 2007	001	80082	CBOD 5 day	1D Qty	0.28	.32475	7/5/2007
2PY00060*BD	July 2007	001	00300	Dissolved Oxygen	1D Conc	5.0	3.2	7/5/2007

2PY00060*BD	July 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	11.7	7/11/2007
2PY00060*BD	July 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.29228	7/11/2007
2PY00060*BD	July 2007	001	00300	Dissolved Oxygen	1D Conc	5.0	3.	7/11/2007
2PY00060*BD	July 2007	001	00300	Dissolved Oxygen	1D Conc	5.0	.8	7/18/2007
2PY00060*BD	July 2007	001	00300	Dissolved Oxygen	1D Conc	5.0	3.3	7/25/2007
2PY00060*BD	August 2007	001	00530	Total Suspended Solids	30D Conc	12	22.	8/1/2007
2PY00060*BD	August 2007	001	00530	Total Suspended Solids	30D Qty	0.23	.48713	8/1/2007
2PY00060*BD	August 2007	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.10894	8/1/2007
2PY00060*BD	August 2007	001	80082	CBOD 5 day	30D Conc	10	11.	8/1/2007
2PY00060*BD	August 2007	001	80082	CBOD 5 day	30D Qty	0.19	.24356	8/1/2007
2PY00060*BD	August 2007	001	00300	Dissolved Oxygen	1D Conc	5.0	.1	8/1/2007
2PY00060*BD	August 2007	001	00530	Total Suspended Solids	1D Conc	18	22.	8/9/2007
2PY00060*BD	August 2007	001	00530	Total Suspended Solids	1D Qty	0.34	.48713	8/9/2007
2PY00060*BD	August 2007	001	50060	Chlorine, Total Residu	1D Conc	0.019	.13	8/17/2007
2PY00060*BD	August 2007	001	00300	Dissolved Oxygen	1D Conc	5.0	2.	8/17/2007
2PY00060*BD	August 2007	001	00300	Dissolved Oxygen	1D Conc	5.0	3.7	8/22/2007
2PY00060*BD	September 2007	001	00530	Total Suspended Solids	30D Conc	12	36.	9/1/2007
2PY00060*BD	September 2007	001	00530	Total Suspended Solids	30D Qty	0.23	.77668	9/1/2007
2PY00060*BD	September 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	11.3	9/1/2007
2PY00060*BD	September 2007	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.24379	9/1/2007
2PY00060*BD	September 2007	001	00530	Total Suspended Solids	1D Conc	18	36.	9/5/2007
2PY00060*BD	September 2007	001	00530	Total Suspended Solids	1D Qty	0.34	.77668	9/5/2007
2PY00060*BD	September 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	11.3	9/5/2007
2PY00060*BD	September 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.24379	9/5/2007
2PY00060*BD	September 2007	001	50060	Chlorine, Total Residu	1D Conc	0.019	2.2	9/5/2007
2PY00060*BD	September 2007	001	00300	Dissolved Oxygen	1D Conc	5.0	2.4	9/19/2007
2PY00060*BD	September 2007	001	00300	Dissolved Oxygen	1D Conc	5.0	3.9	9/27/2007
2PY00060*BD	October 2007	001	00530	Total Suspended Solids	30D Conc	12	16.	10/1/2007
2PY00060*BD	October 2007	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	20.4	10/1/2007
2PY00060*BD	October 2007	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.22585	10/1/2007
2PY00060*BD	October 2007	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	20.4	10/4/2007
2PY00060*BD	October 2007	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.22585	10/4/2007
2PY00060*BD	October 2007	001	50060	Chlorine, Total Residu	1D Conc	0.019	2.2	10/4/2007
2PY00060*BD	October 2007	001	50060	Chlorine, Total Residu	1D Conc	0.019	.13	10/18/2007
2PY00060*BD	November 2007	001	00530	Total Suspended Solids	30D Conc	12	90.	11/1/2007
2PY00060*BD	November 2007	001	00530	Total Suspended Solids	30D Qty	0.23	1.02195	11/1/2007
2PY00060*BD	November 2007	001	80082	CBOD 5 day	30D Conc	10	26.	11/1/2007

2PY00060*BD	November 2007	001	80082	CBOD 5 day	30D Qty	0.19	.29523	11/1/2007
2PY00060*BD	November 2007	001	00530	Total Suspended Solids	1D Conc	18	90.	11/8/2007
2PY00060*BD	November 2007	001	00530	Total Suspended Solids	1D Qty	0.34	1.02195	11/8/2007
2PY00060*BD	November 2007	001	80082	CBOD 5 day	1D Conc	15	26.	11/8/2007
2PY00060*BD	November 2007	001	80082	CBOD 5 day	1D Qty	0.28	.29523	11/8/2007
2PY00060*BD	December 2007	001	00530	Total Suspended Solids	30D Conc	12	30.	12/1/2007
2PY00060*BD	December 2007	001	00530	Total Suspended Solids	30D Qty	0.23	.59614	12/1/2007
2PY00060*BD	December 2007	001	80082	CBOD 5 day	30D Conc	10	25.	12/1/2007
2PY00060*BD	December 2007	001	80082	CBOD 5 day	30D Qty	0.19	.49678	12/1/2007
2PY00060*BD	December 2007	001	00530	Total Suspended Solids	1D Conc	18	30.	12/5/2007
2PY00060*BD	December 2007	001	00530	Total Suspended Solids	1D Qty	0.34	.59614	12/5/2007
2PY00060*BD	December 2007	001	80082	CBOD 5 day	1D Conc	15	25.	12/5/2007
2PY00060*BD	December 2007	001	80082	CBOD 5 day	1D Qty	0.28	.49678	12/5/2007
2PY00060*BD	December 2007	001	00300	Dissolved Oxygen	1D Conc	5.0	1.6	12/26/2007
2PY00060*BD	January 2008	001	00530	Total Suspended Solids	30D Conc	12	82.	1/1/2008
2PY00060*BD	January 2008	001	00530	Total Suspended Solids	30D Qty	0.23	1.86222	1/1/2008
2PY00060*BD	January 2008	001	80082	CBOD 5 day	30D Conc	10	22.	1/1/2008
2PY00060*BD	January 2008	001	80082	CBOD 5 day	30D Qty	0.19	.49962	1/1/2008
2PY00060*BD	January 2008	001	00530	Total Suspended Solids	1D Conc	18	82.	1/3/2008
2PY00060*BD	January 2008	001	00530	Total Suspended Solids	1D Qty	0.34	1.86222	1/3/2008
2PY00060*BD	January 2008	001	80082	CBOD 5 day	1D Conc	15	22.	1/3/2008
2PY00060*BD	January 2008	001	80082	CBOD 5 day	1D Qty	0.28	.49962	1/3/2008
2PY00060*BD	February 2008	001	00530	Total Suspended Solids	30D Conc	12	28.	2/1/2008
2PY00060*BD	February 2008	001	00530	Total Suspended Solids	30D Qty	0.23	.63588	2/1/2008
2PY00060*BD	February 2008	001	80082	CBOD 5 day	30D Conc	10	22.	2/1/2008
2PY00060*BD	February 2008	001	80082	CBOD 5 day	30D Qty	0.19	.49962	2/1/2008
2PY00060*BD	February 2008	001	00530	Total Suspended Solids	1D Conc	18	28.	2/12/2008
2PY00060*BD	February 2008	001	00530	Total Suspended Solids	1D Qty	0.34	.63588	2/12/2008
2PY00060*BD	February 2008	001	80082	CBOD 5 day	1D Conc	15	22.	2/12/2008
2PY00060*BD	February 2008	001	80082	CBOD 5 day	1D Qty	0.28	.49962	2/12/2008
2PY00060*BD	March 2008	001	00530	Total Suspended Solids	30D Conc	12	50.	3/1/2008
2PY00060*BD	March 2008	001	00530	Total Suspended Solids	30D Qty	0.23	1.46196	3/1/2008
2PY00060*BD	March 2008	001	80082	CBOD 5 day	30D Conc	10	20.	3/1/2008
2PY00060*BD	March 2008	001	80082	CBOD 5 day	30D Qty	0.19	.58478	3/1/2008
2PY00060*BD	March 2008	001	00530	Total Suspended Solids	1D Conc	18	50.	3/6/2008
2PY00060*BD	March 2008	001	00530	Total Suspended Solids	1D Qty	0.34	1.46196	3/6/2008
2PY00060*BD	March 2008	001	80082	CBOD 5 day	1D Conc	15	20.	3/6/2008

2PY00060*BD	March 2008	001	80082	CBOD 5 day	1D Qty	0.28	.58478	3/6/2008
2PY00060*BD	March 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	2.9	3/6/2008
2PY00060*BD	April 2008	001	80082	CBOD 5 day	30D Conc	10	12.	4/1/2008
2PY00060*BD	April 2008	001	80082	CBOD 5 day	30D Qty	0.19	.27593	4/1/2008
2PY00060*BD	May 2008	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	13.4	5/1/2008
2PY00060*BD	May 2008	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.30431	5/1/2008
2PY00060*BD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.019	.09	5/1/2008
2PY00060*BD	May 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.7	5/1/2008
2PY00060*BD	May 2008	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	13.4	5/15/2008
2PY00060*BD	May 2008	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.30431	5/15/2008
2PY00060*BD	May 2008	001	50060	Chlorine, Total Residu	1D Conc	0.019	1.94	5/15/2008
2PY00060*BD	June 2008	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	19.2	6/1/2008
2PY00060*BD	June 2008	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.43603	6/1/2008
2PY00060*BD	June 2008	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	19.2	6/4/2008
2PY00060*BD	June 2008	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.43603	6/4/2008
2PY00060*BD	June 2008	001	50060	Chlorine, Total Residu	1D Conc	0.019	.08	6/4/2008
2PY00060*BD	July 2008	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	14.5	7/1/2008
2PY00060*BD	July 2008	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.28813	7/1/2008
2PY00060*BD	July 2008	001	31616	Fecal Coliform	30D Conc	1000	23000.	7/1/2008
2PY00060*BD	July 2008	001	80082	CBOD 5 day	30D Conc	10	15.	7/1/2008
2PY00060*BD	July 2008	001	80082	CBOD 5 day	30D Qty	0.19	.29807	7/1/2008
2PY00060*BD	July 2008	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	14.5	7/11/2008
2PY00060*BD	July 2008	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.28813	7/11/2008
2PY00060*BD	July 2008	001	80082	CBOD 5 day	1D Qty	0.28	.29807	7/11/2008
2PY00060*BD	July 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	3.3	7/11/2008
2PY00060*BD	July 2008	001	31616	Fecal Coliform	1D Conc	2000	23000.	7/16/2008
2PY00060*BD	July 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.5	7/16/2008
2PY00060*BD	July 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	3.5	7/23/2008
2PY00060*BD	August 2008	001	00530	Total Suspended Solids	30D Conc	12	18.	8/1/2008
2PY00060*BD	August 2008	001	00530	Total Suspended Solids	30D Qty	0.23	.49054	8/1/2008
2PY00060*BD	August 2008	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	28.25	8/1/2008
2PY00060*BD	August 2008	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.76987	8/1/2008
2PY00060*BD	August 2008	001	31616	Fecal Coliform	30D Conc	1000	31600.	8/1/2008
2PY00060*BD	August 2008	001	80082	CBOD 5 day	30D Conc	10	74.	8/1/2008
2PY00060*BD	August 2008	001	80082	CBOD 5 day	30D Qty	0.19	2.01665	8/1/2008
2PY00060*BD	August 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	3.9	8/6/2008
2PY00060*BD	August 2008	001	00530	Total Suspended Solids	1D Qty	0.34	.49054	8/13/2008

2PY00060*BD	August 2008	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	32.3	8/13/2008
2PY00060*BD	August 2008	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.88024	8/13/2008
2PY00060*BD	August 2008	001	80082	CBOD 5 day	1D Conc	15	74.	8/13/2008
2PY00060*BD	August 2008	001	80082	CBOD 5 day	1D Qty	0.28	2.01665	8/13/2008
2PY00060*BD	August 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	2.4	8/13/2008
2PY00060*BD	August 2008	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	24.2	8/20/2008
2PY00060*BD	August 2008	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.6595	8/20/2008
2PY00060*BD	August 2008	001	31616	Fecal Coliform	1D Conc	2000	31600.	8/20/2008
2PY00060*BD	August 2008	001	50060	Chlorine, Total Residu	1D Conc	0.019	.09	8/20/2008
2PY00060*BD	August 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	2.7	8/20/2008
2PY00060*BD	August 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	3.1	8/27/2008
2PY00060*BD	September 2008	001	00530	Total Suspended Solids	30D Conc	12	40.	9/1/2008
2PY00060*BD	September 2008	001	00530	Total Suspended Solids	30D Qty	0.23	.94247	9/1/2008
2PY00060*BD	September 2008	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	7.345	9/1/2008
2PY00060*BD	September 2008	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.17306	9/1/2008
2PY00060*BD	September 2008	001	80082	CBOD 5 day	30D Conc	10	22.	9/1/2008
2PY00060*BD	September 2008	001	80082	CBOD 5 day	30D Qty	0.19	.51836	9/1/2008
2PY00060*BD	September 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	3.9	9/3/2008
2PY00060*BD	September 2008	001	00530	Total Suspended Solids	1D Conc	18	40.	9/11/2008
2PY00060*BD	September 2008	001	00530	Total Suspended Solids	1D Qty	0.34	.94247	9/11/2008
2PY00060*BD	September 2008	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	11.4	9/11/2008
2PY00060*BD	September 2008	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.2686	9/11/2008
2PY00060*BD	September 2008	001	80082	CBOD 5 day	1D Conc	15	22.	9/11/2008
2PY00060*BD	September 2008	001	80082	CBOD 5 day	1D Qty	0.28	.51836	9/11/2008
2PY00060*BD	September 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	2.8	9/11/2008
2PY00060*BD	September 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	3.5	9/17/2008
2PY00060*BD	September 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	3.9	9/24/2008
2PY00060*BD	October 2008	001	00530	Total Suspended Solids	30D Conc	12	19.	10/1/2008
2PY00060*BD	October 2008	001	00530	Total Suspended Solids	30D Qty	0.23	.43149	10/1/2008
2PY00060*BD	October 2008	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	24.	10/1/2008
2PY00060*BD	October 2008	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	24.3	10/1/2008
2PY00060*BD	October 2008	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.70855	10/1/2008
2PY00060*BD	October 2008	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.63361	10/1/2008
2PY00060*BD	October 2008	001	80082	CBOD 5 day	30D Conc	10	13.	10/1/2008
2PY00060*BD	October 2008	001	80082	CBOD 5 day	30D Qty	0.19	.29523	10/1/2008
2PY00060*BD	October 2008	001	00300	Dissolved Oxygen	1D Conc	5.0	4.1	10/1/2008
2PY00060*BD	October 2008	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	24.6	10/15/2008

2PY00060*BD	October 2008	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.55867	10/15/2008
2PY00060*BD	October 2008	001	50060	Chlorine, Total Residu	1D Conc	0.019	.3	10/15/2008
2PY00060*BD	October 2008	001	00530	Total Suspended Solids	1D Conc	18	19.	10/22/2008
2PY00060*BD	October 2008	001	00530	Total Suspended Solids	1D Qty	0.34	.43149	10/22/2008
2PY00060*BD	October 2008	001	80082	CBOD 5 day	1D Qty	0.28	.29523	10/22/2008
2PY00060*BD	November 2008	001	80082	CBOD 5 day	30D Qty	0.19	.19162	11/1/2008
2PY00060*BD	May 2009	001	00530	Total Suspended Solids	30D Conc	12	32.	5/1/2009
2PY00060*BD	May 2009	001	00530	Total Suspended Solids	30D Qty	0.23	.58138	5/1/2009
2PY00060*BD	May 2009	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	15.9	5/1/2009
2PY00060*BD	May 2009	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.30693	5/1/2009
2PY00060*BD	May 2009	001	31616	Fecal Coliform	30D Conc	1000	2800.	5/1/2009
2PY00060*BD	May 2009	001	80082	CBOD 5 day	30D Conc	10	26.	5/1/2009
2PY00060*BD	May 2009	001	80082	CBOD 5 day	30D Qty	0.19	.47237	5/1/2009
2PY00060*BD	May 2009	001	50060	Chlorine, Total Residu	1D Conc	0.019	.14	5/1/2009
2PY00060*BD	May 2009	001	00300	Dissolved Oxygen	1D Conc	5.0	4.9	5/1/2009
2PY00060*BD	May 2009	001	00300	Dissolved Oxygen	1D Conc	5.0	3.1	5/13/2009
2PY00060*BD	May 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	15.9	5/20/2009
2PY00060*BD	May 2009	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.30893	5/20/2009
2PY00060*BD	May 2009	001	50060	Chlorine, Total Residu	1D Conc	0.019	.06	5/20/2009
2PY00060*BD	May 2009	001	00530	Total Suspended Solids	1D Conc	18	32.	5/27/2009
2PY00060*BD	May 2009	001	00530	Total Suspended Solids	1D Qty	0.34	.58138	5/27/2009
2PY00060*BD	May 2009	001	31616	Fecal Coliform	1D Conc	2000	2800.	5/27/2009
2PY00060*BD	May 2009	001	80082	CBOD 5 day	1D Conc	15	26.	5/27/2009
2PY00060*BD	May 2009	001	80082	CBOD 5 day	1D Qty	0.28	.47237	5/27/2009
2PY00060*BD	May 2009	001	00300	Dissolved Oxygen	1D Conc	5.0	4.2	5/27/2009
2PY00060*BD	June 2009	001	00530	Total Suspended Solids	30D Conc	12	42.	6/1/2009
2PY00060*BD	June 2009	001	00530	Total Suspended Solids	30D Qty	0.23	.82267	6/1/2009
2PY00060*BD	June 2009	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	10.685	6/1/2009
2PY00060*BD	June 2009	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.19435	6/1/2009
2PY00060*BD	June 2009	001	80082	CBOD 5 day	30D Conc	10	24.	6/1/2009
2PY00060*BD	June 2009	001	80082	CBOD 5 day	30D Qty	0.19	.4701	6/1/2009
2PY00060*BD	June 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	11.7	6/3/2009
2PY00060*BD	June 2009	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.19928	6/3/2009
2PY00060*BD	June 2009	001	00300	Dissolved Oxygen	1D Conc	5.0	3.9	6/3/2009
2PY00060*BD	June 2009	001	00530	Total Suspended Solids	1D Conc	18	42.	6/10/2009
2PY00060*BD	June 2009	001	00530	Total Suspended Solids	1D Qty	0.34	.82267	6/10/2009
2PY00060*BD	June 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	9.67	6/10/2009

2PY00060*BD	June 2009	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.18941	6/10/2009
2PY00060*BD	June 2009	001	80082	CBOD 5 day	1D Conc	15	24.	6/10/2009
2PY00060*BD	June 2009	001	80082	CBOD 5 day	1D Qty	0.28	.4701	6/10/2009
2PY00060*BD	June 2009	001	00300	Dissolved Oxygen	1D Conc	5.0	4.7	6/10/2009
2PY00060*BD	June 2009	001	00300	Dissolved Oxygen	1D Conc	5.0	4.4	6/17/2009
2PY00060*BD	July 2009	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	11.11	7/1/2009
2PY00060*BD	July 2009	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.20814	7/1/2009
2PY00060*BD	July 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	13.9	7/16/2009
2PY00060*BD	July 2009	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.24859	7/16/2009
2PY00060*BD	July 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	8.32	7/22/2009
2PY00060*BD	July 2009	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.16769	7/22/2009
2PY00060*BD	August 2009	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	18.3	8/1/2009
2PY00060*BD	August 2009	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.36802	8/1/2009
2PY00060*BD	August 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	13.3	8/5/2009
2PY00060*BD	August 2009	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.23786	8/5/2009
2PY00060*BD	August 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	19.3	8/12/2009
2PY00060*BD	August 2009	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.45474	8/12/2009
2PY00060*BD	August 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	26.7	8/20/2009
2PY00060*BD	August 2009	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.52298	8/20/2009
2PY00060*BD	August 2009	001	50080	Chlorine, Total Residu	1D Conc	0.019	.05	8/20/2009
2PY00060*BD	August 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	13.9	8/26/2009
2PY00060*BD	August 2009	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.25648	8/26/2009
2PY00060*BD	September 2009	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	7.09	9/1/2009
2PY00060*BD	September 2009	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.14693	9/1/2009
2PY00060*BD	September 2009	001	80082	CBOD 5 day	30D Qty	0.19	.20723	9/1/2009
2PY00060*BD	September 2009	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.14693	9/10/2009
2PY00060*BD	October 2009	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	10.7	10/1/2009
2PY00060*BD	October 2009	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.22477	10/1/2009
2PY00060*BD	October 2009	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	10.7	10/20/2009
2PY00060*BD	October 2009	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.22477	10/20/2009
2PY00060*CD	May 2010	001	50060	Chlorine, Total Residu	1D Conc	0.019	.58	5/5/2010
2PY00060*CD	June 2010	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	8.05	6/1/2010
2PY00060*CD	June 2010	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.18282	6/1/2010
2PY00060*CD	June 2010	001	80082	CBOD 5 day	30D Qty	0.19	.2271	6/1/2010
2PY00060*CD	June 2010	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	8.05	6/16/2010
2PY00060*CD	June 2010	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.18282	6/16/2010
2PY00060*CD	July 2010	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	10.5	7/1/2010

2PY00060*CD	July 2010	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	5.0	9.9	7/1/2010
2PY00060*CD	July 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.19887	7/1/2010
2PY00060*CD	July 2010	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.09	.19149	7/1/2010
2PY00060*CD	July 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	7.5	12.	7/8/2010
2PY00060*CD	July 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.24186	7/8/2010
2PY00060*CD	July 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	7.5	10.4	7/28/2010
2PY00060*CD	July 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.1978	7/28/2010
2PY00060*CD	August 2010	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	5.0	8.72333	8/1/2010
2PY00060*CD	August 2010	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.09	.17293	8/1/2010
2PY00060*CD	August 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	7.5	10.5	8/4/2010
2PY00060*CD	August 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.21163	8/4/2010
2PY00060*CD	August 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	7.5	11.2	8/19/2010
2PY00060*CD	August 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.22256	8/19/2010
2PY00060*CD	October 2010	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	5.0	8.65	10/1/2010
2PY00060*CD	October 2010	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.09	.15024	10/1/2010
2PY00060*CD	October 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	7.5	10.7	10/6/2010
2PY00060*CD	October 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.19707	10/6/2010
2PY00060*CD	October 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	7.5	8.93	10/21/2010
2PY00060*CD	October 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.14754	10/21/2010
2PY00060*CD	October 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	7.5	10.2	10/27/2010
2PY00060*CD	October 2010	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.17759	10/27/2010
2PY00060*CD	March 2011	001	80082	CBOD 5 day	30D Qty	0.19	.19758	3/1/2011
2PY00060*CD	April 2011	001	00530	Total Suspended Solids	30D Conc	12.0	28.	4/1/2011
2PY00060*CD	April 2011	001	00530	Total Suspended Solids	30D Qty	0.228	.53618	4/1/2011
2PY00060*CD	April 2011	001	80082	CBOD 5 day	30D Conc	10.0	18.	4/1/2011
2PY00060*CD	April 2011	001	80082	CBOD 5 day	30D Qty	0.19	.34476	4/1/2011
2PY00060*CD	April 2011	001	00530	Total Suspended Solids	1D Conc	18.0	38.	4/20/2011
2PY00060*CD	April 2011	001	00530	Total Suspended Solids	1D Qty	0.341	.72332	4/20/2011
2PY00060*CD	April 2011	001	80082	CBOD 5 day	1D Conc	15.0	24.	4/20/2011
2PY00060*CD	April 2011	001	80082	CBOD 5 day	1D Qty	0.28	.45683	4/20/2011
2PY00060*CD	April 2011	001	00530	Total Suspended Solids	1D Qty	0.341	.34903	4/27/2011
2PY00060*CD	May 2011	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	5.0	11.2666	5/1/2011
2PY00060*CD	May 2011	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.09	.2117	5/1/2011
2PY00060*CD	May 2011	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	7.5	10.3	5/5/2011
2PY00060*CD	May 2011	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.1915	5/5/2011
2PY00060*CD	May 2011	001	31616	Fecal Coliform	1D Conc	2000	6050.	5/5/2011
2PY00060*CD	May 2011	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	7.5	12.2	5/18/2011

2PY00060*CD	May 2011	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.22987	5/18/2011
2PY00060*CD	May 2011	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	11.3	5/25/2011
2PY00060*CD	May 2011	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.21372	5/25/2011
2PY00060*CD	May 2011	001	31616	Fecal Coliform	1D Conc	2000	4460.	5/25/2011
2PY00060*CD	June 2011	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	13.8	6/1/2011
2PY00060*CD	June 2011	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	16.25	6/1/2011
2PY00060*CD	June 2011	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.25908	6/1/2011
2PY00060*CD	June 2011	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.30588	6/1/2011
2PY00060*CD	June 2011	001	80082	CBOD 5 day	1D Conc	15.0	17.	6/1/2011
2PY00060*CD	June 2011	001	80082	CBOD 5 day	30D Conc	10.0	18.	6/1/2011
2PY00060*CD	June 2011	001	80082	CBOD 5 day	1D Qty	0.28	.31915	6/1/2011
2PY00060*CD	June 2011	001	80082	CBOD 5 day	30D Qty	0.19	.33785	6/1/2011
2PY00060*CD	June 2011	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	18.7	6/8/2011
2PY00060*CD	June 2011	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.35269	6/8/2011
2PY00060*CD	June 2011	001	80082	CBOD 5 day	1D Conc	15.0	24.	6/8/2011
2PY00060*CD	June 2011	001	80082	CBOD 5 day	1D Qty	0.28	.45266	6/8/2011
2PY00060*CD	July 2011	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	14.3033	7/1/2011
2PY00060*CD	July 2011	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.26501	7/1/2011
2PY00060*CD	July 2011	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	26.2	7/5/2011
2PY00060*CD	July 2011	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.48512	7/5/2011
2PY00060*CD	July 2011	001	00300	Dissolved Oxygen	1D Conc	5.0	3.	7/5/2011
2PY00060*CD	July 2011	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	12.9	7/12/2011
2PY00060*CD	July 2011	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.23925	7/12/2011
2PY00060*CD	July 2011	001	00300	Dissolved Oxygen	1D Conc	5.0	3.4	7/12/2011
2PY00060*CD	July 2011	001	00300	Dissolved Oxygen	1D Conc	5.0	2.9	7/20/2011
2PY00060*CD	August 2011	001	00530	Total Suspended Solids	30D Conc	12.0	19.6666	8/1/2011
2PY00060*CD	August 2011	001	00530	Total Suspended Solids	30D Qty	0.228	.36913	8/1/2011
2PY00060*CD	August 2011	001	00610	Nitrogen, Ammonia (NH3	30D Conc	5.0	16.825	8/1/2011
2PY00060*CD	August 2011	001	00610	Nitrogen, Ammonia (NH3	30D Qty	0.09	.31752	8/1/2011
2PY00060*CD	August 2011	001	80082	CBOD 5 day	30D Conc	10.0	18.5	8/1/2011
2PY00060*CD	August 2011	001	80082	CBOD 5 day	30D Qty	0.19	.34392	8/1/2011
2PY00060*CD	August 2011	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	28.9	8/2/2011
2PY00060*CD	August 2011	001	00610	Nitrogen, Ammonia (NH3	1D Qty	0.14	.54551	8/2/2011
2PY00060*CD	August 2011	001	00300	Dissolved Oxygen	1D Conc	5.0	2.4	8/3/2011
2PY00060*CD	August 2011	001	00530	Total Suspended Solids	1D Conc	18.0	22.	8/10/2011
2PY00060*CD	August 2011	001	00530	Total Suspended Solids	1D Qty	0.341	.40761	8/10/2011
2PY00060*CD	August 2011	001	00610	Nitrogen, Ammonia (NH3	1D Conc	7.5	14.4	8/10/2011

2PY00060*CD	August 2011	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.2668	8/10/2011
2PY00060*CD	August 2011	001	80082	CBOD 5 day	1D Conc	15.0	22.	8/10/2011
2PY00060*CD	August 2011	001	80082	CBOD 5 day	1D Qty	0.28	.40761	8/10/2011
2PY00060*CD	August 2011	001	00300	Dissolved Oxygen	1D Conc	5.0	3.1	8/10/2011
2PY00060*CD	August 2011	001	00530	Total Suspended Solids	1D Qty	0.341	.34481	8/17/2011
2PY00060*CD	August 2011	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	7.5	19.8	8/17/2011
2PY00060*CD	August 2011	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.37929	8/17/2011
2PY00060*CD	August 2011	001	00300	Dissolved Oxygen	1D Conc	5.0	2.4	8/17/2011
2PY00060*CD	August 2011	001	00530	Total Suspended Solids	1D Conc	18.0	19.	8/24/2011
2PY00060*CD	August 2011	001	00530	Total Suspended Solids	1D Qty	0.341	.35497	8/24/2011
2PY00060*CD	August 2011	001	80082	CBOD 5 day	1D Qty	0.28	.28024	8/24/2011
2PY00060*CD	September 2011	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	0.09	.10475	9/1/2011
2PY00060*CD	September 2011	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	7.5	17.5	9/1/2011
2PY00060*CD	September 2011	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	5.0	5.5838	9/1/2011
2PY00060*CD	September 2011	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.32874	9/1/2011
2PY00060*CD	September 2011	001	00610	Nitrogen, Ammonia (NH3)	1D Qty	0.14	.15163	9/8/2011
2PY00060*CD	September 2011	001	00610	Nitrogen, Ammonia (NH3)	1D Conc	7.5	8.03	9/8/2011