

Valley Environmental Lab, Inc.

Warren Woods Lead Mapping addendum:

Buildings in Ohio built prior to 1998 or that use plumbing material or solder manufactured before 1998 may have materials with greater than 8% lead and are at a higher risk of contributing lead to the drinking water than materials manufactured after 1998. In addition, buildings built and plumbing materials manufactured after 2014 were required to have less than 0.25% lead by weight and have the lowest risk for contributing lead to the drinking water. It should be noted however that, although prohibited, some use of leaded solder or leaded components may have occurred after the prohibitions became effective.

Edward Mosko, operator

Edward Mosko

RECEIVED  
APR 18 2017  
OHIO EPA NEDO



# ESTIMATE OF WATER LINE DISTRIBUTION

WARREN Woods PWS OH 7801312

