

LEAD AND COPPER SAMPLE SITES:

- ① LC201 - LOT # 130 - LOUIS HEZEBICKS
- ② LC202 - LOT # 112 - BRANDI WARD
- ③ LC203 - LOT # 8 - MARY ANGULO
- ④ LC204 - LOT # 127 - DARREN BRUSH
- ⑤ LC205 - LOT # 16 - JOHN KRAUSE

LEGEND


- NON-LEAD SERVICE CONNECTIONS
- LEAD AND COPPER SAMPLE SITES

NOTES:

AUSTIN MANOR MHP WAS CONSTRUCTED AFTER 1972.
 ALL WATER DISTRIBUTION MAINS ARE AC PIPE OR PVC PIPE.
 ALL WATER SERVICE LINES ARE COPPER TUBING OR HDPE TUBING.

NOTE:

BUILDINGS IN OHIO BUILT PRIOR TO 1998 OR THAT USE PLUMBING MATERIAL OR SOLDER MANUFACTURED BEFORE 1998 MAY HAVE MATERIALS WITH GREATER THAN 8% LEAD AND ARE AT A HIGHER RISK OF CONTRIBUTING LEAD TO THE DRINKING WATER THAN MATERIALS MANUFACTURED AFTER 1998. IN ADDITION, BUILDINGS BUILT AND PLUMBING MATERIALS MANUFACTURED AFTER 2014 WERE REQUIRED TO HAVE LESS THAN 0.25% LEAD BY WEIGHT AND HAVE THE LOWEST RISK FOR CONTRIBUTING LEAD TO THE DRINKING WATER. IT SHOULD BE NOTED HOWEVER THAT, ALTHOUGH PROHIBITED, SOME USE OF LEADED SOLDER OR LEADED COMPONENTS MAY HAVE OCCURRED AFTER THE PROHIBITIONS BECAME EFFECTIVE.



EASEMENT REFERENCE		
City's No.	County Recorder Volume	Page

REVISIONS			
No.	Description	Approval	Date
AS BUILT			

Plans Prepared By :

Aakeever & Associates, Inc.
 P.O. BOX 325, 1810 E. MANSFIELD ST.
 BUCYRUS, OHIO 44820
 Phone: (419) 562-7757 Fax: (419) 562-4717

LEAD MAPPING IN DISTRIBUTION SYSTEM

PWS ID: OH0401512

ENG. FILE NO. _____
 IMP. ACCT. NO. _____
 CONTRACT NO. _____
 COMPLETION DATE _____
 CONTRACTOR _____

AUSTIN MANOR MHP

3583 & 3651 AUSTIN ROAD
GENEVA, OHIO 44041

Scale : Horiz. = AS NOTED
 Vert. = AS NOTED
 Original Sheet Size = 24"x36"
 Original Date : 03/02/2017

Sheet No. : 1 OF 1
 S:\2013\014\007
 Dwg. No. : 2013-014-007