



11/18/2025

Ms. Laura Cottrell
CyrusOne New Albany
2850 N Harwood St
Dallas, TX 75201

RE: FINAL AIR POLLUTION PERMIT-TO-INSTALL AND OPERATE

Facility ID: 0145000619
Permit Number: P0138459
Permit Type: Initial Installation
County: Licking

No	TOXIC REVIEW
Yes	SYNTHETIC MINOR TO AVOID MAJOR NSR
No	CEMS
Yes	MACT/GACT
Yes	NSPS
No	NESHAPS
No	NETTING
Yes	MODELING SUBMITTED
Yes	SYNTHETIC MINOR TO AVOID TITLE V
Yes	FEDERALLY ENFORCABLE PTIO (FEPTIO)
No	SYNTHETIC MINOR TO AVOID MAJOR GHG

Dear Permit Holder:

Enclosed please find a final Ohio Environmental Protection Agency (EPA) Air Pollution Permit-to-Install and Operate (PTIO) which will allow you to install, modify, and/or operate the described emissions unit(s) in the manner indicated in the permit. Because this permit contains conditions and restrictions, please read it very carefully. In this letter, you will find the information on the following topics:

- **Pay any applicable permit fee**
- **How to appeal this permit**
- **How to save money, reduce pollution and reduce energy consumption**
- **How to give us feedback on your permitting experience**
- **How to get an electronic copy of your permit**
- **What should you do if you notice a spill or environmental emergency?**

Pay any applicable permit fee

If there is an enclosed invoice that is associated with this permit action, you must pay the invoice in 30 days. This permit fee supports Ohio EPA's activities to review and issue the necessary approvals for construction or modification of the affected sources. Failure to provide the applicable permit fee within 30 days may result in the accrual of substantial interest penalties. This permit is also conditioned on the payment of any applicable permit fee.

How to appeal this permit

The issuance of this PTIO is a final action of the Director and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of \$70.00, made payable to "Ohio Treasurer Robert Sprague," which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
30 East Broad Street, 4th Floor
Columbus, OH 43215

How to save money, reduce pollution and reduce energy consumption

The Ohio EPA is encouraging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Compliance Assistance and Pollution Prevention at (614) 644-3469. Additionally, all or a portion of the capital expenditures related to installing air pollution control equipment under this permit may be eligible for financing and State tax exemptions through the Ohio Air Quality Development Authority (OAQDA) under Ohio Revised Code Section 3706. For more information, see the OAQDA website: [*Ohio Air Quality Development Authority*](#).

How to give us feedback on your permitting experience

Please complete a survey at [*DAPC - Survey / Ohio Environmental Protection Agency*](#) and give us feedback on your permitting experience. We value your opinion.

How to get an electronic copy of your permit

This permit can be accessed electronically via the eBusiness Center: Air Services in Microsoft Word format or in Adobe PDF on the Ohio EPA document search website here: [*eDocument Search / Ohio Environmental Protection Agency*](#).

What should you do if you notice a spill or environmental emergency?

Any spill or environmental emergency which may endanger human health or the environment should be reported to the Emergency Response 24-HOUR EMERGENCY SPILL HOTLINE toll-free at (800) 282-9378. Report non-emergency complaints to the appropriate district office or local air agency.

If you have any questions regarding your permit, please contact Ohio EPA DAPC, Central Office at (614) 644-2270

Sincerely,



Robert Hodanbosi
Chief, Division of Air Pollution Control

cc:Ohio EPA-CDO

Response to Comments

Facility ID:	0145000619
Facility Name:	CyrusOne New Albany
Facility Description:	CyrusOne
Facility Address:	12181 Jug St New Albany, OH 43054 Licking County
Permit:	P0138459, Permit-To-Install and Operate - Initial Installation
A public notice for the draft permit issuance was published in the Ohio EPA Weekly Review on 10/16/2025. The comment period ended on 11/15/2025.	
Hearing Date (if held):	N/A
Hearing Public Notice Date (if different from draft public notice):	N/A

The following comments were received during the comment period specified. Ohio EPA reviewed and considered all comments received during the public comment period. By law, Ohio EPA has authority to consider specific issues related to protection of the environment and public health. Often, public concerns fall outside the scope of that authority. For example, concerns about zoning issues are addressed at the local level. Ohio EPA may respond to those concerns in this document by identifying another government agency with more direct authority over the issue.

In an effort to help you review this document, the questions are grouped by topic and organized in a consistent format. PDF copies of the original comments in the format submitted are available upon request.

1. **No comments received**



**Environmental
Protection
Agency**

FINAL
Division of Air Pollution Control
Permit-to-Install and Operate
for
CyrusOne New Albany

Facility ID: 0145000619
Permit Number: P0138459
Permit Type: Initial Installation
Issued: 11/18/2025
Effective: 11/18/2025
Expiration: 11/18/2030



**Environmental
Protection
Agency**

Division of Air Pollution Control Permit-to-Install and Operate

for

CyrusOne New Albany

Table of Contents

Response to Comments	3
Authorization	6
List of Commonly Used Abbreviations	28
A. Standard Terms and Conditions	29
B. Facility-Wide Terms and Conditions	34
C. Emissions Unit Terms and Conditions	36
1. Emissions Unit Group - Diesel-Fired Emergency Generators: P001 through P145	37

Authorization

Facility ID: 0145000619
Application Number(s): A0079688
Permit Number: P0138459
Permit Description: Initial install FEPTIO for 145 emergency generators at a data center with federally enforceable limitations on NOx and CO to remain below New Source Review and Title V major source thresholds.
Permit Type: Initial Installation
Permit Fee: \$5,365.00
Issue Date: 11/18/2025
Effective Date: 11/18/2025
Expiration Date: 11/18/2030
Permit Evaluation Report (PER) Jan 1 - Dec 31, Due Feb 15
Annual Date:

This document constitutes issuance of a Permit-to-Install and Operate for the emissions unit(s) identified on the following page to:

CyrusOne New Albany
12181 Jug St
New Albany, OH 43054

Ohio Environmental Protection Agency (EPA) District Office or local air agency responsible for processing and administering your permit:

Ohio EPA DAPC, Central Office
50 West Town St. Suite 700
P.O. Box 1049
Columbus, OH 43216-1049
(614) 644-2270

The above-named entity is hereby granted this Permit-to-Install and Operate for the air contaminant source(s) (emissions unit(s)) listed in this section pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the described emissions unit(s) will operate in compliance with applicable State and federal laws and regulations.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Entered into the Journal of the Director on:



John Logue
Director

Date: 11/18/2025

Authorization (continued)

Permit Number:P0138459

Permit Description:Initial install FEPTIO for 145 emergency generators at a data center with federally enforceable limitations on NOx and CO to remain below New Source Review and Title V major source thresholds.

Permits for the following Emissions Unit(s) or groups of Emissions Units are in this document as indicated below:

Group Name: Emergency Generators

Emissions Unit ID:	P001
Company Equipment ID:	P001
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P002
Company Equipment ID:	P002
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P003
Company Equipment ID:	P003
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P004
Company Equipment ID:	P004
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P005
Company Equipment ID:	P005
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P006
Company Equipment ID:	P006
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P007
Company Equipment ID:	P007

Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P008
Company Equipment ID:	P008
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P009
Company Equipment ID:	P009
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P010
Company Equipment ID:	P010
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P011
Company Equipment ID:	P011
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P012
Company Equipment ID:	P012
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P013
Company Equipment ID:	P013
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P014
Company Equipment ID:	P014
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P015
Company Equipment ID:	P015
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable

Emissions Unit ID:	P016
Company Equipment ID:	P016
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P017
Company Equipment ID:	P017
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P018
Company Equipment ID:	P018
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P019
Company Equipment ID:	P019
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P020
Company Equipment ID:	P020
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P021
Company Equipment ID:	P021
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P022
Company Equipment ID:	P022
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P023
Company Equipment ID:	P023
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P024
Company Equipment ID:	P024

Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P025
Company Equipment ID:	P025
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P026
Company Equipment ID:	P026
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P027
Company Equipment ID:	P027
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P028
Company Equipment ID:	P028
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P029
Company Equipment ID:	P029
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P030
Company Equipment ID:	P030
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P031
Company Equipment ID:	P031
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P032
Company Equipment ID:	P032
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable

Emissions Unit ID:	P033
Company Equipment ID:	P033
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P034
Company Equipment ID:	P034
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P035
Company Equipment ID:	P035
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P036
Company Equipment ID:	P036
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P037
Company Equipment ID:	P037
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P038
Company Equipment ID:	P038
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P039
Company Equipment ID:	P039
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P040
Company Equipment ID:	P040
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P041
Company Equipment ID:	P041

Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P042
Company Equipment ID:	P042
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P043
Company Equipment ID:	P043
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P044
Company Equipment ID:	P044
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P045
Company Equipment ID:	P045
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P046
Company Equipment ID:	P046
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P047
Company Equipment ID:	P047
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P048
Company Equipment ID:	P048
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P049
Company Equipment ID:	P049
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable

Emissions Unit ID:	P050
Company Equipment ID:	P050
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P051
Company Equipment ID:	P051
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P052
Company Equipment ID:	P052
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P053
Company Equipment ID:	P053
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P054
Company Equipment ID:	P054
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P055
Company Equipment ID:	P055
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P056
Company Equipment ID:	P056
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P057
Company Equipment ID:	P057
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P058
Company Equipment ID:	P058

Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P059
Company Equipment ID:	P059
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P060
Company Equipment ID:	P060
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P061
Company Equipment ID:	P061
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P062
Company Equipment ID:	P062
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P063
Company Equipment ID:	P063
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P064
Company Equipment ID:	P064
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P065
Company Equipment ID:	P065
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P066
Company Equipment ID:	P066
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable

Emissions Unit ID:	P067
Company Equipment ID:	P067
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P068
Company Equipment ID:	P068
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P069
Company Equipment ID:	P069
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P070
Company Equipment ID:	P070
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P071
Company Equipment ID:	P071
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P072
Company Equipment ID:	P072
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P073
Company Equipment ID:	P073
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P074
Company Equipment ID:	P074
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P075
Company Equipment ID:	P075

Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P076
Company Equipment ID:	P076
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P077
Company Equipment ID:	P077
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P078
Company Equipment ID:	P078
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P079
Company Equipment ID:	P079
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P080
Company Equipment ID:	P080
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P081
Company Equipment ID:	P081
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P082
Company Equipment ID:	P082
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P083
Company Equipment ID:	P083
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable

Emissions Unit ID:	P084
Company Equipment ID:	P084
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P085
Company Equipment ID:	P085
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P086
Company Equipment ID:	P086
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P087
Company Equipment ID:	P087
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P088
Company Equipment ID:	P088
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P089
Company Equipment ID:	P089
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P090
Company Equipment ID:	P090
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P091
Company Equipment ID:	P091
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P092
Company Equipment ID:	P092

Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P093
Company Equipment ID:	P093
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P094
Company Equipment ID:	P094
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P095
Company Equipment ID:	P095
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P096
Company Equipment ID:	P096
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P097
Company Equipment ID:	P097
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P098
Company Equipment ID:	P098
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P099
Company Equipment ID:	P099
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P100
Company Equipment ID:	P100
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable

Emissions Unit ID:	P101
Company Equipment ID:	P101
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P102
Company Equipment ID:	P102
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P103
Company Equipment ID:	P103
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P104
Company Equipment ID:	P104
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P105
Company Equipment ID:	P105
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P106
Company Equipment ID:	P106
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P107
Company Equipment ID:	P107
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P108
Company Equipment ID:	P108
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P109
Company Equipment ID:	P109

Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P110
Company Equipment ID:	P110
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P111
Company Equipment ID:	P111
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P112
Company Equipment ID:	P112
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P113
Company Equipment ID:	P113
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P114
Company Equipment ID:	P114
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P115
Company Equipment ID:	P115
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P116
Company Equipment ID:	P116
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P117
Company Equipment ID:	P117
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable

Emissions Unit ID:	P118
Company Equipment ID:	P118
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P119
Company Equipment ID:	P119
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P120
Company Equipment ID:	P120
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P121
Company Equipment ID:	P121
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P122
Company Equipment ID:	P122
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P123
Company Equipment ID:	P123
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P124
Company Equipment ID:	P124
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P125
Company Equipment ID:	P125
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P126
Company Equipment ID:	P126

Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P127
Company Equipment ID:	P127
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P128
Company Equipment ID:	P128
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P129
Company Equipment ID:	P129
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P130
Company Equipment ID:	P130
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P131
Company Equipment ID:	P131
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P132
Company Equipment ID:	P132
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P133
Company Equipment ID:	P133
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P134
Company Equipment ID:	P134
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable

Emissions Unit ID:	P135
Company Equipment ID:	P135
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P136
Company Equipment ID:	P136
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P137
Company Equipment ID:	P137
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P138
Company Equipment ID:	P138
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P139
Company Equipment ID:	P139
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P140
Company Equipment ID:	P140
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P141
Company Equipment ID:	P141
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P142
Company Equipment ID:	P142
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P143
Company Equipment ID:	P143

Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P144
Company Equipment ID:	P144
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P145
Company Equipment ID:	P145
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable

List of Commonly Used Abbreviations

AP-42 = U.S. EPA's Compilation of Air Pollution Emissions Factors	HVLP = high volume, low pressure	PER = Permit Evaluation Report
ASTM = American Society for Testing and Materials	LAER = lowest achievable emission rate	PM = particulate matter
BACT = Best Available Control Technology	lb(s)/hr = pound(s) per hour	PM ₁₀ = particulate matter with an aerodynamic diameter less than or equal to 10 microns
BAT = Best Available Technology	LDAR = leak detection and repair	PM _{2.5} = particulate matter with an aerodynamic diameter less than or equal to 2.5 microns
CAA = Clean Air Act	LPG = liquefied petroleum gas/propane	ppb = parts per billion
CAM = compliance assurance monitoring	MACT = maximum achievable control technology	ppm = parts per million
CEMS = continuous emissions monitoring system	MAGLC = maximum acceptable ground level concentration	PSD = Prevention of Significant Deterioration
CFC = chlorofluorocarbon	mg/m ³ = milligrams per cubic meter	psi = pounds per square inch
CFR = Code of Federal Regulations	MM = million	psia = pounds per square inch absolute
CH ₄ = methane	MMBtu = million British Thermal Units	PTE = potential-to-emit
CI = compression ignition	MSDS = material safety data sheet	PTI = Permit-to-Install
CO = carbon monoxide	MSW = municipal solid waste	PTIO = Permit-to-Install and Operate
CO ₂ = carbon dioxide	NAAQS = National Ambient Air Quality Standard	PTO = Permit-to-Operate
COM = continuous opacity monitor	NESHAP = National Emission Standard for Hazardous Air Pollutants	PWR = process weight rate
DAPC = Division of Air Pollution Control	NG = natural gas	RACM = reasonably available control measures
DO/LAA = District Office/Local Air Agency	ng/m ³ = nanograms per cubic meter	RACT = reasonably available control technology
dscf = dry standard cubic foot	NH ₃ = ammonia	RATA = relative accuracy test audit
EAC = emissions activity category	NMHC = non-methane hydrocarbons	RTO = regenerative thermal oxidizer
eDocs = electronic documents database	NMOC = non-methane organic compound	SB265 = Senate Bill 265
ERAC = Environmental Review Appeals Commission	NO = nitrogen oxide	scfm = standard cubic feet per minute
ESP = electrostatic precipitator	NO ₂ = nitrogen dioxide	SI = spark ignition
EU = emissions unit	NO _x = nitrogen oxides	SIP = State Implementation Plan
FEPTIO = Federally Enforceable Permit-to-Install and Operate	NSPS = New Source Performance Standard	SO ₂ = sulfur dioxide
FER = Fee Emissions Report	NSR = New Source Review	SSMP = startup, shutdown, and malfunction plan
FR = Federal Register	NTV = Non-Title V	TDS = total dissolved solids
GACT = generally achievable control technology	O&M = operation and maintenance	TLV = threshold limit value
GHG = greenhouse gases	OAC = Ohio Administrative Code	TO = thermal oxidizer
gr/dscf = grains per dry standard cubic foot	OC = organic compound	TPH = ton(s) per hour
H ₂ S = hydrogen sulfide	Ohio EPA = Ohio Environmental Protection Agency	TPY = ton(s) per year
H ₂ SO ₄ = sulfuric acid	ORC = Ohio Revised Code	TSP = total suspended particulates
HAP = hazardous air pollutant	Pb = lead	VE = visible emissions
HCl = hydrogen chloride	PBR = Permit-By-Rule	VMT = vehicle miles traveled
HF = hydrogen fluoride	PCB = polychlorinated biphenyl	VOC = volatile organic compound
Hg = mercury	PE = particulate emissions	WPP = work practice plan
hp = horsepower	PEMS = predictive emissions monitoring system	µg/m ³ = micrograms per cubic meter

A. Standard Terms and Conditions

1. What does this permit-to-install and operate (PTIO) allow me to do?

This permit allows you to install and operate the emissions unit(s) identified in this PTIO. You must install and operate the unit(s) in accordance with the application you submitted and all the terms and conditions contained in this PTIO, including emission limits and those terms that ensure compliance with the emission limits (for example, operating, recordkeeping and monitoring requirements).

2. Who is responsible for complying with this permit?

The person identified on the "Authorization" page, above, is responsible for complying with this permit until the permit is revoked, terminated, or transferred. "Person" means a person, firm, corporation, association, or partnership. The words "you," "your," or "permittee" refer to the "person" identified on the "Authorization" page above.

The permit applies only to the emissions unit(s) identified in the permit. If you install or modify any other equipment that requires an air permit, you must apply for an additional PTIO(s) for these sources.

3. What records must I keep under this permit?

You must keep all records required by this permit, including monitoring data, test results, strip-chart recordings, calibration data, maintenance records, and any other record required by this permit for five years from the date the record was created. You can keep these records electronically, provided they can be made available to Ohio EPA during an inspection at the facility. Failure to make requested records available to Ohio EPA upon request is a violation of this permit requirement.

4. What are my permit fees and when do I pay them?

There are two fees associated with permitted air contaminant sources in Ohio:

- a) PTIO fee. This one-time fee is based on a fee schedule in accordance with Ohio Revised Code (ORC) section 3745.11 or based on a time and materials charge for permit application review and permit processing if required by the Director.

You will be sent an invoice for this fee after you receive this PTIO and payment is due within 30 days of the invoice date. You are required to pay the fee for this PTIO even if you do not install or modify your operations as authorized by this permit.

- b) Annual emissions fee. Ohio EPA will assess a separate fee based on the total annual emissions from your facility. You self-report your emissions in accordance with Ohio Administrative Code (OAC) Chapter 3745-78. This fee assessed is based on a fee schedule in ORC section 3745.11 and funds Ohio EPA's permit compliance oversight activities. For facilities that are permitted as synthetic minor sources, the fee schedule is adjusted annually for inflation. Ohio EPA will notify you when it is time to report your emissions and to pay your annual emission fees.

5. When does my PTIO expire, and when do I need to submit my renewal application?

This permit expires on the date identified at the beginning of this permit document (see "Authorization" page above) and you must submit a renewal application to renew the permit. Ohio EPA will send a renewal notice to you approximately six months prior to the expiration date of this permit. However, it is very important that you submit a complete renewal permit application (either electronically through Ohio EPA's eBusiness Center: Air Services web service or postmarked prior to expiration of this permit) even if you do not receive the renewal notice.

If a complete renewal application is submitted before the expiration date, Ohio EPA considers this a timely application for purposes of ORC section 119.06, and you are authorized to continue operating the emissions unit(s) covered by this permit beyond the expiration date of this permit until final action is taken by Ohio EPA on the renewal application.

6. What happens to this permit if my project is delayed or I do not install or modify my source?

This PTIO expires 18 months after the issue date identified on the "Authorization" page above unless otherwise specified if you have not (1) started constructing the new or modified emission sources identified in this permit, or (2) entered into a binding contract to undertake such construction. This deadline can be extended once by 12 months, provided you apply to Ohio EPA for this extension within a reasonable time before the 18-month period has ended and you can show good cause for any such extension.

7. What reports must I submit under this permit?

An annual permit evaluation report (PER) is required in addition to any malfunction reporting required by OAC rule 3745-15-06 or other specific rule-based reporting requirement identified in this permit. Your PER due date is identified in the Authorization section of this permit.

8. If I am required to obtain a Title V operating permit in the future, what happens to the operating provisions and permit evaluation report (PER) obligations under this permit?

If you are required to obtain a Title V permit under OAC Chapter 3745-77 in the future, the permit-to-operate portion of this permit will be superseded by the issued Title V permit. From the effective date of the Title V permit forward, this PTIO will effectively become a PTI (permit-to-install) in accordance with OAC rule 3745-31-02(B). The following terms and conditions of this permit will no longer be applicable after issuance of the Title V permit: Section B, Term 1.b) and Section C, for each emissions unit, Term a)(2).

The PER requirements in this permit remain effective until the date the Title V permit is issued and is effective and cease to apply after the effective date of the Title V permit. The final PER obligation will cover operations up to the effective date of the Title V permit and must be submitted on or before the submission deadline identified in this permit on the last day prior to the effective date of the Title V permit.

9. What are my obligations when I perform scheduled maintenance on air pollution control equipment?

You must perform scheduled maintenance of air pollution control equipment in accordance with OAC rule 3745-15-06(A). If scheduled maintenance requires shutting down or bypassing any air pollution control equipment, you must also shut down the emissions unit(s) served by the air pollution control equipment during maintenance, unless the conditions of OAC rule 3745-15-06(A)(3) are met. Any emissions that exceed permitted amount(s) under this permit (unless specifically exempted by rule) must be reported as deviations in the annual permit evaluation report (PER), including nonexempt excess emissions that occur during approved scheduled maintenance.

10. Do I have to report malfunctions of emissions units or air pollution control equipment? If so, how must I report?

If you have a reportable malfunction of any emissions unit(s) or any associated air pollution control system, you must report this to the Ohio EPA DAPC, Central Office in accordance with OAC rule 3745-15-06(B). Malfunctions that must be reported are those that result in emissions that exceed permitted emission levels. It is your responsibility to evaluate control equipment breakdowns and operational upsets to determine if a reportable malfunction has occurred.

If you have a malfunction but determine that it is not a reportable malfunction under OAC rule 3745-15-06(B), it is recommended that you maintain records associated with control equipment breakdown or process upsets. Although it is not a requirement of this permit, Ohio EPA recommends that you maintain records for non-reportable malfunctions.

11. Can Ohio EPA or my local air agency inspect the facility where the emission unit(s) is/are located?

Yes. Under Ohio law, the Director or his/her authorized representative may inspect the facility, conduct tests, examine records or reports to determine compliance with air pollution laws and regulations and the terms and conditions of this permit. You must provide, within a reasonable time, any information Ohio EPA requests either verbally or in writing.

12. What happens if one or more emissions units operated under this permit is/are shut down permanently?

Ohio EPA can terminate the permit terms associated with any permanently shut down emissions unit. "Shut down" means the emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31.

You should notify Ohio EPA of any emissions unit that is permanently shut down by submitting a certification that identifies the date on which the emissions unit was permanently shut down. The certification must be submitted by an authorized official from the facility. You cannot continue to operate an emission unit once the certification has been submitted to Ohio EPA by the authorized official.

You must comply with all recordkeeping and reporting for any permanently shut down emissions unit in accordance with the provisions of the permit, regulations or laws that were enforceable during the period of operation, such as the requirement to submit a PER, air fee emission report, or malfunction report. You must also keep all records relating to any permanently shut down emissions unit, generated while the emissions unit was in operation, for at least five years from the date the record was generated.

Again, you cannot resume operation of any emissions unit certified by the authorized official as being permanently shut down without first applying for and obtaining a permit pursuant to OAC Chapter 3745-31.

13. Can I transfer this permit to a new owner or operator?

You can transfer this permit to a new owner or operator. If you transfer the permit, the new owner or operator must follow the procedures in OAC Chapter 3745-31-07, including notifying Ohio EPA or the local air agency of the change in ownership or operator within thirty days of the transfer date. Any transferee of this permit shall assume the responsibilities of the transferor permit holder.

14. Does compliance with this permit constitute compliance with OAC rule 3745-15-07, "air pollution nuisance"?

This permit and OAC rule 3745-15-07 prohibit operation of the air contaminant source(s) regulated under this permit in a manner that causes a nuisance. Ohio EPA can require additional controls or modification of the requirements of this permit through enforcement orders or judicial enforcement action if, upon investigation, Ohio EPA determines existing operations are causing a nuisance.

15. What happens if a portion of this permit is determined to be invalid?

If a portion of this permit is determined to be invalid, the remainder of the terms and conditions remain valid and enforceable. The exception is where the enforceability of terms and conditions are dependent on the term or condition that was declared invalid.



**Environmental
Protection
Agency**

Final Permit-to-Install and Operate

CyrusOne New Albany

Permit Number: P0138459

Facility ID: 0145000619

Effective Date: 11/18/2025

B. Facility-Wide Terms and Conditions

1. This permit document constitutes a PTI issued in accordance with ORC 3704.03(F) and a PTO issued in accordance with ORC 3704.03(G).
 - a) For the purpose of a PTI document, the facility-wide T&C identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
 - (1) None.
 - b) For the purpose of a PTO document, the facility-wide T&C identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
 - (1) None.
2. The Ohio EPA has determined that this facility operates affected sources that are subject to the requirements of 40 CFR Part 63, Subpart ZZZZ, the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines. Ohio EPA is not accepting the delegation authority to implement and enforce the area source requirements of this NESHAP standard. The area source requirements of this NESHAP standard are implemented and enforced by U.S. EPA, Region 5. The promulgated version of this NESHAP standard and the 40 CFR Part 63, General Provisions may be accessed via the Internet from the Electronic Code of Federal Regulations (e-CFR) website <http://www.ecfr.gov/> or by contacting the Ohio EPA, District Office or Local Air Agency.
3. All applications, notifications or reports required by terms and conditions in this permit to be submitted or "reported in writing" are to be submitted to Ohio EPA through the Ohio EPA's eBusiness Center: Air Services web service ("Air Services"). Ohio EPA will accept hard copy submittals on an as-needed basis if the permittee cannot submit the required documents through the Ohio EPA eBusiness Center. In the event of an alternative hard copy submission in lieu of the eBusiness Center, the post-marked date or the date the document is delivered in person will be recognized as the date submitted. Electronic submission of applications, notifications, or reports required to be submitted to Ohio EPA fulfills the requirement to submit the required information to the Director, the District Office or Local Air Agency, and/or any other individual or organization specifically identified as an additional recipient identified in this permit unless otherwise specified. Consistent with OAC rule 3745-15-03, the required application, notification or report is considered to be "submitted" on the date the submission is successful using a valid electronic signature. Signature by the signatory authority may be represented as provided through procedures established in Air Services.

C. Emissions Unit Terms and Conditions

1. Emissions Unit Group - Diesel-Fired Emergency Generators: P001 through P145

EU ID	Operations, Property and/or Equipment Description
P001-P014, P016-P029, P030-P043, P045-P058, P059-P072, P074-P087, P088-P101, P117-P130, and P132-P145	2.25MW Diesel-Fired Emergency Generator
P015, P044, P073, P102, and P131	1.5MW Diesel-Fired Emergency Generator

- a) This permit document constitutes a PTI issued in accordance with ORC 3704.03(F) and a PTO issued in accordance with ORC 3704.03(G).
- (1) For the purpose of a PTI document, the EU T&C identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
- a. None.
- (2) For the purposes of a PTO document, the EU T&C identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
- a. b)(1)f., c)(2), d)(6), e)(3), and f)(1)d.
- b) Applicable Emissions Limitations and/or Control Requirements
- (1) The specific operation(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures are identified below. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-17-07(A)	Visible particulate emissions from the stack serving this emissions unit shall not exceed 20 percent opacity as a six-minute average, except as provided by rule.
b.	OAC rule 3745-17-11(B)(5)(b)	Particulate emissions from the engine's exhaust shall not exceed 0.062 lb/MMBtu actual heat input.
c.	OAC rule 3745-18-06(G)	SO ₂ emissions shall not exceed 0.5 lb/MMBtu actual heat input.
d.	OAC rule 3745-31-05(A)(3) [BAT for NO _x]	The emissions unit shall meet the standards established for NO _x emissions in 40 CFR Part 60, Subpart IIII. See b)(1)h. and b)(2)a. through b)(2)c. below.
e.	OAC rule 3745-31-05(A)(3)(a)(ii)	The BAT requirements under OAC rule 3745-31-05(A)(3) do not apply to the CO, VOC, PM ₁₀ , PM _{2.5} and SO ₂ emissions from this air contaminant source since the potentials to emit are less than 10 tons per year.



f.	OAC rule 3745-31-05(D) [Federally enforceable limitations to avoid Title V and NSR]	The NO _x emissions from emissions units P001 through P145 combined shall not exceed 99.0 tons per rolling, 12-month period. The CO emissions from emissions units P001 through P145 combined shall not exceed 49.6 tons per rolling, 12-month period.
g.	OAC rule 3745-110-03	See b)(2)e. below.
h.	40 CFR Part 60, Subpart IIII 40 CFR 60.4202(b)(2) 40 CFR 60.4205(b) 40 CFR 60.4207(b) 40 CFR Part 1039, Appendix I, Tier 2 40 CFR 1039.105	The emissions unit shall be certified to meet the following emissions standards: 0.20 grams PM/kW-hr; 6.4 grams NO _x + NMHC/kW-hr; 3.5 grams CO/kW-hr; 20 percent opacity during the acceleration mode; 15 percent opacity during the lugging mode; and 50 percent opacity during the peaks in either the acceleration or lugging modes. See b)(2)a. through b)(2)d. and c)(1) below.
i.	40 CFR Part 60, Subpart A	Table 8 to 40 CFR Part 60, Subpart IIII- "Applicability of General Provisions to Subpart IIII" identifies which parts of the General Provisions in 40 CFR Part 60.1-19 apply.

(2) Additional Terms and Conditions

- a. The emergency stationary compression ignition (CI) internal combustion engine (ICE) is subject to and shall be operated in compliance with the requirements of 40 CFR Part 60, Subpart IIII, the standards of performance for stationary CI ICE.
- b. The emergency stationary CI ICE has been or shall be purchased certified by the manufacturer to emission standards as stringent as those identified in 40 CFR 60.4202(b)(2), including the Tier 2 standards in 40 CFR 1039, Appendix I for engines greater than or equal to 750 horsepower (560 kilowatt) and the smoke standards as specified in 40 CFR 1039.105.
- c. The emergency stationary ICE must comply with the applicable requirements specified in 40 CFR 60.4211(f) in order to be considered an emergency stationary ICE under Part 60, Subpart IIII.
- d. The emergency stationary CI ICE shall burn only ultra-low sulfur diesel (ULSD) that meets the following per-gallon standards:
 - i. A maximum sulfur content of 15 ppm (0.0015% sulfur by weight); and
 - ii. A cetane index or aromatic contents, as follows:

- (a) A minimum cetane index of 40; or
 - (b) A maximum aromatic content of 35 volume percent.
- e. For the purpose of meeting the exemption in OAC rule 3745-110-03(K)(2), the emergency stationary CI ICE shall not be operated in any consecutive 12-month period to equal or exceed 500 hours of operation. If the engine operation equals or exceeds 500 hours during any consecutive 12-month period, the NO_x emissions shall not exceed 3.0 g/hp-hr; and the permittee shall demonstrate compliance in accordance with OAC 3745-110-03(H) and OAC rule 3745-110-05.
- c) **Operational Restrictions**
- (1) The emergency stationary CI ICE shall be installed, operated, and maintained according to the manufacturer's emission-related written instructions and the permittee shall only change those emission-related settings that are allowed by the manufacturer. The CI ICE must also be installed and operated to meet the applicable requirements from 40 CFR Part 60, Subpart IIII; 40 CFR Part 1039, Control of Emissions from New and In-use Nonroad CI Engines; and 40 CFR Part 1068, the General Compliance Provisions for Highway, Stationary, and Nonroad Programs. The permittee shall operate and maintain the stationary CI ICE to achieve the emissions standards established in 40 CFR 60.4205 over the entire life of the engine.
 - (2) The maximum ULSD fuel usage for emissions units P001 through P145 shall be limited by the following formulas for each rolling, 12-month period:

$$99.0 \text{ tons of NO}_x \geq \sum_{i=P001}^{P145} \left[\frac{(\text{NO}_x \text{ EF}_i)(Q_i)}{2,000 \frac{\text{lb}}{\text{ton}}} \right]$$

and

$$49.6 \text{ tons of CO} \geq \sum_{i=P001}^{P145} \left[\frac{(\text{CO EF}_i)(Q_i)}{2,000 \frac{\text{lb}}{\text{ton}}} \right]$$

where:

i = each individual emissions unit, including P001 through P145

$\text{NO}_x \text{ EF}_i$ = the NO_x emissions factor, in lb/gal, for each emissions unit, i , as provided in Table 1 below based on the manufacturer's design specifications in the permit application

Table 1: NO_x Emissions Factors

Emissions Units	NO _x Emissions Factor (lb/gal)
P001-P014, P016-P029, P030-P043, P045-P058, P059-P072, P074-P087, P088-P101, P117-P130, and P132-P145	0.329

P015, P044, P073, P102, and P131	0.427
----------------------------------	-------

Q_i = the number of gallons of ULSD fuel used by each emission unit, i , during the rolling, 12-month period

$CO\ EF_i$ = the CO emissions factor, in lb/gal, for each emissions unit, i , as provided in Table 2 below based on the manufacturer's design specifications in the permit application

Table 2: CO Emissions Factors

Emissions Units	CO Emissions Factor (lb/gal)
P001-P014, P016-P029, P030-P043, P045-P058, P059-P072, P074-P087, P088-P101, P117-P130, and P132-P145	0.171
P015, P044, P073, P102, and P131	0.0794

d) **Monitoring and/or Recordkeeping Requirements**

- (1) The permittee shall maintain the manufacturer's certification, to the applicable Tier 2 emission standards in 40 CFR 1039, Appendix I, on site or at a central location for all facility ICE and it shall be made available for review upon request. If the manufacturer's certification is not kept on site, the permittee shall maintain a log for the location of each ICE and it shall identify the agency-assigned emissions unit number, the manufacturer's identification number, and the identification number of the certificate. The manufacturer's operations manual and any written instructions or procedures developed by the permittee and approved by the manufacturer shall be maintained at the same location as the ICE.
- (2) The permittee shall maintain documents provided by the oil supplier for each shipment of fuel oil to demonstrate compliance with the ULSD requirement. These documents must include the receipt or bill of lading that includes confirmation that the fuel meets the ULSD standard.
- (3) For each day during which the permittee burns a fuel other than ULSD, the permittee shall maintain a record of the type, percent sulfur content, and quantity of fuel burned in this emissions unit.
- (4) The emergency stationary CI ICE shall be installed with a non-resettable hour meter prior to startup of the engine.
- (5) The permittee shall maintain monthly records of the following information:
 - a. the total number of hours the engine was in operation;
 - b. the number of hours spent in emergency operation;
 - c. what classified the operation as an emergency;
 - d. the number of hours spent in non-emergency operation;
 - e. the number of hours in maintenance checks and readiness testing; and



- f. the rolling, 12-month summation of the number of hours the engine was in operation.
- (6) The permittee shall maintain monthly records of the following information for emissions units P001 through P145:
 - a. the number of gallons of ULSD fuel used by each emissions units for P001 through P145;
 - b. the rolling, 12-month summation of NO_x emissions from emissions units from P001 through P145, combined, in tons; and
 - c. the rolling, 12-month summation of CO emissions from emissions units from P001 through P145, combined, in tons.

The NO_x and CO emissions from emissions units P001 through P145 shall be calculated using NO_x and CO emissions factors based on the manufacturer's technical specifications. The emissions factors that shall be used for emissions units P001 through P145 are specified in Tables 1 and 2 in c)(2) above.

e) Reporting Requirements

- (1) The permittee shall submit to Ohio EPA, DO/LAA a revised EAC form that identifies the serial number for the engine within 30 days after placement on its concrete pad.
- (2) The permittee shall submit an annual PER to Ohio EPA by the due date identified in the Authorization section of this permit. The PER shall cover a reporting period of no more than 12 months for each air contaminant source identified in this permit.
- (3) The permittee shall submit quarterly deviation (excursion) reports that identify:
 - a. all deviations (excursions) of the following emission limitations, operational restrictions and/or control device operating parameter limitations that restrict the PTE of any regulated air pollutant and have been detected by the monitoring, recordkeeping and/or testing requirements in this permit:
 - i. all exceedances of the rolling, 12-month ULSD fuel usage limitation specified in c)(2) above;
 - ii. all exceedances of the rolling, 12-month NO_x emissions limitation; and
 - iii. all exceedances of the rolling, 12-month CO emissions limitation.
 - b. the probable cause of each deviation (excursion);
 - c. any corrective actions that were taken to remedy the deviations (excursions) or prevent future deviations (excursions); and
 - d. the magnitude and duration of each deviation (excursion).

If no deviations (excursions) occurred during a calendar quarter, the permittee shall submit a report that states that no deviations (excursions) occurred during the quarter.

The quarterly reports shall be submitted each year by January 31 (covering October to December), April 30 (covering January to March), July 31 (covering April to June), and October 31 (covering July to September), unless an alternative schedule has been established and approved by the director (Ohio EPA, DO/LAA).

f) Testing Requirements



- (1) Compliance with the Emissions Limitations and/or Control Requirements specified in section b) of these terms and conditions shall be determined in accordance with the following methods:

a. Emissions Limitation

Visible particulate emissions from the stack serving this emissions unit shall not exceed 20% opacity as a 6-minute average, except as specified by rule.

Applicable Compliance Method

If required, compliance with the stack visible particulate emissions limitation shall be determined through visible emissions observations performed in accordance with U.S. EPA Reference Method 9 in 40 CFR Part 60, Appendix A.

b. Emissions Limitation

Particulate emissions from the engine's exhaust shall not exceed 0.062 lb/MMBtu actual heat input.

Applicable Compliance Method

Compliance shall be determined based on the manufacturer's specification sheet.

If required, the permittee shall demonstrate compliance with this emission limitation in accordance with the methods and procedures specified in OAC rule 3745-17-03(B)(10).



c. Emissions Limitation

SO₂ emissions shall not exceed 0.5 lb/MMBtu actual heat input.

Applicable Compliance Method

Compliance shall be determined using documents required in d)(2) above. Emissions of SO₂ shall be calculated in accordance with OAC rule 3745-18-04(F)(2) using the maximum fuel sulfur content of 15 ppm.

d. Emissions Limitations

NO_x emissions from emissions units P001 through P145, combined, shall not exceed 99.0 tons per rolling, 12-month period.

CO emissions from emissions units P001 through P145, combined, shall not exceed 49.6 tons per rolling, 12-month period.

Applicable Compliance Method

Compliance with these emissions limitations shall be determined in accordance with the recordkeeping specified in d)(6) above.

e. Emissions Limitations

The emissions unit shall be certified to meet the following emissions standards:

0.20 grams PM/kW-hr;

6.4 grams NO_x + NMHC/kW-hr; and

3.5 grams CO/kW-hr;

20 percent opacity during the acceleration mode;

15 percent opacity during the lugging mode; and

50 percent opacity during the peaks in either the acceleration or lugging modes.

Applicable Compliance Method

Compliance with the emissions limitations shall be based on the manufacturer's certification and by maintaining the engine according to the manufacturer's instructions.

g) Miscellaneous Requirements

(1) None.