



12/10/2025

Jonathan Wray
Cologix - COL 5
585 Scherers Ct
Columbus, OH 43085

RE: FINAL AIR POLLUTION PERMIT-TO-INSTALL AND OPERATE

Facility ID: 0121000483
Permit Number: P0138685
Permit Type: Initial Installation
County: Delaware

No	TOXIC REVIEW
No	SYNTHETIC MINOR TO AVOID MAJOR NSR
No	CEMS
Yes	MACT/GACT
Yes	NSPS
No	NESHAPS
No	NETTING
No	MODELING SUBMITTED
Yes	SYNTHETIC MINOR TO AVOID TITLE V
Yes	FEDERALLY ENFORCABLE PTIO (FEPTIO)
No	SYNTHETIC MINOR TO AVOID MAJOR GHG

Dear Permit Holder:

Enclosed please find a final Ohio Environmental Protection Agency (EPA) Air Pollution Permit-to-Install and Operate (PTIO) which will allow you to install, modify, and/or operate the described emissions unit(s) in the manner indicated in the permit. Because this permit contains conditions and restrictions, please read it very carefully. In this letter, you will find the information on the following topics:

- **Pay any applicable permit fee**
- **How to appeal this permit**
- **How to save money, reduce pollution and reduce energy consumption**
- **How to give us feedback on your permitting experience**
- **How to get an electronic copy of your permit**
- **What should you do if you notice a spill or environmental emergency?**

Pay any applicable permit fee

If there is an enclosed invoice that is associated with this permit action, you must pay the invoice in 30 days. This permit fee supports Ohio EPA's activities to review and issue the necessary approvals for construction or modification of the affected sources. Failure to provide the applicable permit fee within 30 days may result in the accrual of substantial interest penalties. This permit is also conditioned on the payment of any applicable permit fee.

How to appeal this permit

The issuance of this PTIO is a final action of the Director and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of \$70.00, made payable to "Ohio Treasurer Robert Sprague," which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
30 East Broad Street, 4th Floor
Columbus, OH 43215

How to save money, reduce pollution and reduce energy consumption

The Ohio EPA is encouraging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Compliance Assistance and Pollution Prevention at (614) 644-3469. Additionally, all or a portion of the capital expenditures related to installing air pollution control equipment under this permit may be eligible for financing and State tax exemptions through the Ohio Air Quality Development Authority (OAQDA) under Ohio Revised Code Section 3706. For more information, see the OAQDA website: [*Ohio Air Quality Development Authority*](#).

How to give us feedback on your permitting experience

Please complete a survey at [*DAPC - Survey / Ohio Environmental Protection Agency*](#) and give us feedback on your permitting experience. We value your opinion.

How to get an electronic copy of your permit

This permit can be accessed electronically via the eBusiness Center: Air Services in Microsoft Word format or in Adobe PDF on the Ohio EPA document search website here: [*eDocument Search / Ohio Environmental Protection Agency*](#).

What should you do if you notice a spill or environmental emergency?

Any spill or environmental emergency which may endanger human health or the environment should be reported to the Emergency Response 24-HOUR EMERGENCY SPILL HOTLINE toll-free at (800) 282-9378. Report non-emergency complaints to the appropriate district office or local air agency.

If you have any questions regarding your permit, please contact Ohio EPA DAPC, Central Office at (614) 644-2270.

Sincerely,



Robert Hodanbosi
Chief, Division of Air Pollution Control

cc: Ohio EPA-CDO

Response to Comments

Facility ID:	0121000483
Facility Name:	Cologix - COL 5
Facility Description:	Data Center
Facility Address:	6787 Green Meadows Dr Lewis Center, OH 43035 Delaware County
Permit:	P0138685, Permit-To-Install and Operate - Initial Installation
A public notice for the draft permit issuance was published in the Ohio EPA Weekly Review on 11/06/2025. The comment period ended on 12/06/2025.	
Hearing Date (if held):	
Hearing Public Notice Date (if different from draft public notice):	No comments received.

The following comments were received during the comment period specified. Ohio EPA reviewed and considered all comments received during the public comment period. By law, Ohio EPA has authority to consider specific issues related to protection of the environment and public health. Often, public concerns fall outside the scope of that authority. For example, concerns about zoning issues are addressed at the local level. Ohio EPA may respond to those concerns in this document by identifying another government agency with more direct authority over the issue.

In an effort to help you review this document, the questions are grouped by topic and organized in a consistent format. PDF copies of the original comments in the format submitted are available upon request.

1. Topic: None

- a) Comment: No comments received.
- b) Response: NA



**Environmental
Protection
Agency**

FINAL
Division of Air Pollution Control
Permit-to-Install and Operate
for
Cologix - COL 5

Facility ID: 0121000483
Permit Number: P0138685
Permit Type: Initial Installation
Issued: 12/10/2025
Effective: 12/10/2025
Expiration: 12/10/2030



**Environmental
Protection
Agency**

**Division of Air Pollution Control
Permit-to-Install and Operate**

for
Cologix - COL 5

Table of Contents

Authorization	6
List of Commonly Used Abbreviations	10
A. Standard Terms and Conditions	11
B. Facility-Wide Terms and Conditions	16
C. Emissions Unit Terms and Conditions	18
1. Emissions Unit Group - Emergency Generators: P001, P002, P003, P004, P005, P006, P007, P008, P009, P010, P011, P012, P013, P014 and P015	19

Authorization

Facility ID: 0121000483
Application Number(s): A0079551
Permit Number: P0138685
Permit Description: Initial permit to install and operate for fifteen, diesel-fired 2500 KW emergency generators.
Permit Type: Initial Installation
Permit Fee: \$555.00
Issue Date: 12/10/2025
Effective Date: 12/10/2025
Expiration Date: 12/10/2030
Permit Evaluation Report (PER) Annual Jan 1 - Dec 31, Due Feb 15
Date:

This document constitutes issuance of a Permit-to-Install and Operate for the emissions unit(s) identified on the following page to:

Cologix - COL 5
6787 Green Meadows Dr
Lewis Center, OH 43035

Ohio Environmental Protection Agency (EPA) District Office or local air agency responsible for processing and administering your permit:

Ohio EPA DAPC, Central Office
50 West Town St. Suite 700
P.O. Box 1049
Columbus, OH 43216-1049
(614) 644-2270

The above-named entity is hereby granted this Permit-to-Install and Operate for the air contaminant source(s) (emissions unit(s)) listed in this section pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the described emissions unit(s) will operate in compliance with applicable State and federal laws and regulations.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Entered into the Journal of the Director on:



John Logue
Director

Date: 12/10/2025

Authorization (continued)

Permit Number: P0138685

Permit Description: Initial permit to install and operate for fifteen, diesel-fired 2500 KW emergency generators.

Permits for the following Emissions Unit(s) or groups of Emissions Units are in this document as indicated below:

Group Name: Emergency Generators

Emissions Unit ID:	P001
Company Equipment ID:	GEN-A1
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P002
Company Equipment ID:	GEN-B1
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P003
Company Equipment ID:	GEN-C1
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P004
Company Equipment ID:	GEN-D1
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P005
Company Equipment ID:	GEN-E1
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P006
Company Equipment ID:	GEN-F1
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P007
Company Equipment ID:	GEN-G1

Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P008
Company Equipment ID:	GEN-H1
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P009
Company Equipment ID:	GEN-R1
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P010
Company Equipment ID:	GEN-A2
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P011
Company Equipment ID:	GEN-B2
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P012
Company Equipment ID:	GEN-C2
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P013
Company Equipment ID:	GEN-D2
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P014
Company Equipment ID:	GEN-R2
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	P015
Company Equipment ID:	GEN-H2
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable



**Environmental
Protection
Agency**

Final Permit-to-Install and Operate

Cologix - COL 5

Permit Number: P0138685

Facility ID: 0121000483

Effective Date: 12/10/2025

--

List of Commonly Used Abbreviations

AP-42 = U.S. EPA's Compilation of Air Pollution Emissions Factors	HVLP = high volume, low pressure	PER = Permit Evaluation Report
ASTM = American Society for Testing and Materials	LAER = lowest achievable emission rate	PM = particulate matter
BACT = Best Available Control Technology	lb(s)/hr = pound(s) per hour	PM ₁₀ = particulate matter with an aerodynamic diameter less than or equal to 10 microns
BAT = Best Available Technology	LDAR = leak detection and repair	PM _{2.5} = particulate matter with an aerodynamic diameter less than or equal to 2.5 microns
CAA = Clean Air Act	LPG = liquefied petroleum gas/propane	ppb = parts per billion
CAM = compliance assurance monitoring	MACT = maximum achievable control technology	ppm = parts per million
CEMS = continuous emissions monitoring system	MAGLC = maximum acceptable ground level concentration	PSD = Prevention of Significant Deterioration
CFC = chlorofluorocarbon	mg/m ³ = milligrams per cubic meter	psi = pounds per square inch
CFR = Code of Federal Regulations	MM = million	psia = pounds per square inch absolute
CH ₄ = methane	MMBtu = million British Thermal Units	PTE = potential-to-emit
CI = compression ignition	MSDS = material safety data sheet	PTI = Permit-to-Install
CO = carbon monoxide	MSW = municipal solid waste	PTIO = Permit-to-Install and Operate
CO ₂ = carbon dioxide	NAAQS = National Ambient Air Quality Standard	PTO = Permit-to-Operate
COM = continuous opacity monitor	NESHAP = National Emission Standard for Hazardous Air Pollutants	PWR = process weight rate
DAPC = Division of Air Pollution Control	NG = natural gas	RACM = reasonably available control measures
DO/LAA = District Office/Local Air Agency	ng/m ³ = nanograms per cubic meter	RACT = reasonably available control technology
dscf = dry standard cubic foot	NH ₃ = ammonia	RATA = relative accuracy test audit
EAC = emissions activity category	NMHC = non-methane hydrocarbons	RTO = regenerative thermal oxidizer
eDocs = electronic documents database	NMOC = non-methane organic compound	SB265 = Senate Bill 265
ERAC = Environmental Review Appeals Commission	NO = nitrogen oxide	scfm = standard cubic feet per minute
ESP = electrostatic precipitator	NO ₂ = nitrogen dioxide	SI = spark ignition
EU = emissions unit	NO _x = nitrogen oxides	SIP = State Implementation Plan
FEPTIO = Federally Enforceable Permit-to-Install and Operate	NSPS = New Source Performance Standard	SO ₂ = sulfur dioxide
FER = Fee Emissions Report	NSR = New Source Review	SSMP = startup, shutdown, and malfunction plan
FR = Federal Register	NTV = Non-Title V	TDS = total dissolved solids
GACT = generally achievable control technology	O&M = operation and maintenance	TLV = threshold limit value
GHG = greenhouse gases	OAC = Ohio Administrative Code	TO = thermal oxidizer
gr/dscf = grains per dry standard cubic foot	OC = organic compound	TPH = ton(s) per hour
H ₂ S = hydrogen sulfide	Ohio EPA = Ohio Environmental Protection Agency	TPY = ton(s) per year
H ₂ SO ₄ = sulfuric acid	ORC = Ohio Revised Code	TSP = total suspended particulates
HAP = hazardous air pollutant	Pb = lead	VE = visible emissions
HCl = hydrogen chloride	PBR = Permit-By-Rule	VMT = vehicle miles traveled
HF = hydrogen fluoride	PCB = polychlorinated biphenyl	VOC = volatile organic compound
Hg = mercury	PE = particulate emissions	WPP = work practice plan
hp = horsepower	PEMS = predictive emissions monitoring system	µg/m ³ = micrograms per cubic meter



A. Standard Terms and Conditions

1. What does this permit-to-install and operate (PTIO) allow me to do?

This permit allows you to install and operate the emissions unit(s) identified in this PTIO. You must install and operate the unit(s) in accordance with the application you submitted and all the terms and conditions contained in this PTIO, including emission limits and those terms that ensure compliance with the emission limits (for example, operating, recordkeeping and monitoring requirements).

2. Who is responsible for complying with this permit?

The person identified on the "Authorization" page, above, is responsible for complying with this permit until the permit is revoked, terminated, or transferred. "Person" means a person, firm, corporation, association, or partnership. The words "you," "your," or "permittee" refer to the "person" identified on the "Authorization" page above.

The permit applies only to the emissions unit(s) identified in the permit. If you install or modify any other equipment that requires an air permit, you must apply for an additional PTIO(s) for these sources.

3. What records must I keep under this permit?

You must keep all records required by this permit, including monitoring data, test results, strip-chart recordings, calibration data, maintenance records, and any other record required by this permit for five years from the date the record was created. You can keep these records electronically, provided they can be made available to Ohio EPA during an inspection at the facility. Failure to make requested records available to Ohio EPA upon request is a violation of this permit requirement.

4. What are my permit fees and when do I pay them?

There are two fees associated with permitted air contaminant sources in Ohio:

- a) PTIO fee. This one-time fee is based on a fee schedule in accordance with Ohio Revised Code (ORC) section 3745.11 or based on a time and materials charge for permit application review and permit processing if required by the Director.

You will be sent an invoice for this fee after you receive this PTIO and payment is due within 30 days of the invoice date. You are required to pay the fee for this PTIO even if you do not install or modify your operations as authorized by this permit.

- b) Annual emissions fee. Ohio EPA will assess a separate fee based on the total annual emissions from your facility. You self-report your emissions in accordance with Ohio Administrative Code (OAC) Chapter 3745-78. This fee assessed is based on a fee schedule in ORC section 3745.11 and funds Ohio EPA's permit compliance oversight activities. For facilities that are permitted as synthetic minor sources, the fee schedule is adjusted annually for inflation. Ohio EPA will notify you when it is time to report your emissions and to pay your annual emission fees.

5. When does my PTIO expire, and when do I need to submit my renewal application?

This permit expires on the date identified at the beginning of this permit document (see "Authorization" page above) and you must submit a renewal application to renew the permit. Ohio EPA will send a renewal notice to you approximately six months prior to the expiration date of this permit. However, it is very important that you submit a complete renewal permit application (either electronically through Ohio EPA's eBusiness Center: Air Services web service or postmarked prior to expiration of this permit) even if you do not receive the renewal notice.

If a complete renewal application is submitted before the expiration date, Ohio EPA considers this a timely application for purposes of ORC section 119.06, and you are authorized to continue operating the emissions unit(s) covered by this permit beyond the expiration date of this permit until final action is taken by Ohio EPA on the renewal application.

6. What happens to this permit if my project is delayed or I do not install or modify my source?

This PTIO expires 18 months after the issue date identified on the "Authorization" page above unless otherwise specified if you have not (1) started constructing the new or modified emission sources identified in this permit, or (2) entered into a binding contract to undertake such construction. This deadline can be extended once by 12 months, provided you apply to Ohio EPA for this extension within a reasonable time before the 18-month period has ended and you can show good cause for any such extension.

7. What reports must I submit under this permit?

An annual permit evaluation report (PER) is required in addition to any malfunction reporting required by OAC rule 3745-15-06 or other specific rule-based reporting requirement identified in this permit. Your PER due date is identified in the Authorization section of this permit.

8. If I am required to obtain a Title V operating permit in the future, what happens to the operating provisions and permit evaluation report (PER) obligations under this permit?

If you are required to obtain a Title V permit under OAC Chapter 3745-77 in the future, the permit-to-operate portion of this permit will be superseded by the issued Title V permit. From the effective date of the Title V permit forward, this PTIO will effectively become a PTI (permit-to-install) in accordance with OAC rule 3745-31-02(B). The following terms and conditions of this permit will no longer be applicable after issuance of the Title V permit: Section B, Term 1.b) and Section C, for each emissions unit, Term a)(2).

The PER requirements in this permit remain effective until the date the Title V permit is issued and is effective and cease to apply after the effective date of the Title V permit. The final PER obligation will cover operations up to the effective date of the Title V permit and must be submitted on or before the submission deadline identified in this permit on the last day prior to the effective date of the Title V permit.

9. What are my obligations when I perform scheduled maintenance on air pollution control equipment?

You must perform scheduled maintenance of air pollution control equipment in accordance with OAC rule 3745-15-06(A). If scheduled maintenance requires shutting down or bypassing any air pollution control equipment, you must also shut down the emissions unit(s) served by the air pollution control equipment during maintenance, unless the conditions of OAC rule 3745-15-06(A)(3) are met. Any emissions that exceed permitted amount(s) under this permit (unless specifically exempted by rule) must be reported as deviations in the annual permit evaluation report (PER), including nonexempt excess emissions that occur during approved scheduled maintenance.

10. Do I have to report malfunctions of emissions units or air pollution control equipment? If so, how must I report?

If you have a reportable malfunction of any emissions unit(s) or any associated air pollution control system, you must report this to the Ohio EPA DAPC, Central Office in accordance with OAC rule 3745-15-06(B). Malfunctions that must be reported are those that result in emissions that exceed permitted emission levels. It is your responsibility to evaluate control equipment breakdowns and operational upsets to determine if a reportable malfunction has occurred.

If you have a malfunction but determine that it is not a reportable malfunction under OAC rule 3745-15-06(B), it is recommended that you maintain records associated with control equipment breakdown or process upsets. Although it is not a requirement of this permit, Ohio EPA recommends that you maintain records for non-reportable malfunctions.

11. Can Ohio EPA or my local air agency inspect the facility where the emission unit(s) is/are located?

Yes. Under Ohio law, the Director or his/her authorized representative may inspect the facility, conduct tests, examine records or reports to determine compliance with air pollution laws and regulations and the terms and conditions of this permit. You must provide, within a reasonable time, any information Ohio EPA requests either verbally or in writing.

12. What happens if one or more emissions units operated under this permit is/are shut down permanently?

Ohio EPA can terminate the permit terms associated with any permanently shut down emissions unit. "Shut down" means the emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31.

You should notify Ohio EPA of any emissions unit that is permanently shut down by submitting a certification that identifies the date on which the emissions unit was permanently shut down. The certification must be submitted by an authorized official from the facility. You cannot continue to operate an emission unit once the certification has been submitted to Ohio EPA by the authorized official.

You must comply with all recordkeeping and reporting for any permanently shut down emissions unit in accordance with the provisions of the permit, regulations or laws that were enforceable during the period of operation, such as the requirement to submit a PER, air fee emission report, or malfunction report. You must also keep all records relating to any permanently shut down emissions unit, generated while the emissions unit was in operation, for at least five years from the date the record was generated.

Again, you cannot resume operation of any emissions unit certified by the authorized official as being permanently shut down without first applying for and obtaining a permit pursuant to OAC Chapter 3745-31.

13. Can I transfer this permit to a new owner or operator?

You can transfer this permit to a new owner or operator. If you transfer the permit, the new owner or operator must follow the procedures in OAC Chapter 3745-31-07, including notifying Ohio EPA or the local air agency of the change in ownership or operator within thirty days of the transfer date. Any transferee of this permit shall assume the responsibilities of the transferor permit holder.

14. Does compliance with this permit constitute compliance with OAC rule 3745-15-07, "air pollution nuisance"?

This permit and OAC rule 3745-15-07 prohibit operation of the air contaminant source(s) regulated under this permit in a manner that causes a nuisance. Ohio EPA can require additional controls or modification of the requirements of this permit through enforcement orders or judicial enforcement action if, upon investigation, Ohio EPA determines existing operations are causing a nuisance.



15. What happens if a portion of this permit is determined to be invalid?

If a portion of this permit is determined to be invalid, the remainder of the terms and conditions remain valid and enforceable. The exception is where the enforceability of terms and conditions are dependent on the term or condition that was declared invalid.



B. Facility-Wide Terms and Conditions

1. This permit document constitutes a PTI issued in accordance with ORC 3704.03(F) and a PTO issued in accordance with ORC 3704.03(G).
 - a) For the purpose of a PTI document, the facility-wide T&C identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
 - (1) None.
 - b) For the purpose of a PTO document, the facility-wide T&C identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
 - (1) None.
2. All applications, notifications or reports required in writing are to be submitted through Ohio EPA's eBusiness Center: Air Services online web portal. Hardcopy submissions will be accepted on an as-needed basis if the permittee cannot submit the required documents through Air Services. In the event of a hardcopy submission, the post-marked date or the date the document is delivered in person will be recognized as the date submitted. Electronic submittal of applications, notifications or reports to Ohio EPA fulfills the requirement to submit information to the director, the DO/LAA, and/or any other individual or organization identified as a recipient unless otherwise specified in this permit. Consistent with OAC rule 3745-15-03, the application, notification or report is considered submitted on the date the submittal is successful using a valid electronic signature. Signature by the signatory authority may be represented as provided through procedures established in Air Services.
3. The Ohio EPA has determined that this facility operates affected sources that are subject to the requirements of 40 CFR Part 63, Subpart ZZZZ, the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines. Ohio EPA is not accepting the delegation authority to implement and enforce the area source requirements of this NESHAP standard. The area source requirements of this NESHAP standard are implemented and enforced by U.S. EPA, Region 5. The promulgated version of this NESHAP standard and the 40 CFR Part 63, General Provisions may be accessed via the Internet from the Electronic Code of Federal Regulations (e-CFR) website <http://www.ecfr.gov/> or by contacting the Ohio EPA, DO/LAA.



C. Emissions Unit Terms and Conditions



1. Emissions Unit Group - Emergency Generators: P001, P002, P003, P004, P005, P006, P007, P008, P009, P010, P011, P012, P013, P014 and P015.

EU ID	Operations, Property and/or Equipment Description
P001	2505 kW Emergency Generator
P002	2505 kW Emergency Generator
P003	2505 kW Emergency Generator
P004	2505 kW Emergency Generator
P005	2505 kW Emergency Generator
P006	2505 kW Emergency Generator
P007	2505 kW Emergency Generator
P008	2505 kW Emergency Generator
P009	2505 kW Emergency Generator
P010	2505 kW Emergency Generator
P011	2505 kW Emergency Generator
P012	2505 kW Emergency Generator
P013	2505 kW Emergency Generator
P014	2505 kW Emergency Generator
P015	2505 kW Emergency Generator

- a) This permit document constitutes a PTI issued in accordance with ORC 3704.03(F) and a PTO issued in accordance with ORC 3704.03(G).
- (1) For the purpose of a PTI document, the EU T&C identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
- a. None.
- (2) For the purposes of a PTO document, the EU T&C identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
- a. See b)(1)e., c)(2), d)(5), e)(1), and f)(1)d. below.
- b) Applicable Emissions Limitations and/or Control Requirements
- (1) The specific operation(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures are identified below. Emissions from each unit shall not



exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-31-05(A)(3)(a)(ii)	See b)(2)a below.
b.	OAC rule 3745-17-07(A)	Visible particulate emissions (PM) from the stack serving this emissions unit shall not exceed 20 percent opacity as a six-minute average, except as provided by rule.
c.	OAC rule 3745-17-11(B)(5)(b)	Particulate emissions from the engine's exhaust shall not exceed 0.062 lb/MMBtu actual heat input.
d.	OAC rule 3745-18-06(G)	Sulfur dioxides (SO ₂) emissions shall not exceed 0.5 lb/MMBtu actual heat input.
e.	OAC rule 3745-31-05(D) [Federally enforceable limitations to avoid Title V]	Nitrogen oxides (NO _x) emissions from emissions units P001 through P015, combined, shall not exceed 99.87 tons per rolling, 12-month period. See c)(2) below.
f.	OAC rule 3745-110-03	See b)(2)f. below.
g.	40 CFR Part 60, Subpart IIII 40 CFR 60.4202(b)(2) 40 CFR 60.4205(b) 40 CFR 60.4207(b) 40 CFR Part 1039, Appendix I, Tier 2 40 CFR 1039.105	The emissions unit shall be certified to meet the following emissions standards: 0.20 grams PM/kW-hr; 6.4 grams NO _x + NMHC/kW-hr; 3.5 grams CO/kW-hr; 20 percent opacity during the acceleration mode; 15 percent opacity during the lugging mode; and 50 percent opacity during the peaks in either the acceleration or lugging modes. See b)(2)b. through b)(2)d. and c)(1) below.
h.	40 CFR Part 60, Subpart A	Table 8 to 40 CFR Part 60, Subpart IIII- "Applicability of General Provisions to Subpart IIII" identifies which parts of the General Provisions in 40 CFR Part 60.1-19 apply.

(2) Additional Terms and Conditions

- a. The Best Available Technology (BAT) requirements under OAC rule 3745-31-05(A)(3) do not apply since the unrestricted potential to emit for carbon monoxide



(CO), volatile organic compounds (VOC), PM, and SO₂ are less than 10 tons per year. The BAT requirements do not apply to the NO_x emissions from this air contaminant source since the potential to emit is less than 10 tons/year taking into account the federally enforceable restriction in OAC rule 3745-31-05(D).

- b. The emergency stationary compression ignition (CI) internal combustion engine (ICE) is subject to and shall be operated in compliance with the requirements of 40 CFR Part 60, Subpart IIII, the standards of performance for stationary CI ICE.
- c. The emergency stationary CI ICE has been or shall be purchased certified by the manufacturer to emission standards as stringent as those identified in 40 CFR 60.4202(b)(2), including the Tier 2 standards in 40 CFR 1039, Appendix I for engines greater than or equal to 750 horsepower (560 kilowatt) and the smoke standards as specified in 40 CFR 1039.105.
- d. The emergency stationary ICE must comply with the applicable requirements specified in 40 CFR 60.4211(f) in order to be considered an emergency stationary ICE under Part 60, Subpart IIII.
- e. This emergency stationary CI ICE shall burn only ULSD, hydrogenated renewable diesel, or a blend of ULSD and hydrogenated renewable diesel that meets the following conditions:
 - i. The fuel shall meet the ICE manufacturer's fuel specifications for the specific make and model of engine. In accordance with the information provided in the permit application, hydrogenated renewable diesel fuel shall comply with the requirements of EN15940 and ASTM D975.
 - ii. The fuel shall not contravene the ICE's Tier 2 certification.
 - iii. The fuel shall meet the following per-gallon ULSD standards:
 - (a) A maximum sulfur content of 15 ppm (0.0015% sulfur by weight); and
 - (b) A cetane index or aromatic contents, as follows:
 - (i) A minimum cetane index of 40; or
 - (ii) A maximum aromatic content of 35 volume percent.
- f. For the purpose of meeting the exemption in OAC rule 3745-110-03(K)(2), the emergency stationary CI ICE shall not be operated in any consecutive 12-month period to equal or exceed 500 hours of operation. If the engine operation equals or exceeds 500 hours during any consecutive 12-month period, the NO_x emissions shall not exceed 3.0 g/hp-hr; and the permittee shall demonstrate compliance in accordance with OAC 3745-110-05.

c) Operational Restrictions

- (1) The emergency stationary CI ICE shall be installed, operated, and maintained according to the manufacturer's emission-related written instructions and the permittee shall only change those emission-related settings that are allowed by the manufacturer. The CI ICE must also be installed and operated to meet the applicable requirements from 40 CFR Part 60, Subpart IIII; 40 CFR Part 1039, Control of Emissions from New and In-use Nonroad CI Engines; and



40 CFR Part 1068, the General Compliance Provisions for Highway, Stationary, and Nonroad Programs. The permittee shall operate and maintain the stationary CI ICE to achieve the emissions standards established in 40 CFR 60.4205 over the entire life of the engine.

- (2) The individual hours of operation for emissions units P001 through P015 shall not exceed 300 hours per rolling, 12-month period.
- d) **Monitoring and/or Recordkeeping Requirements**
- (1) The permittee shall maintain the manufacturer's certification, to the applicable Tier 2 emission standards in 40 CFR 1039, Appendix I, on site or at a central location for all facility ICE and it shall be made available for review upon request. If the manufacturer's certification is not kept on site, the permittee shall maintain a log for the location of each ICE and it shall identify the agency-assigned emissions unit number, the manufacturer's identification number, and the identification number of the certificate. The manufacturer's operations manual and any written instructions or procedures developed by the permittee and approved by the manufacturer shall be maintained at the same location as the ICE.
 - (2) The permittee shall maintain documents provided by the oil supplier for each shipment of fuel oil to demonstrate compliance with the ULSD requirement. These documents must include the receipt or bill of lading that includes confirmation that the fuel meets the ULSD standard.
 - (3) For each day during which the permittee burns a fuel other than ultra-low sulfur diesel (ULSD), Hydrogenated vegetable oil, or a blend of ULSD and Hydrogenated vegetable oil, the permittee shall maintain a record of the type, percent sulfur content, and quantity of fuel burned in this emissions unit.
 - (4) The emergency stationary CI ICE shall be installed with a non-resettable hour meter prior to startup of the engine.
 - (5) The permittee shall maintain monthly records of the following information for emissions units P001 through P015:
 - a. the total number of hours the engine was in operation;
 - b. the number of hours spent in emergency operation;
 - c. what classified the operation as an emergency;
 - d. the number of hours spent in non-emergency operation;
 - e. the number of hours in maintenance checks and readiness testing;
 - f. the rolling, 12-month summation of the number of hours the engine was in operation; and
 - g. the rolling, 12-month summation of NO_x emissions from emissions units P001 through P015, combined, in tons.

The NO_x emissions from emissions units P001 through P015 shall be calculated using the maximum hourly NO_x emission rates based on the manufacturer's technical specifications. The maximum emission rates provided in the permit application, A0079551, is 44.35 pounds of NO_x per hour.



e) Reporting Requirements

- (1) The permittee shall submit quarterly deviation (excursion) reports that identify:
 - a. All deviations (excursions) of the following emission limitations, operational restrictions, and/or control device operating parameter limitations that restrict the PTE of any regulated air pollutant and have been detected by the monitoring, record keeping, and/or testing requirements in this permit:
 - i. all exceedances of the rolling, 12-month hours of operation limitation specified in c)(2) above; and
 - ii. all exceedances of the rolling, 12-month NO_x emissions limitation.
 - b. The probable cause of each deviation (excursion).
 - c. Any corrective actions that were taken to remedy the deviations (excursions) or prevent future deviations (excursions).
 - d. The magnitude and duration of each deviation (excursion).

If no deviations (excursions) occurred during a calendar quarter, the permittee shall submit a report that states no deviations (excursions) occurred during the quarter.

The quarterly reports shall be submitted each year by January 31 (covering October to December), April 30 (covering January to March), July 31 (covering April to June), and October 31 (covering July to September), unless an alternative schedule has been established and approved by the appropriate Ohio EPA DO/LAA.
- (2) The permittee shall submit an annual PER to Ohio EPA by the due date identified in the Authorization section of this permit. The PER shall cover a reporting period of no more than 12 months for each air contaminant source identified in this permit.
- (3) The permittee shall submit a revised EAC form that identifies the serial number for the engine within 30 days after placement on its concrete pad. The form shall be submitted via Ohio EPA's eBusiness Center: Air Services online web portal.

f) Testing Requirements

- (1) Compliance with the Emissions Limitations and/or Control Requirements specified in section b) of these terms and conditions shall be determined in accordance with the following methods:
 - a. Emissions Limitation

Visible particulate emissions from the stack serving this emissions unit shall not exceed 20% opacity as a 6-minute average, except as specified by rule.

Applicable Compliance Method

If required, compliance with the stack visible particulate emissions limitation shall be determined through visible emissions observations performed in accordance with U.S. EPA Reference Method 9 in 40 CFR Part 60, Appendix A.
 - b. Emissions Limitation

Particulate emissions from the engine's exhaust shall not exceed 0.062 lb/MMBtu actual heat input.

Applicable Compliance Method



Compliance shall be determined based on the manufacturer's technical data sheet specifying maximum PM emissions rates that are equal to or less than 0.143 g/kWh (0.107 g/hp-hr) at 100% load and 0.19 g/kWh (0.141 g/hp-hr) at 75% load.

If required, the permittee shall demonstrate compliance with this emission limitation in accordance with the methods and procedures specified in OAC rule 3745-17-03(B)(10).

c. Emissions Limitation

SO₂ emissions shall not exceed 0.5 lb/MMBtu actual heat input.

Applicable Compliance Method

Compliance shall be determined using documents required in d)(2) above. Emissions of SO₂ shall be calculated in accordance with OAC rule 3745-18-04(F)(2) using the maximum fuel sulfur content of 15 ppm.

d. Emissions Limitations

NO_x emissions from emissions units P001 through P015, combined, shall not exceed 99.78 tons per rolling, 12-month period.

Applicable Compliance Method

Compliance with these emissions limitations shall be determined in accordance with the recordkeeping specified in d)(5).

e. Emissions Limitations

The emissions unit shall be certified to meet the following emissions standards:

0.20 grams PM/kW-hr;

6.4 grams NO_x + NMHC/kW-hr; and

3.5 grams CO/kW-hr;

20 percent opacity during the acceleration mode;

15 percent opacity during the lugging mode; and

50 percent opacity during the peaks in either the acceleration or lugging modes.

Applicable Compliance Method

Compliance with the emissions limitations shall be based on the manufacturer's certification and by maintaining the engine according to the manufacturer's instructions.

g) **Miscellaneous Requirements**

(1) None.